

## # OPC-UA Signal Mapping

| Variable     | Type   | OPC-UA Node ID                      | Access     |
|--------------|--------|-------------------------------------|------------|
|              |        |                                     |            |
| xStart       | BOOL   | ns=4;s= var ...PLC_PRG.xStart       | Read/Write |
| xStop        | BOOL   | ns=4;s= var ...PLC_PRG.xStop        | Read/Write |
| xRunning     | BOOL   | ns=4;s= var ...PLC_PRG.xRunning     | Read       |
| iCycleCount  | INT    | ns=4;s= var ...PLC_PRG.iCycleCount  | Read       |
| rTemperature | REAL   | ns=4;s= var ...PLC_PRG.rTemperature | Read       |
| sState       | STRING | ns=4;s= var ...PLC_PRG.sState       | Read       |

## ## Security Model

- Anonymous group: View only (read)
- Operator account: Service group with Modify rights (read + write)
- Authentication: Username/Password via AUTO\_NEGOTIATE