



PU FOAM

- DESCRIPTION:** PU Foam is a universal foam for filling and tying in exterior and interior construction work. For fixing doors, window frames, filling holes and cracks and thermal pipe isolation. Resistant to all weather conditions including vaporizing of salty water and moist.
- FEATURES:** Under the conditions of 25 degrees Celsius and 50 air humidity, cutting can be completed within 20minutes after construction. The most commonly used building substrates have good adhesion. It has good weather resistance and strong anti shrinkage ability, suitable for large logarithmic materials.
- APPLICATION DETAILS:** The application surface must be solid, clean, dry and free of dust, oil and grease. Surfaces must be moisturized before the application of PU foam. The most suitable in temperature for use of PU foam is between 20-25°C. Low temperature cans should be used after storage at room temperature for a period of time (20min). Shake the tube vigorously about 30 times before use.

DATA:

PRODUCT DATA SHEET	
Exterior	Liquid in the tank, hard foam after solidification
Density	$\geq 10\text{kg/m}^3$
Coefficient of heat conductivity (35°C)	$\leq 0.050\text{W}/(\text{m} \cdot \text{K})$
Bubbling times	$\geq (\text{Labeled value} - 10) \text{ multiple}$
dimensional stability 23°C/48h	Foaming direction $\leq 5\%$
	Planar orientation $\leq 5\%$
Shear strength (aluminum plate)	$\geq 80\text{kPa}$
Tensile bonding strength	
Cement mortar board	$\geq 60\text{kPa}$
Aluminum plate (standard conditions)	$\geq 80\text{kPa}$
Aluminum plate (soaked for 7 days)	$\geq 60\text{kPa}$
PVC plastic board (standard conditions)	$\geq 80\text{kPa}$
PVC plastic board (soaked for 7 days)	$\geq 60\text{kPa}$

Note: The basis for fire inspection is GB 8624-2012 and GB/T 8626-2007

PACKAGING : 250ml/pc, 500ml/pc, 500ml/pc, 350g-1000g,
12pcs/ctn, 15pcs/ctn.

Attention: Due to the possibility of future product upgrades, key technical data or the description of this product in this publication may be changed. Henan Kaysidat New Material Co., Ltd. reserves the right to modify the description without prior notice. Although the information provided is based on our investigation and is trustworthy, Guizhou Mingtai Chemical Technology Co., Ltd. Assumes no responsibility for any performance results that may arise during the use of the products described herein. We or our distributors will not be held responsible for any damages caused to our products. Before use, users should check the quality, safety, and all other performance of our product. This document prohibits any patent attention from being made without permission.

مدار MADAR

PRIME

وصل حديثا NEW ARRIVAL


بخاخ فوم عالي الجودة الحجم (750ml)



207198010



عزل وتثبيت
إطارات النوافذ
والأبواب



سد الفجوات
حول الأنابيب
والتوصيلات

متوفر الآن بجميع الفروع

2.17-F02 COSHH ASSESSMENT

PROJECT/FACILITY NAME	ILMi Science discovery innovation center.	PROJECT/FACILITY CODE	KSA24001
------------------------------	---	------------------------------	----------

HCS USER DETAILS									
NAME			EMP NO		DESIGNATION		DEPARTMENT NAME		
ALI HOSSAIN			24743		SITE MECHANIC		FMD		
DESCRIPTION OF ACTIVITY			The task involves the use of Polyurethane Foam in pressurized aerosol cans for sealing, filling, and insulating gaps, joints, and voids in construction materials such as concrete, brick, wood, and plastic. The foam is applied directly from the can through a nozzle or applicator gun. Once dispensed, the foam expands and cures upon contact with air moisture, forming a rigid, semi-structural material. Activities may take place both indoors and outdoors and may involve working in confined or poorly ventilated areas.						
HAZARDOUS SUBSTANCE NAME (or group of substances)			Diphenylmethane-4,4'-diisocyanate (MDI) – respiratory sensitizer, irritant, Isocyanate prepolymers – potential respiratory and skin sensitizer, Flammable propellants Polyols – may cause skin and eye irritation						
EXPOSURE LIMIT/TOXICITY (OES/WEL* OR LD50*)			The primary hazardous component in polyurethane foam is 4,4'-Methylenediphenyl diisocyanate (MDI), which has a Workplace Exposure Limit (WEL) of 0.02 mg/m³ (8-hour TWA) and 0.07 mg/m³ (15-minute STEL), and an oral LD50 in rats of greater than 2,000 mg/kg. The foam also contains flammable propellants such as dimethyl ether, with a WEL of 400 ppm (8-hour TWA) and 500 ppm (15-minute STEL), and propane/butane, with a WEL of 1,000 ppm (8-hour TWA). These components pose inhalation, skin, and fire hazards if not properly controlled.						
CLASS OF HAZARD						HEALTH EFFECT		HAZARD CATEGORY	
EXPLOSIVE		☒	FLAMMABLE		☒	Respiratory Irritation & Sensitization – Inhalation of isocyanate vapors can cause coughing, wheezing, shortness of breath, and may lead to occupational asthma with repeated exposure.		LOW	☐
OXIDIZING		☐	HAZARDOUS TO ENVIRONMENT		☐	Skin & Eye Irritation – Contact with uncured foam may cause redness, irritation, or allergic skin reactions; vapors or splashes can irritate the eyes.		MEDIUM	☒
ACUTE TOXICITY		☐	SERIOUS HEALTH HAZARD		☐	Long-Term Health Risks – Prolonged or repeated exposure may lead to chronic respiratory issues, and some components are suspected of causing cancer through inhalation.		HIGH	☐
CORROSIVE		☐	HEALTH HAZARD		☒			EXCEPTIONAL	☐
GAS UNDER PRESSURE		☒							

Note: OES – Occupational Exposure Standard / WEL – Workplace Exposure Limit, LD50 – a dose at which 50% of subjects will die.

USE OF HAZARDOUS SUBSTANCE	
NATURE OF USE	Polyurethane foam is used as an expanding sealant and insulation material, applied from aerosol cans or dispensing guns to fill gaps, joints, and cavities in construction and maintenance activities. It cures upon exposure to air moisture, creating a rigid, insulating barrier.

EXPOSURE POTENTIAL				
QUANTITY USED (SPECIFY)	<10mg ☒	10mg – 1g ☐	1g – 100g ☐	>100g ☐
Dense Solid ☐		Dusty Solid ☐	Gas/Aerosol ☐	

2.17-F02 COSHH ASSESSMENT

PHYSICAL CHARACTERISTICS AFFECTING EXPOSURE	Non-volatile Liquid	☐	Volatile Liquid	☒	Highly Volatile liquid	☐
PRIMARY CONTAINMENT	Closed System (CS)	☒	Partially CS	☐	Open System	☐
FREQUENCY OF USE	Occasional	☒	Frequent	☐	Continuous	☐
OVERALL EXPOSURE POTENTIAL	Negligible	☐	Low	☒	Medium	☐
					High	☐

RISK ASSESSMENT										
ROUTE(S) OF CONTACT	Skin	☒	Eyes	☒	Inhalation	☒	Ingestion	☒	Other	☐
ASSESSMENT OF RISK HEALTH	Negligible			☐	Low	☐	Medium	☒	High	☐

2.17-F02 COSHH ASSESSMENT

PRECAUTIONS NECESSARY IN HANDLING AND USE

☒	Hand protection (specify)	Use chemical-resistant gloves, preferably nitrile gloves or butyl rubber gloves, to prevent skin contact with uncured foam and isocyanates. Gloves should be checked regularly for damage and replaced as needed	☒	Use written protocol
☒	Eye and Face protection (specify)	Safety goggles or chemical safety glasses with side protection to prevent foam or vapor contact with the eyes. In situations with a higher risk of splashing, use a face shield in addition to goggles.	☐	Copy attached
☒	Respiratory protection (specify)	Use respiratory protection or move to fresh air	☐	Other (specify)
☐	Specialize clothing (specify)			
SPECIAL STORAGE PRECAUTIONS		Store polyurethane foam cans in a cool, dry, well-ventilated area away from sources of heat, sparks, open flames, and direct sunlight.	DISPOSAL	Empty or fully cured polyurethane foam can be disposed of as general waste, following local regulations.

EMERGENCY PROCEDURES

IN CASE OF SPILLAGE	N/A			
OTHER SPECIFIED EMERGENCY PROCEDURES	N/A			
FIRST AID STANDARD	☒	Non-standard (specify)	☐	
INFORMATION, INSTRUCTION AND TRAINING				
SOURCE OF INFORMATION	MSDS	☒	Other (specify)	☐
TRAINING REQUIRED (SPECIFY)	Chemical handling training internal.			

FINAL ASSESSMENT RISK TO HEALTH IS

Unlikely	☐	Significant but adequately controlled	☒	Significant, and controls needed	☐	Unknown. Actions Needed	☐
----------	--------------------------	---------------------------------------	-------------------------------------	----------------------------------	--------------------------	-------------------------	--------------------------

ACTION TO IMPLEMENT THIS ASSESSMENT

ARE ANY OF THE FOLLOWING REQUIRED?	Monitoring of exposure	☐	Health Surveillance	☒	Workplace air monitoring	☐
	Other (specify)	☐				

FLAMMABLE AND EXPLOSIVES

Is there a substance used or formed that might give rise to a fire or explosion?	Yes ☒	No ☐
If yes, list control measures. A more detailed risk assessment will be required if the lower explosive limit is reached during leak or spillage.		

- Polyurethane foam products typically contain flammable propellants such as propane, butane, or dimethyl ether, which can give rise to fire or explosion hazards, especially if released in confined areas.
-
-
-
-

2.17-F02 COSHH ASSESSMENT

ASSESSOR DETAILS

NAME	EMP NO	DESIGNATION	SIGNATURE	DATE
Shibin Sabu	541116	HSE Coordinator		05-10-25

REVIEWED AND APPROVED BY PROJECT/FACILITY SAFETY MANAGER

NAME	EMP NO	DESIGNATION	SIGNATURE	DATE
Francious Albert Pienaar	539653	HSE Manager		



5.14-F01 HSE COMMUNICATION ATTENDANCE REGISTER

COMPANY NAME	ALEC	DATE	12/10/25
PROJECT/FACILITY NAME	ILMI SCIENCE DISCOVERY & INNOVATION CENTRE	PROJECT/FACILITY CODE	KSA24001
LOCATION			
ZONE			

	NAME	EMP NO	DATE	SIGNATURE
SPEAKER				
ENGINEER				
FOREMAN	Kesar	546955		

TYPE OF COMMUNICATION	TBT ☐	SAFETY ALERT ☐	INCIDENT RECALL ☐	OTHERS (SPECIFY) ☐
-----------------------	------------------------------	---------------------------------------	--	---

TOPIC DISCUSSED	Foam Spray 750ml
-----------------	------------------

(ATTACHED COPY OF TOPIC POINTS DISCUSSED)

NO	NAME	EMP NO	DESIGNATION	COMPANY NAME	SIGNATURE
1.	Sendu	24674	Foamwork	ALEC	
2.	Ramrivan	24064	Foam work	ALEC	
3.	SAMIM	24252	Foam work	ALEC	SAMIM
4.	Ratiquel Hassan	24672	Foam work	ALEC	Ratiquel
5.	Salchawat	24496	Foam work	ALEC	
6.	HAMMAD	25765	Foam work	ALEC	
7.	Roshidul	24461	Foamwork	ALEC	
8.	Bindhyachal	22160	Foamwork	ALEC	
	Abdul Samim	24327	Foamwork	ALEC	
10.	md. Momin	24432	Foam work	ALEC	momin
11.	MUSTFA	24097	Foamwork	ALEC	
12.	S. Ali	24462	Foamwork	ALEC	
13.	UTTAM	24724	Foamwork	ALEC	
14.	md. Rasheed	24398	Foamwork	ALEC	
15.	Parameswaran	24291	Foamwork	ALECC	
16.					
17.					
18.					
19.					
20.					



5.14-F01 HSE COMMUNICATION ATTENDANCE REGISTER

COMPANY NAME	ALEC	DATE	
PROJECT/FACILITY NAME	ILMI SCIENCE DISCOVERY & INNOVATION CENTRE	PROJECT/FACILITY CODE	KSA24001
LOCATION	Chemical Storage Area		
ZONE			

	NAME	EMP NO	DATE	SIGNATURE
SPEAKER				
ENGINEER	UMAR AKRAM	542204		
FOREMAN	Samtesh			

TYPE OF COMMUNICATION	TBT ☒	SAFETY ALERT ☐	INCIDENT RECALL ☐	OTHERS (SPECIFY) ☐
-----------------------	---	---------------------------------------	--	---

TOPIC DISCUSSED	Foam Spray 750ml
(ATTACHED COPY OF TOPIC POINTS DISCUSSED)	

NO	NAME	EMP NO	DESIGNATION	COMPANY NAME	SIGNATURE
1.	Burham	24951	Foam work	ALEC	Burham
2.	Harun Rasid	24971	Foam work	ALEC	Harun Rasid
3.	Abdul Samim	24327	Foam work	ALEC	Abdul Samim
4.	UMAR ALI	24392	Foam work	ALEC	UMAR ALI
5.	Tofayel	24463	Foam work	ALEC	Tofayel
6.	UMAR ALI	24392	Foam work	ALEC	UMAR ALI
7.	Nazim	24396	Foam work	ALEC	Nazim
8.	Parameshwar	24291	Foam work	ALEC	Parameshwar
	Sameem	24252	Foam work	ALEC	Sameem
10.	Indi mira	24745	Foam work	ALEC	Indi mira
11.	md Rifai	24672	Foam work	ALEC	md Rifai
12.	Indi mira	24745	Foam work	ALEC	Indi mira
13.	SENDU	24674	Foam work	ALEC	SENDU
14.	Samim	24252	Foam work	ALEC	Samim
15.	md IUSUF	24466	Foam work	ALEC	md IUSUF
16.	Samim	24252	Foam work	ALEC	Samim
17.	ZAHIDUL	24655	Foam work	ALEC	ZAHIDUL
18.	ZAHIDUL	24655	Foam work	ALEC	ZAHIDUL
19.	Kalam	25140	Foam work	ALEC	Kalam
20.	Harun	24971	Foam work	ALEC	Harun