

Phase 7: The Master Integrator

Economics, Tariffs, and the Coordinated Dance of the Grid

The Virtual Professor

Final Phase of Part I

The Professor's Intuition: The Invisible Product

Electricity is the strangest product in the world. It is invisible, it travels near the speed of light, and it must be consumed the exact microsecond it is produced. How do you put a price tag on a product you cannot hold or store?

Furthermore, you cannot just turn on all your power plants and let them run. You have to play a massive game of chess with nature. If it rains heavily, water is free, so you run your hydro plants. If there is a drought, you have to burn expensive coal. This final phase is about the **Business and Strategy** of power generation. This is where the math meets the money.

1 The Two-Part Tariff: Billing the Invisible

(Core Semester Concept: Why your electricity bill is split in two)

If you look at an industrial electricity bill, the factory is not just charged for the energy they use. They are charged using a **Two-Part Tariff**:

$$\text{Total Bill} = (A \times \text{Maximum Demand in kW}) + (B \times \text{Energy Consumed in kWh}) \quad (1)$$

Why do utilities charge for Maximum Demand (kW)?

Imagine you own a stadium. 364 days a year, you use zero electricity. But on the day of the Grand Finale, you turn on 10,000 massive floodlights all at once. To the utility company, this is a nightmare. To prevent the grid from melting when you turn those lights on, they had to build thicker copper wires, bigger transformers, and keep a backup Gas Turbine running *all year long* just waiting for your one event.

- **The kW charge (Fixed Cost):** Covers the massive capital cost the utility spent building the infrastructure to handle your worst-case "Maximum Demand" spike.
- **The kWh charge (Running Cost):** Covers the actual cost of the coal/gas burned to generate the energy you consumed.

2 The Power Factor Penalty

(Frequently tested in short notes)

Industrial consumers (factories with huge induction motors) are heavily penalized if their Power Factor drops below 0.9. Why?

- **The Physics:** Power Factor is the ratio of *Active Power* (kW - the power that actually does work) to *Apparent Power* (kVA - the total power flowing in the wires).

- **The Economics:** If a factory has a terrible Power Factor (e.g., 0.5), it means they are drawing massive amounts of "Reactive Current" that does zero useful work. However, this useless current still flows through the utility's transmission lines, causing massive I^2R heating losses and taking up capacity in transformers.
- **The Penalty:** Utilities force industries to install Capacitor Banks to fix their power factor locally. If they don't, the utility charges them a massive penalty for wasting transmission line capacity.

3 Depreciation: The Cost of Aging Metal

A power plant costs millions to build, but it will eventually rust and die (usually after 30 to 50 years). The utility must recover this cost slowly over the life of the plant to afford a replacement. This is called **Depreciation**.

3.1 1. Straight-Line Method

The simplest method. The plant loses the exact same amount of value every single year.

$$\text{Annual Depreciation Charge} = \frac{\text{Initial Capital Cost} - \text{Salvage (Scrap) Value}}{\text{Useful Life in Years}} \quad (2)$$

3.2 2. Sinking Fund Method (Exam Favorite)

A more realistic, banking-based method. The utility takes a fixed amount of money (q) every year and puts it into a bank account that earns compound interest (r). By the time the plant dies in n years, the deposits plus the interest will equal the replacement cost.

$$q = \frac{(\text{Initial Cost} - \text{Salvage Value}) \times r}{(1 + r)^n - 1} \quad (3)$$

4 Coordinated Operation: The Hydro-Thermal Dance

(Highly conceptual question often asked in Part I exams)

The grid is a team. A Coal Plant has high capital costs but low running costs (likes to run at Base Load). A Hydro Plant has massive capital costs, zero running costs, but is limited by how much water is in the river.

How do we operate them together throughout the year to save the most money?




Figure 1: The inversion of roles between Hydro and Thermal plants based on the season.

4.1 The Strategy

1. **Wet Season (Monsoon):** The reservoir is overflowing. Water is completely free, but if you don't use it, it spills over the dam and is wasted. Therefore, the **Hydro Plant is forced to run continuously as the Base Load**. The Thermal plant is kept running at minimum capacity and is only fired up to handle the Peak Load.
2. **Dry Season (Summer):** The reservoir is nearly empty. Water is precious. The Thermal plant (which has a steady supply of coal) takes over as the heavy lifter, running continuously as the **Base Load**. The precious remaining water in the dam is conserved carefully, and the Hydro Plant is only opened for a few hours a day to handle the sudden Peak Loads.

Congratulations!

You have successfully reverse-engineered **Part I of the Power Supply Systems Syllabus**. You now understand the grid from the heat of the coal fire, to the shockwaves in the penstock, to the economic tariffs on the factory floor.