AQUA PURE PACKAGED DRINKING WATER

CENTRAL QUALITY CONTROL & ANALYTICAL LABORATORY | ISO 9001:2015 & BIS IS 14543

20L Water Can Batch Analysis Certificate

Routine Batch Release Test Log

Batch No: AQ-2026-B108 | Sampling Date: 04-Nov-2026 | Testing Date: 05-Nov-2026

Sample Type: Finished Packaged Unit | Status: PASS / CONFORMS | Authorized: Dr. S. Rao, Chief Chemist

Parameter	Observed Value	BIS IS 14543 Limit	Compliance
pH Value (at 25 deg C)	7.24	6.5 - 8.5	PASS (Within Range)
Total Dissolved Solids (TDS)	98.4 mg/L	75 - 150 mg/L	PASS (Within Range)
Turbidity	0.08 NTU	Max 2.0 NTU	PASS (Compliant)
Total Hardness (as CaCO3)	54.0 mg/L	Max 200 mg/L	PASS (Compliant)
Calcium (as Ca)	18.2 mg/L	Max 75 mg/L	PASS (Compliant)
Magnesium (as Mg)	8.4 mg/L	Max 30 mg/L	PASS (Compliant)
Chlorides (as Cl)	24.1 mg/L	Max 200 mg/L	PASS (Compliant)
Sulphates (as SO4)	12.6 mg/L	Max 200 mg/L	PASS (Compliant)
Residual Ozone	0.12 mg/L	0.10 - 0.20 mg/L	PASS (Within Range)
Aerobic Microbial Count	0 CFU/ml	Max 20 CFU/ml	PASS (Sterile)
Total Coliform Bacteria	Absent in 250ml	Absent in 250ml	PASS (Sterile)
E. Coli / Faecal Streptococci	Absent in 250ml	Absent in 250ml	PASS (Sterile)

CERTIFICATE CONCLUSION & RELEASE:

The test sample complies fully with all chemical, physical, and microbiological specifications of IS 14543:2018 for Packaged Drinking Water. Batch cleared for commercial market dispatch.