

Appendix A – Preventative Maintenance – Scope of Works

Specified Preventative Maintenance scope of works should be completed to the contracted frequencies. The scope of works for each asset is contained within the appropriate Preventative Maintenance checklist below. Please ensure the below checklists are completed alongside each Preventative Maintenance service, signed, and provided with the invoice as per Special Condition Section 15.6.

4 Changes:

1. Back of House custom field
2. Tech arrival and departure time
3. Asset ID Tag to be included beside the serial number
4. Field for Purchase order number

1. AUTOMATIC ENTRY DOOR

Company	Technician Name	
 AUTOINGRESS	Store Name	Aldi - Echuca (DER080)
	Date of Service	01/10/2025

General Items	When arriving to/departing from site the technician must sign into Rapid Global or equivalent ALDI Contractor Management System (CMS). The technician must check into ServiceChannel and then checkout upon completion. Enquire with staff as to performance of system and any specific issues that need attention. Record and notify store staff of any issues that need to be addressed.
PO Number	

Task	Complete (Y/N)				
	S/N 25201 : E x t e r n a l Entry Include Asset Tag	S/N 25241 : I n t e r n a l Entry Include Asset Tag	S/N 25242 : I n t e r n a l Exit Include Asset Tag	S/N 39883 : C a r p a r k E x t e r n a l Entry Include Asset Tag	S/N 39884 : C a r p a r k I n t e r n a l Entry Include Asset Tag
Check condition of brush/rubber seals					
Check and adjust door guides					
Check brake distance open/close					
Check door alignment					
Check door clearances					
Check that covers are secured					
Check door leaves and sidelights and adjust as required					
Check the integrity of the holding point fixings					
Check all moving parts for signs of wear					
Check electrical components and replace if necessary					
Test electric locking system					
Check motor and gearbox function and operation					

Check anti crush operation and ensure correct opening					
Check the failsafe mechanism/inverter system					
Check microcomputer control unit and adjust if necessary					
Check alignment and tune the photo electric beams and activation sensors					
Test emergency opening under power failure conditions					
Check for loose or damaged glass					
Tighten all loose nuts, bolts, and electrical terminations					
Check power supply, check battery condition and record voltage					
Record battery date (photo required)					
Check and secure wiring					
Clean track and check bottom guide rail					
Clean track wheels					
Check for finger, head, and body traps as per AS5007					
Clean area					
Check for vermin gaps under/around doors					
Ensure service sticker attached with correct dates					
Document any damage to the door					
Review last battery replacement; replace if older than 2 years					
NSW STORES ONLY					
Restore power and set doors to 'lock' mode					
Check doors open upon manual activation of the green push button					

Additional Comments

Store Manager Signature

--	--

Technician Signature

Arrival Time

Departure Time

--

Store Stamp

Next Service Due

--	--

2. AUTOMATIC SLIDING DOOR (BACK OF HOUSE)

Company	Technician Name	
	Store Name	Aldi - Echuca (DER080)
	Date of Service	01/10/2025

General Items	When arriving to/ departing from site the technician must sign into Pegasus or equivalent ALDI Contractor Management System (CMS).
Purchase Order	The technician must check into ServiceChannel and then checkout upon completion. Enquire with staff as to performance of system and any specific issues that need attention. Record and notify store staff of any issues that need to be addressed.

Add a Back of House field to the child record.

Add Serial Number asset details on a row

Task	Complete (Y / N)
Door Detail	Serial number; Asset ID
Check and adjust door guides	
Check brake distance open/close	
Check door alignment	
Check door clearances	
Check that covers are secured	
Check door leaves and adjust as required	
Check the integrity of the holding point fixings	
Check all moving parts for signs of wear	
Check electrical components and replace if necessary	
Test electric locking system	
Check motor and gearbox function and operation	
Check the failsafe mechanism/inverter system	
Check microcomputer control unit and adjust if necessary	
Check alignment and tune the photo electric beams and activation sensors	
Check emergency opening under power failure conditions and adjust if necessary	
Tighten all loose nuts, bolts and electrical terminations	
Check battery condition and record voltage V: _____	
Record date that is on the batteries - photographic evidence to be provided	
Check and secure wiring	
Clean track	
Clean track wheels	
Clean area	

Check for any gaps that would allow ingress of vermin (including underneath each door)	
Document any damage to the door itself	

Additional Comments

Store Manager Signature	
Technician Signature <i>Arrival Time, Departure Time</i>	
Store Stamp <i>(Expand Field)</i>	
Next Service Due	