



GOVERNMENT OF ANDHRA PRADESH

APTC FORM-10



This Challan can be verified
by scanning the QR code at
<https://verify.nidhi.apcfss.in/cfms>

Challan No: **11186830392026**

Challan Creation Date & Time: **30/08/2026 12:24:18 PM**

Status:

Payment Transaction Successful

Treasury/PAO Code:**6801**

STO: **DTAO-Amalapuram**

CFMS Transaction ID:

10100397882026

Service:

1088-Fee for Renewal NOCs

Major Head:

0070 Other Administrative Services

Sub-Major Head:

60 Other Services

Minor Head:

109 Fire Protection and Control

Group Sub-Head:

00 Not Applicable

Sub-Head:

81 Other Receipts

Detailed Head:

000 Not Applicable

Sub-Detailed Head:

000 Not Applicable

Charged/Voted:

V

Non-Contingency/Contingency:

N

Amount Rs:

82000.00

Amount In words Rs:

Eighty two thousand only

Purpose:

FIRE RENEWAL NOC FOR 5 YEARS

Remitter's Name & Address:

MURARJI EDUCATIONAL SOCIETY

**MURARJI EDUCATIONAL SOCIETY EDUCARE ENGLISH
MEDIUM SCHOOL, GEDDADA VILLAGE MAMIDIKUDHURU
MANDAL , DR BR AMBEDKAR KONASEEMA DIST 86**

Remitter's Mobile Number

8686561695

DDO Code:

68011005001

O/o District Disaster Response & Fire Of

Bank Reference Number:

CPAHENTCY0

Payment Date:

30/08/2026

Received RS:.....**82000.00**.....



Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department
Fire No Objection Certificate for Occupancy

File No: 26289/KNS/MSB/2025

Date: __/04/2025

Sir/Madam,


Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Issue of Fire No Objection Certificate for Occupancy to the existing building of (Murarji educational society EDUCARE English medium school) Murarji educational society EDUCARE English medium school, Geddada Village Mamidikuduru mandal Dr Br Ambedkar Konaseema District - Regarding.

Ref: Online Application Dt. 28-04-2025

Having satisfied with the reasonable fire safety measures that you have affirmed to have undertaken in your School/College buildings. I hereby grant Occupancy Fire NOC for a period of One year.


1. Ensue two exits/two staircases for orderly evacuation of teachers, students and staff in case of any fire incident or emergency.
2. Conduct Mock Drill @ twice a year with participation of teachers, students and preferably in presence some of the parents. And take signatures of staff, teachers, parents, student leaders affirming their familiarity with the equipment and its functioning.
3. **Ensured Electrical Safety by observing the following Precautions:**
 - a. Installation of Miniature Circuit Breakers (MCBs) in all floors.
 - b. No Overloading of power sockets in any Educational Building.
 - c. 10 years old wiring to be changed, especially where high power consuming appliances such as Air conditioners, Electrical/Mechanical/Computer labs, High-tech labs, etc., are used.
 - d. Grounding/Earthing shall be done.
 - e. Lightning conductors may be provided for high-rise buildings exceeding 5 floors.
 - f. No High Tension Lines should run inside or in close proximity (< 6 meters) to any Educational institution buildings.
 - g. No charging for EV vehicles @ cellars of School/College buildings.

Let the above be tested and certified by any electrical Engineer without regard to any Jurisdiction under employment of Government of Andhra Pradesh once a year.

For Murarji Educational Society

Secretary & Correspondent

4. As the ensuring safety is a continuous learning process, we will advise from time to time, practical , modern , reliable but not too hard or that require major modifications to your building structure. And you shall undertake to observe these precautions to enhance fire safety.
5. Therefore, this building meets the “reasonable fire safety criteria” as envisaged in NBC and hence the Fire No Objection Certificate for Occupancy is issued.
6. As a Policy, no retrospective application of rules shall be made for building as long as they comply with that NOC requirements till the life of the building.
7. Any clarifications, you are welcome to meet the DG, Fire Services (9441236448) without appointment in his office as ensuring fire safety with better and affordable technology is a , continuous learning and collaborative endeavour.(for school fire safety mock drill, visit https://www.youtube.com/watch?v=OW-oyYEAT_4)

Your Sincerely,


Director General

State Disaster Response & Fire Services
Andhra Pradesh, Vijayawada.


To

The Management of Murarji educational society EDUCARE English medium school,
Murarji educational society EDUCARE English medium school, Geddada Village
Mamidikuduru mandal Dr Br Ambedkar Konaseema District

Copy to the District Educational Officer, Concerned.

Copy to the Secretary Board of Intermediate Education, Andhra Pradesh, Vijayawada

For. Murarji Educational Society


Secretary & Correspondent