

Government of Andhra Pradesh
WQM Water Testing Laboratory
O/o The Dy. Executive Engineer
Rural Water Supply & Sanitation Department
Amalapuram Sub-Division,
Dr.B.R.Ambedkar Konaseema District

Test Report On Chemical&Bacteriological Analysis of Water (DRINKING)
General physical Chemical&Bacteria Parameter


Name of the Village : Geddada
Name of the Mandal / Municipality : Mamidikuduru
Name and address : EDUCARE EM SCHOOL, Door No:1-129/1, Geddada
Name of The Source : RO Water
Description of the test items : 17 CHEMICAL ANALYSIS
Date of Collection : 18.08.2026. Date of Report : 18.08.2026.

Sl.No.	Physcio-Chemical Parameters	Units	Tested Value	As per IS (10500 - 2012)	
				Required (Acceptable Limit)	Permissible Limit (in the absence of alternative source)
1	Colour	Co-Pt	5	5	15
2	Turbidity	NTU	0	0	5
3	pH		6.69	6.5-8.5	No relaxation
4	Electrical Conductivity	micromhos/cm	85	-	-
5	Total Dissolved Solids	mg/lit	55	500	2000
6	Total Alkalinity as CaCO ₃	mg/lit	28	200	600
7	Total Hardness as CaCO ₃	mg/lit	24	200	600
8	Calcium as Ca ⁺⁺	mg/lit	2	75	200
9	Magnesium as Mg ⁺⁺	mg/lit	1	30	100
10	Flouride as F ⁻	mg/lit	0	1.0	1.5
11	Chloride as Cl ⁻	mg/lit	14	250	1000
12	Nitrate as NO ₃ ⁻	mg/lit	0	45	No relaxation
13	Sulphate as SO ₄ ⁻	mg/lit	0	200	400
14	Total Iron as Fe	mg/lit	0	0.3	1
15	Residual Chlorine	mg/lit	0	0.2ppm	2ppm
16	Total Coliform	100ML	<2	No relaxation	No relaxation
17	E Coli	100ML	0	No relaxation	No relaxation

REMARKS :The Above Sample is chemically Satisfied it is fit for drinking purpose

Analyzed by

RbR 18/8/2026
Lab Chemist
RWS & S Sub-Division
Amalapuram
Lab. Chemist / Lab. Microbiologist.



Note : The above said results are related only to the sample tested
Report should not be produced half or full without permission of laboratory