

NEW YORK UNIVERSITY  
SIX METRO TECH CENTER  
BROOKLYN, NY 11201

HYDRAULIC CALCULATIONS FOR

DRAWING NUMBER: DATE: MAY 6, 2015

-DESIGN DATA-

REMOTE AREA NUMBER: REMOTE AREA LOCATION:

OCCUPANCY CLASSIFICATION:

DENSITY: gpm/sq. ft.

AREA OF APPLICATION: sq. ft.

COVERAGE PER SPRINKLER: sq. ft.

TYPE OF SPRINKLERS CALCULATED:

NUMBER OF SPRINKLERS CALCULATED:

\*IN-RACK SPRINKLER DEMAND: gpm

HOSE-STREAM DEMAND: gpm

TOTAL WATER REQUIRED (INCLUDING HOSE): gpm

FLOW AND PRESSURE (AT BASE OF RISER): gpm @ psi

TYPE OF SYSTEM:

\*VOLUME OF DRY OR PREACTION SYSTEM:

\*DETAILS:

WATER SUPPLY

Source: Test Date: Test By:

Location:

Static: psi Residual: psi Flow: gpm

Source Elevation Relative to Finished Floor Level: ft.

INSTALLING CONTRACTOR

Name:

Address:

Phone: Certification number:

NAME OF DESIGNER:

AUTHORITY HAVING JURISDICTION:

NOTES:

Calculations performed by HASS under license # 27021847 ,  
granted by HRS SYSTEMS, INC.

(Notes continue after pipe calculations results.)


DATE: 5/6/2015

C:\WORK\FLUID\TARIQ\_HASS.SDF

JOB TITLE:

WATER SUPPLY ANALYSIS

Static: 85.00 psi Resid: 83.00 psi Flow: 500.0 gpm



DATE: 5/6/2015

C:\WORK\FLUID\TARIQ\_HASS.SDF

JOB TITLE:

## NFPA WATER SUPPLY DATA

SOURCE NODE TAG	STATIC PRESS. (PSI)	RESID. PRESS. (PSI)	FLOW @ (GPM)	AVAIL. PRESS. (PSI)	TOTAL @ DEMAND (GPM)	REQ'D PRESS. (PSI)
SOURCE	85.0	83.0	500.0	84.4	252.8	

## AGGREGATE FLOW ANALYSIS:

TOTAL FLOW AT SOURCE	252.8 GPM
TOTAL HOSE STREAM ALLOWANCE AT SOURCE	0.0 GPM
OTHER HOSE STREAM ALLOWANCES	0.0 GPM
TOTAL DISCHARGE FROM ACTIVE SPRINKLERS	252.8 GPM

## NODE ANALYSIS DATA

NODE TAG	ELEVATION (FT)	NODE TYPE	PRESSURE (PSI)	DISCHARGE (GPM)	NOTES
1	80.0	K= 4.90	11.9	16.9	
2	80.0	- - - -	13.6	- - -	
3	80.0	K= 4.90	13.2	17.8	
4	80.0	K= 4.90	16.2	19.7	
5	80.0	K= 4.90	17.5	20.5	
6	80.0	- - - -	15.3	- - -	
7	80.0	K= 4.90	12.1	17.0	
8	80.0	K= 4.90	9.2	14.8	
9	80.0	K= 4.90	8.4	14.2	
10	80.0	- - - -	21.1	- - -	
11	80.0	K= 4.90	20.3	22.1	
12	80.0	K= 4.90	25.3	24.6	
13	80.0	- - - -	26.5	- - -	
14	80.0	K= 4.90	23.5	23.8	
15	80.0	K= 4.90	20.1	22.0	
16	80.0	- - - -	16.4	- - -	
17	80.0	K= 4.90	15.9	19.6	
18	80.0	K= 4.90	16.4	19.9	
19	0.0	- - - -	72.4	- - -	
20	0.0	- - - -	84.4	- - -	
SOURCE	0.0	SOURCE	84.4	252.8	

DATE: 5/6/2015

C:\WORK\FLUID\TARIQ\_HASS.SDF

JOB TITLE:

## NFPA PIPE DATA

Pipe Tag	K-fac	Add Fl	Add Fl	To	Fit:	L	C	(Pt)	
Frm Node	PT	(q)	Node/	Nom ID	Eq.Ln.	F		(Pe)	Notes
To Node	PT	Tot.(Q)	Disch	Act ID	(ft.)	T	Pf/ft.	(Pf)	
Pipe: 1	4.90	16.9	Disch			17.17	120	1.6	
2	80.0	13.6		1.000	----	0.00		0.0	
1	80.0	11.9		1.049		17.17	0.095	1.6	
Pipe: 2	4.90	17.8	Disch			3.67	120	0.4	
2	80.0	13.6		1.000	----	0.00		0.0	
3	80.0	13.2		1.049		3.67	0.105	0.4	
Pipe: 3	0.0	16.9	1			7.25	120	2.6	
4	80.0	16.2	3	1.000	----	0.00		0.0	
2	80.0	13.6		1.049		7.25	0.361	2.6	
Pipe: 4	4.90	19.7	Disch			6.00	120	1.3	
5	80.0	17.5	2	1.250	----	0.00		0.0	
4	80.0	16.2		1.380		6.00	0.218	1.3	
Pipe: 5	0.0	0.0				13.33	120	2.1	
5	80.0	17.5	7	1.250	----	0.00		0.0	
6	80.0	15.3		1.380		13.33	0.160	2.1	
Pipe: 6	4.90	17.0	Disch			20.33	120	3.3	
6	80.0	15.3	8	1.250	----	0.00		0.0	
7	80.0	12.1		1.380		20.33	0.160	3.3	
Pipe: 7	4.90	14.8	Disch			11.25	120	2.9	
7	80.0	12.1	9	1.000	----	0.00		0.0	
8	80.0	9.2		1.049		11.25	0.260	2.9	
Pipe: 8	4.90	14.2	Disch			10.50	120	0.7	
8	80.0	9.2		1.000	----	0.00		0.0	
9	80.0	8.4		1.049		10.50	0.069	0.7	
Pipe: 9	4.90	20.5	Disch			27.33	120	3.7	
10	80.0	21.1	4	2.000	----	0.00		0.0	
5	80.0	17.5		2.067		27.33	0.134	3.7	
Pipe: 10	4.90	22.1	Disch			5.50	120	0.9	
10	80.0	21.1		1.000	----	0.00		0.0	
11	80.0	20.3		1.049		5.50	0.156	0.9	
Pipe: 11	0.0	121.0	5			22.67	120	4.1	
12	80.0	25.3	11	2.000	----	0.00		0.0	
10	80.0	21.1		2.067		22.67	0.182	4.1	
Pipe: 12	4.90	24.6	Disch			5.17	120	1.3	
13	80.0	26.5	10	2.000	----	0.00		0.0	
12	80.0	25.3		2.067		5.17	0.244	1.3	

DATE: 5/6/2015

C:\WORK\FLUID\TARIQ\_HASS.SDF

JOB TITLE:

Pipe Tag	K-fac	Add Fl	Add Fl	To	Fit:	L	C	(Pt)	
Frm Node	El (ft)	PT	(q)	Node/	Nom ID	Eq.Ln.	F	(Pe)	Notes
To Node	El (ft)	PT	Tot. (Q)	Disch	Act ID	(ft.)	T	Pf/ft.	(Pf)
Pipe: 13		4.90	23.8	Disch			12.75	120	3.0
13	80.0	26.5	61.4	15	1.500	----	0.00		0.0
14	80.0	23.5	85.2		1.610		12.75	0.236	3.0
Pipe: 14		4.90	22.0	Disch			12.42	120	3.4
14	80.0	23.5	39.4	16	1.250	----	0.00		0.0
15	80.0	20.1	61.4		1.380		12.42	0.273	3.4
Pipe: 15		0.0	0.0				8.08	120	3.7
15	80.0	20.1	39.4		1.000	----	0.00		0.0
16	80.0	16.4	39.4		1.049		8.08	0.457	3.7
Pipe: 16		4.90	19.6	Disch			4.00	120	0.5
16	80.0	16.4	0.0		1.000	----	0.00		0.0
17	80.0	15.9	19.6		1.049		4.00	0.125	0.5
Pipe: 17		4.90	19.9	Disch			2.00	120	0.0
16	80.0	16.4	0.0		2.000	----	0.00		0.0
18	80.0	16.4	19.9		2.067		2.00	0.005	0.0
Pipe: 18		0.0	85.2	14			146.83	120	45.9
19	0.0	72.4	167.7	12	3.000	----	0.00		-34.7
13	80.0	26.5	252.8		3.068		146.83	0.076	11.2
Pipe: 19			252.8	13	Fixed Pressure Loss Device				
20	0.0	84.4	0.2		12.0 psi, 253.0 gpm				
19	0.0	72.4	253.0						
Pipe: 20		Source	0.0				2.00	120	0.0
SOURCE	0.0	84.4	252.8	19	4.000	----	0.00		0.0
20	0.0	84.4	252.8		4.026		2.00	0.020	0.0

## NOTES (HASS):

- (1) Calculations were performed by the HASS 8.5 computer program under license no. 27021847 granted by  
HRS Systems, Inc.  
208 Southside Square  
Petersburg, TN 37144  
(931) 659-9760
- (2) The system has been calculated to provide an average imbalance at each node of 0.018 gpm and a maximum imbalance at any node of 0.179 gpm.
- (3) Total pressure at each node is used in balancing the system. Maximum water velocity is 16.0 ft/sec at pipe 12.
- (4) Items listed in bold print on the cover sheet  
  
are automatically transferred from the calculation report.