



MISH 13

SAFETY FORMS

FIRE PREVENTION INSPECTION CHECKLIST INSP

MHC INDUSTRIAL SAFETY AND HEALTH PROGRAM (MISH) — FORMS LIBRARY

FORM IDENTIFICATION & CONTROL

FORM NUMBER

MISH 13

REVISION

1.0

{{FORM_SECTION_LABEL}}

MISH 13

CATEGORY

Safety Forms

EFFECTIVE DATE

June 2026

DOCUMENT OWNER

Safety Officer (Matt Ramsey)

{{FORM_BRIEFING_HEAD}}

- ★ Authority: {{FORM_BRIEFING_AUTHORITY}}
- ★ Use: {{FORM_BRIEFING_USE}}
- ★ Retention: {{FORM_BRIEFING_RETENTION}}
- ★ Revision Control: {{FORM_BRIEFING_REVISION}}

REFERENCE



MISH 13

COMPANY CONTACT

MH Construction, Inc.

3111 N Capitol Ave.

Pasco, WA 99301

(509) 308-6489 • www.mhc-gc.com

WA Lic: MHCONCI907R7 • OR Lic: 194331 • ID Lic: RCE-49250

ACCREDITATION & TRUST



Fire Prevention Inspection Checklist Insp

MISH 13

MH CONSTRUCTION, INC.

Industrial Safety & Health Program (MISH)

FORM-MISH-13 | Fire Prevention Inspection Checklist

Rev. 3 | Effective: 04/07/2026 | Safety Officer: Matt Ramsey

PROJECT INFORMATION

Project Name / Number	
Job Site Address	
Date	
Supervisor / Foreman	
Employee Name(s) (where applicable)	
Subcontractor (where applicable)	

INSPECTION CHECKLIST

Inspection frequency: Monthly (per 29 CFR 1926.150(c)(1) and WAC 296-155-260)

Item #	Inspection Item	Pass	Fail	N/A	Corrective Action Required
1	Are all fire extinguishers properly charged and inspected monthly? (per 29 CFR 1926.150(c)(1))	☐	☐	☐	
2	Are fire extinguishers readily accessible and unobstructed? (per 29 CFR 1926.150(c)(1)(viii))	☐	☐	☐	
3	Are 'No Smoking' signs posted in designated areas? (per 29 CFR 1926.151(a)(3))	☐	☐	☐	
4	Are flammable liquids stored in approved containers and cabinets? (per 29 CFR 1926.152(a)(1))	☐	☐	☐	
5	Is proper ventilation provided when handling flammable liquids? (per 29 CFR 1926.152(g)(3))	☐	☐	☐	
6	Are ignition sources controlled in areas where flammable materials are present? (per 29 CFR 1926.151(b)(1))	☐	☐	☐	
7	Are waste materials and debris properly disposed of to prevent fire hazards? (per 29 CFR 1926.25(c))	☐	☐	☐	
8	Are temporary heating devices safely installed and maintained? (per 29 CFR 1926.154(a))	☐	☐	☐	
9	Are fire brigades organized and trained if required? (per 29 CFR 1926.150(a)(5))	☐	☐	☐	
10	Are fire alarms and communication systems functional? (per 29 CFR 1926.150(e))	☐	☐	☐	

11	Are emergency exits clearly marked and unobstructed? (per WAC 296-155-260(2))	☐	☐	☐	
12	Is hot work being performed with appropriate permits and fire watch? (per WAC 296-155-265(1))	☐	☐	☐	
13	Are combustible materials stored away from heat sources? (per WAC 296-155-265(2))	☐	☐	☐	
14	Are electrical cords and equipment in good condition and not overloaded? (per WAC 296-155-265(3))	☐	☐	☐	
15	Are employees trained on fire prevention and emergency procedures? (per WAC 296-155-260(1))	☐	☐	☐	

DEFICIENCY LOG

Item #	Description of Deficiency	Corrective Action	Assigned To	Due Date	Completed Date

INSPECTOR SIGNATURE

Inspector Name		Signature	
Date		Supervisor Review	

Regulatory Authority

OSHA: 29 CFR 1926 Subpart F; 29 CFR 1926.150 Fire Protection; 29 CFR 1926.151 Fire Prevention

WISHA: WAC 296-155-260 Fire Protection; WAC 296-155-265 Fire Prevention

AGC: Safety and Health Manual Ch. 8 Fire Prevention

This form supports compliance with the above regulations. Retain completed forms for minimum 3 years per 29 CFR 1904.33 and WAC 296-27.

Prepared by:		Title:		Date:	
Reviewed by:		Title:		Date:	