



MISH 29

SAFETY FORMS

ELECTRICAL SAFETY PRE TASK JHA

MHC INDUSTRIAL SAFETY AND HEALTH PROGRAM (MISH) — FORMS LIBRARY

FORM IDENTIFICATION & CONTROL

FORM NUMBER

MISH 29

REVISION

1.0**{{FORM_SECTION_LABEL}}****MISH 29**

CATEGORY

Safety Forms

EFFECTIVE DATE

June 2026

DOCUMENT OWNER

Safety Officer (Matt Ramsey)

{{FORM_BRIEFING_HEAD}}

- ★ Authority: {{FORM_BRIEFING_AUTHORITY}}
- ★ Use: {{FORM_BRIEFING_USE}}
- ★ Retention: {{FORM_BRIEFING_RETENTION}}
- ★ Revision Control: {{FORM_BRIEFING_REVISION}}

REFERENCE



MISH 29

COMPANY CONTACT

MH Construction, Inc.

3111 N Capitol Ave.

Pasco, WA 99301

(509) 308-6489 • www.mhc-gc.com

WA Lic: MHCONCI907R7 • OR Lic: 194331 • ID Lic: RCE-49250

ACCREDITATION & TRUST



Electrical Safety Pre Task JHA

MISH 29

MH CONSTRUCTION, INC.

Industrial Safety & Health Program (MISH)

FORM-MISH-29 | Electrical Safety Pre-Task JHA

Rev. 3 | Effective: 04/07/2026 | Safety Officer: Matt Ramsey

Project Name / Number:		Supervisor / Foreman:	
Job Site Address:		Employee Name(s):	
Date:		Subcontractor:	

Task Description: _____

Pre-Task Hazard Identification: ☐ Live electrical circuits/equipment ☐ Overhead power lines ☐ Underground utilities ☐ Wet or damp conditions ☐ Damaged cords or tools ☐ Lack of GFCI protection ☐ Inadequate lighting ☐ Confined space entry required ☐ Lockout/Tagout required ☐ Arc flash potential	Required PPE: ☐ Hard Hat (Class E) ☐ Safety Glasses ☐ Voltage Rated Gloves ☐ Leather Protectors ☐ Arc Flash Face Shield ☐ FR Clothing ☐ EH Rated Footwear ☐ Hearing Protection
---	--

Job Hazard Analysis:

Step #	Task Step Description	Potential Hazard	Hazard Control Measure	Responsible Party
1	Identify electrical circuits/equipment	Shock, electrocution	Verify circuits are de-energized using a tested voltage meter	Electrician
2	Apply Lockout/Tagout (LOTO)	Unexpected energization	Apply personal locks and tags to energy isolation devices	Authorized Employee
3	Inspect tools and cords	Shock from damaged equipment	Visually inspect all tools and cords before use; remove damaged items	All Workers
4	Work near overhead lines	Electrocution from contact	Maintain minimum 10-foot clearance; use spotter if necessary	Operator/Spotter
5	Use temporary power	Shock in wet conditions	Ensure all temporary power circuits have GFCI protection	Electrician/Foreman
6				
7				
8				
9				
10				

Emergency Contacts: Nearest Hospital: _____ | Emergency Number: 911 | Site First Aid Location: _____

Regulatory Authority

OSHA: 29 CFR 1926 Subpart K; 29 CFR 1926.404 Wiring Design and Protection GFCI; 29 CFR 1926.416 General Requirements; 29 CFR 1926.417 Lockout and Tagging

WISHA: WAC 296-155-426 Introduction; WAC 296-155-428 General Requirements; WAC 296-155-429 Lockout and Tagging of Circuits; WAC 296-155-447 Wiring Design and Protection

AGC: Safety and Health Manual Ch. 21 Electrical Safety

This form supports compliance with the above regulations. Retain completed forms for minimum 3 years per 29 CFR 1904.33 and WAC 296-27.

Prepared by: _____ | Title: _____ | Date:

Reviewed by: _____ | Title: _____ | Date:
