



MISH 33

SAFETY FORMS

FLOOR OPENING AND OPEN SIDED SURFACE INSPECTION

MHC INDUSTRIAL SAFETY AND HEALTH PROGRAM (MISH) — FORMS LIBRARY

FORM IDENTIFICATION & CONTROL

FORM NUMBER

MISH 33

REVISION

1.0

{{FORM_SECTION_LABEL}}

MISH 33

CATEGORY

Safety Forms

EFFECTIVE DATE

June 2026

DOCUMENT OWNER

Safety Officer (Matt Ramsey)

{{FORM_BRIEFING_HEAD}}

- ★ Authority: {{FORM_BRIEFING_AUTHORITY}}
- ★ Use: {{FORM_BRIEFING_USE}}
- ★ Retention: {{FORM_BRIEFING_RETENTION}}
- ★ Revision Control: {{FORM_BRIEFING_REVISION}}

REFERENCE



MISH 33

COMPANY CONTACT

MH Construction, Inc.

3111 N Capitol Ave.

Pasco, WA 99301

(509) 308-6489 • www.mhc-gc.com

WA Lic: MHCONCI907R7 • OR Lic: 194331 • ID Lic: RCE-49250

ACCREDITATION & TRUST



Floor Opening and Open Sided Surface Inspection

MISH 33

MH CONSTRUCTION, INC.

Industrial Safety & Health Program (MISH)

FORM-MISH-33 | Floor Opening and Open-Sided Surface Inspection

Rev. 3 | Effective: 04/07/2026 | Safety Officer: Matt Ramsey

Project Name / Number:	
Job Site Address:	
Date:	
Supervisor / Foreman:	
Employee Name(s) (where applicable):	
Subcontractor (where applicable):	

Inspection Checklist

Inspection frequency note: Per 29 CFR 1926.20(b)(2) and WAC 296-880-050, regular and frequent inspections of the job site, materials, and equipment shall be made by competent persons.

Item #	Inspection Item	Pass	Fail	N/A	Corrective Action Required
1	Floor openings properly guarded (per 29 CFR 1926.502(b))	☐	☐	☐	

2	Open-sided floors/platforms properly guarded (per 29 CFR 1926.502(b))	☐	☐	☐	
3	Covers for floor openings secured and marked (per 29 CFR 1926.502(i))	☐	☐	☐	
4	Guardrail systems meet height requirements (per 29 CFR 1926.502(b)(1))	☐	☐	☐	
5	Midrails installed (per 29 CFR 1926.502(b)(2))	☐	☐	☐	
6	Toeboards installed where required (per 29 CFR 1926.502(b)(3))	☐	☐	☐	
7	Guardrail systems capable of withstanding 200 lbs force (per 29 CFR 1926.502(b)(4))	☐	☐	☐	
8	Holes 2 inches or more in diameter covered or guarded (per 29 CFR 1926.501(b)(4))	☐	☐	☐	
9	Skylight openings protected (per 29 CFR 1926.501(b)(4))	☐	☐	☐	
10	Protection from falling objects provided (per 29 CFR 1926.501(c))	☐	☐	☐	
11	All fall protection equipment inspected prior to use (per 29 CFR 1926.502(d)(21))	☐	☐	☐	
12	Access to work areas clear and unobstructed	☐	☐	☐	
13	Housekeeping maintained to prevent trip hazards	☐	☐	☐	
14	Warning lines used where appropriate (per 29 CFR 1926.502(f))	☐	☐	☐	
15	Safety nets installed and maintained (per 29 CFR 1926.502(c))	☐	☐	☐	

Deficiency Log

Item #	Description of Deficiency	Corrective Action	Assigned To	Due Date	Completed Date

Inspector Signature Block

Inspector Name: _____ Signature: _____ Date: _____

Supervisor Review: _____ Signature: _____ Date: _____

Regulatory Authority

OSHA: 29 CFR 1926 Subpart M; 29 CFR 1926.502(b) Guardrail Systems; 29 CFR 1926.502(i) Covers

WISHA: WAC 296-880 Unified Fall Protection covers floor openings open-sided surfaces and ramps

AGC: Safety and Health Manual Ch. 7 Fall Protection

This form supports compliance with the above regulations. Retain completed forms for minimum 3 years per 29 CFR 1904.33 and WAC 296-27.

Prepared by: _____ | Title: _____ | Date: _____

Reviewed by: _____ | Title: _____ | Date: _____
