



MISH 12

SAFETY FORMS

FLAMMABLE COMBUSTIBLE LIQUIDS INSPECTION CHECKLIST

MHC INDUSTRIAL SAFETY AND HEALTH PROGRAM (MISH) — FORMS LIBRARY

FORM IDENTIFICATION & CONTROL

FORM NUMBER

MISH 12

REVISION

1.0

{{FORM_SECTION_LABEL}}

MISH 12

CATEGORY

Safety Forms

EFFECTIVE DATE

June 2026

DOCUMENT OWNER

Safety Officer (Matt Ramsey)

{{FORM_BRIEFING_HEAD}}

- ★ Authority: {{FORM_BRIEFING_AUTHORITY}}
- ★ Use: {{FORM_BRIEFING_USE}}
- ★ Retention: {{FORM_BRIEFING_RETENTION}}
- ★ Revision Control: {{FORM_BRIEFING_REVISION}}

REFERENCE



MISH 12

COMPANY CONTACT

MH Construction, Inc.

3111 N Capitol Ave.

Pasco, WA 99301

(509) 308-6489 • www.mhc-gc.com

WA Lic: MHCONCI907R7 • OR Lic: 194331 • ID Lic: RCE-49250

ACCREDITATION & TRUST



Flammable Combustible Liquids Inspection Checklist

MISH 12

MH CONSTRUCTION, INC.

Industrial Safety & Health Program (MISH)

FORM-MISH-12 | Flammable Combustible Liquids Inspection Checklist

Rev. 3 | Effective: 04/07/2026 | Safety Officer: Matt Ramsey

Project Information

Project Name / Number:	
Job Site Address:	
Date:	
Supervisor / Foreman:	
Employee Name(s) (where applicable):	
Subcontractor (where applicable):	

Inspection Checklist

Inspection frequency note: Refer to applicable OSHA/WISHA requirements for inspection frequency.

Item #	Inspection Item	Pass	Fail	N/A	Corrective Action Required
1	Are flammable liquids stored in approved containers? (per 29 CFR 1926.152(a)(1))	☐	☐	☐	
2	Are storage cabinets labeled "FLAMMABLE - KEEP FIRE AWAY"? (per 29 CFR 1926.152(b)(2)(iii))	☐	☐	☐	
3	Is the storage area free of weeds, debris, and other combustible materials? (per 29 CFR 1926.152(c)(5))	☐	☐	☐	
4	Are "No Smoking" signs posted in storage areas? (per 29 CFR 1926.152(b)(3))	☐	☐	☐	
5	Are fire extinguishers readily available near storage areas? (per 29 CFR 1926.152(d)(1))	☐	☐	☐	
6	Are containers closed when not in use? (per 29 CFR 1926.152(f)(1))	☐	☐	☐	
7	Is dispensing of flammable liquids done in a safe manner? (per 29 CFR 1926.152(e)(2))	☐	☐	☐	
8	Are safety cans used for handling flammable liquids? (per 29 CFR 1926.152(a)(1))	☐	☐	☐	
9	Are temporary heating devices located away from combustible materials? (per WAC 296-155-280(1))	☐	☐	☐	

10	Are temporary heating devices properly ventilated? (per WAC 296-155-280(2))	☐	☐	☐	
11	Are fuel lines and connections for heating devices secure and leak-free? (per WAC 296-155-280(3))	☐	☐	☐	
12	Are heating devices placed on stable, non-combustible surfaces? (per WAC 296-155-280(4))	☐	☐	☐	
13	Is there adequate clearance around heating devices? (per WAC 296-155-280(5))	☐	☐	☐	
14	Are employees trained on the safe use of flammable liquids? (per AGC Ch. 8)	☐	☐	☐	
15	Are emergency procedures established for spills or fires? (per AGC Ch. 8)	☐	☐	☐	

Deficiency Log

Item #	Description of Deficiency	Corrective Action	Assigned To	Due Date	Completed Date

Inspector Signature

Inspector Name	Signature	Date
Supervisor Review	Signature	Date

Regulatory Authority

OSHA: 29 CFR 1926 Subpart F; 29 CFR 1926.152 Flammable Liquids

WISHA: WAC 296-155-270 Flammable Liquids; WAC 296-155-280 Temporary Heating Devices

AGC: Safety and Health Manual Ch. 8 Fire Safety

This form supports compliance with the above regulations. Retain completed forms for minimum 3 years per 29 CFR 1904.33 and WAC 296-27.

Prepared by: _____ | Title: _____ | Date: _____

Reviewed by: _____ | Title: _____ | Date: _____