



CONTROLLED ENTERPRISE DOCUMENT

TBT-21.02 | Fire Pump Installation And Hydrostatic Testing

MH Construction, INC Enterprise Management System

Document family: TOOLBOX TALK LIBRARY

Document title: TBT-21.02 | Fire Pump Installation And Hydrostatic Testing

Version: 1.0 | Lifecycle: Rough Draft

Use only after required functional, technical, field-usability, and approval gates are complete.

Control: Version 1.0 | Status Rough Draft | Author and Chief Editor: Matt Ramsey | Co-Editor: Todd Shoeff | Final Approver: Jeremy Thamert

TBT-21.02: Fire Pump Installation & Hydrostatic Testing

CSI Division: Div 21 | Track Assignment: Track 3 MEP & Interior

DIRECTIVE

Hydrostatic testing of fire suppression systems involves immense pressure. All personnel must clear the immediate area during the pressure test.

GENERAL ORDER

Ensure all caps and plugs are rated for the test pressure. Inspect all gauges before applying pressure.

Key Hazards & Mitigation (The 'What If')

- Pipe cap blows off during test — ensure the area is cleared and barricaded before the test begins.
- Water leaks near an electrical panel — stop the test, relieve pressure, protect the panel.
- Worker tries to tighten a fitting under pressure — never adjust fittings while the system is pressurized.

FIELD INSTRUCTION

Foreman: Announce the hydrostatic test to all site crews and barricade the test zone before pressurization.

Attendance Roster (MISH-F-10.1)

Print Name	Signature	Date

Toolbox Talk Documentation & Sign-Off
This Toolbox Talk (TBT) is a mandatory component of the MH Construction, INC Industrial Safety & Health (MISH) Program. All site personnel, including subcontractors and temporary laborers, must attend this briefing before commencing related work activities.

The Site Safety Commander or designated Foreman is responsible for delivering this content, ensuring comprehension, and documenting attendance. Failure to adhere to the safety protocols outlined herein may result in disciplinary action up to and including removal from the jobsite.

By signing the daily attendance log (Form MISH-F-10.1), you acknowledge that you have received, understood, and agree to comply with the safety directives presented in this Toolbox Talk.