



CONTROLLED ENTERPRISE DOCUMENT

TBT-26.01 | Electrical Safety And LOTO

MH Construction, INC Enterprise Management System

Document family: TOOLBOX TALK LIBRARY

Document title: TBT-26.01 | Electrical Safety And LOTO

Version: 1.0 | Lifecycle: Rough Draft

Use only after required functional, technical, field-usability, and approval gates are complete.

Control: Version 1.0 | Status Rough Draft | Author and Chief Editor: Matt Ramsey | Co-Editor: Todd Shoeff | Final Approver: Jeremy Thamert

TBT-26.01: Electrical Safety & LOTO

CSI Division: Div 26 | OSHA Reference: 29 CFR 1926.416
Delivery: Mandatory before working on or near energized electrical circuits.

DIRECTIVE — Policy Standard

No employee shall work on an electrical circuit unless it has been de-energized, tested, and locked out/tagged out (LOTO) in accordance with the MH Construction, INC LOTO Program.

GENERAL ORDER — Procedure

Only qualified electricians may perform live work, and only when de-energizing introduces additional hazards. All other workers must treat all circuits as live until proven dead and locked out.

Key Hazards & Mitigation (The 'What If'):

- Missing Locks: If a breaker is turned off but not locked out, anyone could turn it back on. Every worker exposed to the hazard must apply their own personal lock.
- Extension Cords: If an extension cord has a missing ground prong or damaged insulation, cut the plug off and throw it away. Do not attempt to repair it with electrical tape.
- Arc Flash: If a qualified electrician must open an energized panel, the area must be barricaded, and the electrician must wear the required arc flash PPE (cal-rated suit, face shield, insulated gloves).

FIELD INSTRUCTION — Execution

FIELD INSTRUCTION: Foremen must inspect all extension cords and power tools in use today. Verify LOTO permits for any active shutdowns. Log attendance on MISH-F-10.1 and complete MISH-F-27.1 if applicable.

Attendance Roster (Log on MISH-F-10.1):

Print Name	Signature	Company/Trade