



CONTROLLED ENTERPRISE DOCUMENT

TBT-26.05 | Switchgear Installation And Phasing

MH Construction, INC Enterprise Management System

Document family: TOOLBOX TALK LIBRARY

Document title: TBT-26.05 | Switchgear Installation And Phasing

Version: 1.0 | Lifecycle: Rough Draft

Use only after required functional, technical, field-usability, and approval gates are complete.

Control: Version 1.0 | Status Rough Draft | Author and Chief Editor: Matt Ramsey | Co-Editor: Todd Shoeff | Final Approver: Jeremy Thamert

TBT-26.05: Switchgear Installation & Phasing

CSI Division: Div 26 | Track Assignment: Track 3 MEP & Interior

DIRECTIVE

Switchgear installation requires extreme precision. All gear must be verified de-energized and locked out before the bus bars are connected.

GENERAL ORDER

Use a calibrated meter to verify zero energy. Follow the manufacturer's torque specs for all lug connections.

Key Hazards & Mitigation (The 'What If')

- Meter shows voltage on a 'dead' line — stop work, trace the feed, apply LOTO.
- Worker drops a wrench into the gear — retrieve it immediately, account for all tools before closing the panel.
- Improper torque causes a hot spot — use a calibrated torque wrench for every connection.

FIELD INSTRUCTION

Foreman: Verify the zero-energy state personally with a meter before allowing the crew to touch the bus bars.

Attendance Roster (MISH-F-10.1)

Print Name	Signature	Date

Toolbox Talk Documentation & Sign-Off

This Toolbox Talk (TBT) is a mandatory component of the MH Construction, INC Industrial Safety & Health (MISH) Program. All site personnel, including subcontractors and temporary laborers, must attend this briefing before commencing related work activities.

The Site Safety Commander or designated Foreman is responsible for delivering this content, ensuring comprehension, and documenting attendance. Failure to adhere to the safety protocols outlined herein may result in disciplinary action up to and including removal from the jobsite.

By signing the daily attendance log (Form MISH-F-10.1), you acknowledge that you have received, understood, and agree to comply with the safety directives presented in this Toolbox Talk.