



CONTROLLED ENTERPRISE DOCUMENT

TBT-28.01 | Fire Alarm And Security System Rough In

MH Construction, INC Enterprise Management System

Document family: TOOLBOX TALK LIBRARY

Document title: TBT-28.01 | Fire Alarm And Security System Rough In

Version: 1.0 | Lifecycle: Rough Draft

Use only after required functional, technical, field-usability, and approval gates are complete.

Control: Version 1.0 | Status Rough Draft | Author and Chief Editor: Matt Ramsey | Co-Editor: Todd Shoeff | Final Approver: Jeremy Thamert

TBT-28.01: Fire Alarm & Security System Rough-In

CSI Division: Div 28 | Track Assignment: Track 3 MEP & Interior

DIRECTIVE

Fire alarm wiring must be clearly identified and separated from high-voltage lines. Ensure proper tie-off when working at heights.

GENERAL ORDER

Coordinate with other trades to avoid cutting or damaging installed alarm loops. Test systems only when the area is clear.

Key Hazards & Mitigation (The 'What If')

- Alarm sounds unexpectedly during test — notify all crews prior to testing.
- Working near live electrical panels — maintain minimum clearance, use insulated tools.
- Drilling through fire-rated wall — ensure fire caulk is applied immediately after.

FIELD INSTRUCTION

Foreman: Notify the Chief Superintendent and all site crews before conducting any audible alarm testing.

Attendance Roster (MISH-F-10.1)

Print Name	Signature	Date

Toolbox Talk Documentation & Sign-Off

This Toolbox Talk (TBT) is a mandatory component of the MH Construction, INC Industrial Safety & Health (MISH) Program. All site personnel, including subcontractors and temporary laborers, must attend this briefing before commencing related work activities.

The Site Safety Commander or designated Foreman is responsible for delivering this content, ensuring comprehension, and documenting attendance. Failure to adhere to the safety protocols outlined herein may result in disciplinary action up to and including removal from the jobsite.

By signing the daily attendance log (Form MISH-F-10.1), you acknowledge that you have received, understood, and agree to comply with the safety directives presented in this Toolbox Talk.