

## Quality Control Checklist

Date: 2021-04-08 - Block F - F101

### ELECTRICAL

Category	Description	Subcontractor	Site Foreman	Construction Manager	Comments
1: Power on distribution board	DB correctly installed (position per drawing) true and square? Cover installed properly? All screws fitted?	✓	✓	✓	
1: Power on distribution board	All circuit breakers installed properly? No copper from conductors visible behind circuit breaker?	✓	✓	✓	
1: Power on distribution board	Earth leakage installed? Tested?	✓	✓	✓	
1: Power on distribution board	Whole distribution board labelled correctly with a complete legend? Is the legend visible?	✓	✓	✓	
1: Power on distribution board	Pre-paid meter and relay position blanked off? Draw wire installed?	✓	✓	✓	
2: Meter Box / Telephone DB	Correctly positioned and installed? Tested wrt app?	✓	✓	✓	
2: Meter Box / Telephone DB	True and square fitment of outlet / cover?	✓	✓	✓	
2: Meter Box / Telephone DB	Fitted with lid and cover? No cracks no paint left on it?	✓	✓	✓	
2: Meter Box / Telephone DB	All draw wires installed?	✓	✓	✓	
2: Meter Box / Telephone DB	All telco / data / TV outlets blanks fitted?	✓	✓	✓	
3: Fittings	All light fittings correctly installed? True and square? Did the siteforeman accept this?	✓	✓	✓	
3: Fittings	All light switches correctly? True and square	✓	✓	✓	
3: Fittings	All light bulbs installed? Tested? Do they all work? No shimmer?	✓	✓	✓	
3: Fittings	All plug points fitted where required? True and square?	✓	✓	✓	
3: Fittings	All telco / data and TV blanks covers fitted where required?	✓	✓	✓	
3: Fittings	All lights in working order?	✓	✓	✓	
3: Fittings	All plug points in working order?	✓	✓	✓	

Signature Subcontractor

Handwritten signature consisting of the letters 'S' and 'C' joined together.

Signature Site Foreman

Handwritten signature consisting of the letters 'S' and 'F' joined together.

Signature Construction  
Manager

Handwritten signature consisting of the letters 'C' and 'M' joined together.