

Energy Savings — Financial Report

LB Energy Predictive Pre-Heat Controller

Summary

Energy without model	Energy with model	Energy saved	Cost avoided
788 kWh	230 kWh	558 kWh (71%)	€ 167

Per-event breakdown

Event start	Without model (kWh)	With model (kWh)	Saved (kWh)
2026-03-30 04:30	53.3	32.9	20.4
2026-03-31 04:30	83.4	32.9	50.5
2026-04-01 04:30	95.1	32.9	62.2
2026-04-02 04:30	157.1	32.9	124.2
2026-04-03 04:30	154.8	32.9	121.9
2026-04-04 04:30	127.1	32.9	94.2
2026-04-05 04:30	117.1	32.9	84.2

Method

Baseline (B1) follows the building's current fixed pre-heat schedule. Model (B3) uses the calibrated RC controller to start pre-heat at the optimal lead time. Energy figures are electrical kWh measured at the heat pump over the pre-heat window for each heating event in the source dataset. Cost avoided assumes an electricity tariff of €0.30/kWh.