WABAG	100 MLD DESALINATION PLANT , NEMMELI	
10M35/EPCR/E/006	POWER CONSUMPTION FOR THE MONTH OF JANUARY 2018	

DATE	MRSS TRIVECTOR METER READING			L&T READING			DWRO	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	FINAL READING (KWH)	INITIAL READING (KWH)	NET READING (KWH)	PLANT POWER CONSUMPTION (KWH)		
1-Jan-18	510963	510659	304000	4127241	4114662	12579	291421	78430	3.72
2-Jan-18	511273	510963	310000	4139655	4127241	12414	297586	79134	3.76
3-Jan-18	511531	511273	258000	4151353	4139655	11698	246302	64360	3.83
4-Jan-18	511841	511531	310000	4164139	4151353	12786	297214	78288	3.80
5-Jan-18	512154	511841	313000	4177067	4164139	12928	300072	78886	3.80
6-Jan-18	512521	512154	367000	4194889	4177067	17822	349178	92181	3.79
7-Jan-18	512873	512521	352000	4212010	4194889	17121	334879	88254	3.79
8-Jan-18	513243	512873	370000	4230216	4212010	18206	351794	92861	3.79
9-Jan-18	513604	513243	361000	4247630	4230216	17414	343586	90426	3.80
10-Jan-18	513982	513604	378000	4266351	4247630	18721	359279	95803	3.75
11-Jan-18	514300	513982	318000	4279000	4266351	12649	305351	80489	3.79
12-Jan-18	514605	514300	305000	4292920	4279000	13920	291080	78879	3.69
13-Jan-18	514918	514605	313000	4305742	4292920	12822	300178	79358	3.78
14-Jan-18	515223	514918	305000	4318769	4305742	13027	291973	79520	3.67
15-Jan-18	515531	515223	308000	4332077	4318769	13308	294692	79365	3.71
16-Jan-18	515840	515531	309000	4345282	4332077	13205	295795	79280	3.73
17-Jan-18	516152	515840	312000	4358308	4345282	13026	298974	79226	3.77
18-Jan-18	516463	516152	311000	4371015	4358308	12707	298293	79409	3.76
19-Jan-18	516768	516463	305000	4383982	4371015	12967	292033	77428	3.77
20-Jan-18	517078	516768	310000	4396638	4383982	12656	297344	78726	3.78
21-Jan-18	517390	517078	312000	4409688	4396638	13050	298950	79242	3.77
22-Jan-18	517702	517390	312000	4422662	4409688	12974	299026	79118	3.78
23-Jan-18	518015	517702	313000	4435567	4422662	12905	300095	79362	3.78
24-Jan-18	518328	518015	313000	4448582	4435567	13015	299985	79385	3.78
25-Jan-18	518643	518328	315000	4461796	4448582	13214	301786	79188	3.81
26-Jan-18	518953	518643	310000	4474424	4461796	12628	297372	78462	3.79
27-Jan-18	519268	518953	315000	4487221	4474424	12797	302203	78659	3.84
28-Jan-18	519569	519268	301000	4499522	4487221	12301	288699	73145	3.95
29-Jan-18	519896	519569	327000	4512806	4499522	13284	313716	79415	3.95
30-Jan-18	520201	519896	305000	4525441	4512806	12635	292365	75530	3.87
31-Jan-18	520519	520201	318000	4537852	4525441	12411	305589	77849	3.93
TOTAL			9860000			423190	9436810	2489658	3.79

MRSS MONTHLY POWER CONSUMPTION	9860000	KWH
L&T MONTHLY POWER CONSUMPTION	423190	KWH
PLANT MONTHLY POWER CONSUMPTION	9436810	KWH
POWER CONSUMPTION DURING SHUTDOWN	0	KWH
NET PLANT MONTHLY POWER CONSUMPTION	9436810	KWH
RO WATER MOTHLY PRODUCTION	2489658	M3
PLANT SPECIFIC POWER KWH/M3	3.79	KWHr/M3

VATECH WABAG LTD

CMWSSB

WABAG	100 MLD DESALINATION PLANT , NEMMELI	
10M35/EPCR/E/006	POWER CONSUMPTION FOR THE MONTH OF FEBRUARY 2018	

DATE	MRSS TRIVECTOR METER READING			L&T READING			DWRO	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	FINAL READING (KWH)	INITIAL READING (KWH)	NET READING (KWH)	PLANT POWER CONSUMPTION (KWH)		
1-Feb-18	520845	520519	326000	4550651	4537852	12799	313201	79228	3.95
2-Feb-18	521167	520845	322000	4563903	4550651	13252	308748	79454	3.89
3-Feb-18	521488	521167	321000	4576979	4563903	13076	307924	79536	3.87
4-Feb-18	521809	521488	321000	4590393	4576979	13414	307586	79432	3.87
5-Feb-18	522126	521809	317000	4603054	4590393	12661	304339	77560	3.92
6-Feb-18	522444	522126	318000	4615598	4603054	12544	305456	77756	3.93
7-Feb-18	522761	522444	317000	4628338	4615598	12740	304260	77534	3.92
8-Feb-18	523080	522761	319000	4641001	4628338	12663	306337	77720	3.94
9-Feb-18	523406	523080	326000	4654102	4641001	13101	312899	77522	4.04
10-Feb-18	523731	523406	325000	4666868	4654102	12766	312234	77649	4.02
11-Feb-18	524054	523731	323000	4679722	4666868	12854	310146	77598	4.00
12-Feb-18	524353	524054	299000	4691979	4679722	12257	286743	71057	4.04
13-Feb-18	524679	524353	326000	4705032	4691979	13053	312947	78910	3.97
14-Feb-18	524999	524679	320000	4717728	4705032	12696	307304	77589	3.96
15-Feb-18	525323	524999	324000	4730465	4717728	12737	311263	77742	4.00
16-Feb-18	525644	525323	321000	4743054	4730465	12589	308411	77071	4.00
17-Feb-18	525962	525644	318000	4756111	4743054	13057	304943	77377	3.94
18-Feb-18	526288	525962	326000	4768966	4756111	12855	313145	77463	4.04
19-Feb-18	526604	526288	316000	4782064	4768966	13098	302902	77758	3.90
20-Feb-18	526920	526604	316000	4795051	4782064	12987	303013	77738	3.90
21-Feb-18	527236	526920	316000	4807624	4795051	12573	303427	77781	3.90
22-Feb-18	527549	527236	313000	4820153	4807624	12529	300471	77738	3.87
23-Feb-18	527868	527549	319000	4832930	4820153	12777	306223	77130	3.97
24-Feb-18	528136	527868	268000	4846042	4832930	13112	254888	63460	4.02
25-Feb-18	528455	528136	319000	4858862	4846042	12820	306180	77716	3.94
26-Feb-18	528776	528455	321000	4872467	4858862	13605	307395	77535	3.96
27-Feb-18	529102	528776	326000	4885074	4872467	12607	313393	77361	4.05
28-Feb-18	529435	529102	333000	4898316	4885074	13242	319758	77449	4.13
TOTAL			8916000			360464	8555536	2159864	3.96

MRSS MONTHLY POWER CONSUMPTION	8916000	KWH
L&T MONTHLY POWER CONSUMPTION	360464	KWH
PLANT MONTHLY POWER CONSUMPTION	8555536	KWH
POWER CONSUMPTION DURING SHUTDOWN	0	KWH
NET PLANT MONTHLY POWER CONSUMPTION	8555536	KWH
RO WATER MOTHLY PRODUCTION	2159864	M3
PLANT SPECIFIC POWER KWH/M3	3.96	KWHr/M3

VATECH WABAG LTD

CMWSSB

WABAG

10M35/EPCR/E/006

100 MLD DESALINATION PLANT , NEMMELI

POWER CONSUMPTION FOR THE MONTH OF MARCH 2018

DATE	MRSS TRIVECTOR METER READING			L&T READING			ENHANCEMENT ADDITIONAL LOAD POWER CONSUMPTION (KWH)	NET PLANT POWER CONSUMPTION (KWH)	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	MRSS POWER CONSUMPTION (KWH)	FINAL READING (KWH)	INITIAL READING (KWH)	L&T POWER CONSUMPTION (KWH)				
1-Mar-18	529771	529435	336000	4911294	4898316	12978	9723	313299	77438	4.05
2-Mar-18	530105	529771	334000	4924406	4911294	13112	9723	311165	77732	4.00
3-Mar-18	530424	530105	319000	4937296	4924406	12890	9723	296387	77721	3.81
4-Mar-18	530750	530424	326000	4950094	4937296	12798	9723	303479	77517	3.91
5-Mar-18	531069	530750	319000	4963053	4950094	12959	9723	296318	78478	3.78
6-Mar-18	531280	531069	211000	4972046	4963053	8993	9723	192284	50920	3.78
7-Mar-18	531596	531280	316000	4985446	4972046	13400	9723	292877	78924	3.71
8-Mar-18	531917	531596	321000	4998620	4985446	13174	9723	298103	78351	3.80
9-Mar-18	532196	531917	279000	5009847	4998620	11227	9723	258050	66383	3.89
10-Mar-18	532512	532196	316000	5023467	5009847	13620	9723	292657	79055	3.70
11-Mar-18	532828	532512	316000	5036851	5023467	13384	9723	292893	79046	3.71
12-Mar-18	533154	532828	326000	5049900	5036851	13049	9723	303228	78521	3.86
13-Mar-18	533475	533154	321000	5063526	5049900	13626	9723	297651	79102	3.76
14-Mar-18	533799	533475	324000	5077979	5063526	14453	9723	299824	79620	3.77
15-Mar-18	534121	533799	322000	5091542	5077979	13563	9723	298714	79539	3.76
16-Mar-18	534444	534121	323000	5104805	5091542	13263	9723	300014	79881	3.76
17-Mar-18	534767	534444	323000	5118096	5104805	13291	9723	299986	79763	3.76
18-Mar-18	535090	534767	323000	5131149	5118096	13053	9723	300224	79525	3.78
19-Mar-18	535486	535090	396000	5150543	5131149	19394	9723	366883	97684	3.76
20-Mar-18	535803	535486	317000	5164370	5150543	13827	9723	293450	77090	3.81
21-Mar-18	536196	535803	393000	5183504	5164370	19134	9723	364143	97612	3.73
22-Mar-18	536598	536196	402000	5202754	5183504	19250	9723	373027	100292	3.72
23-Mar-18	537002	536598	404000	5222097	5202754	19343	9723	374934	100317	3.74
24-Mar-18	537401	537002	399000	5241481	5222097	19384	9723	369893	98472	3.76
25-Mar-18	537799	537401	398000	5260798	5241481	19317	9723	368960	96555	3.82
26-Mar-18	538195	537799	396000	5279900	5260798	19102	9723	367175	96292	3.81
27-Mar-18	538603	538195	408000	5299156	5279900	19256	9723	379021	100250	3.78
28-Mar-18	539013	538603	410000	5318340	5299156	19184	9723	381093	100150	3.81
29-Mar-18	539425	539013	412000	5337606	5318340	19266	9723	383011	100080	3.83
30-Mar-18	539828	539425	403000	5356569	5337606	18963	9723	374314	97862	3.82
31-Mar-18	540241	539828	413000	5375796	5356569	19227	9723	384050	100377	3.83
TOTAL			10806000			477480	301413	10027107	2640549	3.80

MRSS MONTHLY POWER CONSUMPTION	10806000
L&T MONTHLY POWER CONSUMPTION	477480
PLANT MONTHLY POWER CONSUMPTION	10027107
POWER CONSUMPTION DURING SHUTDOWN	0
NET PLANT MONTHLY POWER CONSUMPTION	10027107
RO WATER MOTHLY PRODUCTION	2640549
PLANT SPECIFIC POWER KWH/M3	3.80

VATECH-WABAG LTD

GMWSSB

WABAG	100 MLD DESALINATION PLANT , NEMMELI	
10M35/EPCR/E/006	POWER CONSUMPTION FOR THE MONTH OF APRIL 2018	

DATE	MRSS TRIVECTOR METER READING			L&T READING			ENHANCEMENT ADDITIONAL LOAD	NET PLANT POWER CONSUMPTION (KWH)	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	MRSS POWER CONSUMPTION (KWH)	FINAL READING (KWH)	INITIAL READING (KWH)	L&T POWER CONSUMPTION (KWH)	POWER CONSUMPTION (KWH)			
1-Apr-18	540654	540241	413000	5395275	5375796	19479	9723	383798	100185	3.83
2-Apr-18	541067	540654	413000	5414679	5395275	19404	9723	383873	100195	3.83
3-Apr-18	541379	541067	312000	5427750	5414679	13071	9723	289206	73787	3.92
4-Apr-18	541781	541379	402000	5445721	5427750	17971	9723	374306	97798	3.83
5-Apr-18	542170	541781	389000	5463308	5445721	17587	9723	361690	91889	3.94
6-Apr-18	542563	542170	393000	5481439	5463308	18131	9723	365146	95430	3.83
7-Apr-18	542958	542563	395000	5500422	5481439	18983	9723	366294	95186	3.85
8-Apr-18	543369	542958	411000	5519149	5500422	18727	9723	382550	100210	3.82
9-Apr-18	543781	543369	412000	5538417	5519149	19268	9723	383009	100319	3.82
10-Apr-18	544193	543781	412000	5557807	5538417	19390	9723	382887	100321	3.82
11-Apr-18	544539	544193	346000	5573765	5557807	15958	9723	320319	82946	3.86
12-Apr-18	544952	544539	413000	5592737	5573765	18972	9723	384305	100452	3.83
13-Apr-18	545365	544952	413000	5611911	5592737	19174	9723	384103	100373	3.83
14-Apr-18	545777	545365	412000	5631170	5611911	19259	9723	383018	100275	3.82
15-Apr-18	546189	545777	412000	5650556	5631170	19386	9723	382891	100114	3.82
16-Apr-18	546601	546189	412000	5669913	5650556	19357	9723	382920	100339	3.82
17-Apr-18	547013	546601	412000	5688875	5669913	18962	9723	383315	100322	3.82
18-Apr-18	547040	547013	27000	5689901	5688875	1026		25974		
19-Apr-18	547381	547040	341000	5705988	5689901	16087	9723	315190	82070	3.84
20-Apr-18	547792	547381	411000	5725495	5705988	19507	9723	381770	100514	3.80
21-Apr-18	548202	547792	410000	5744675	5725495	19180	9723	381097	100291	3.80
22-Apr-18	548595	548202	393000	5762301	5744675	17626	9723	365651	95566	3.83
23-Apr-18	549005	548595	410000	5781628	5762301	19327	9723	380950	100316	3.80
24-Apr-18	549417	549005	412000	5801093	5781628	19465	9723	382812	100715	3.80
25-Apr-18	549828	549417	411000	5820188	5801093	19095	9723	382182	100630	3.80
26-Apr-18	550239	549828	411000	5839296	5820188	19108	9723	382169	100660	3.80
27-Apr-18	550650	550239	411000	5858447	5839296	19151	9723	382126	100582	3.80
28-Apr-18	551060	550650	410000	5877852	5858447	19405	9723	380872	100516	3.79
29-Apr-18	551470	551060	410000	5896980	5877852	19128	9723	381149	100381	3.80
30-Apr-18	551880	551470	410000	5916097	5896980	19117	9723	381160	100346	3.80
TOTAL			11639000			540301	281967	10816732	2822728	3.82

MRSS MONTHLY POWER CONSUMPTION	11639000
L&T MONTHLY POWER CONSUMPTION	540301
ENHANCEMENT ADDITIONAL LOAD POWER CONSUMPTION	281967
PLANT MONTHLY POWER CONSUMPTION	10816732
POWER CONSUMPTION DURING SHUTDOWN	25974
NET PLANT MONTHLY POWER CONSUMPTION	10790758
RO WATER MOTHLY PRODUCTION	2822728
PLANT SPECIFIC POWER KWH/M3	3.82

VATECH WABAG LTD

CMWSSB

WABAG

100 MLD DESALINATION PLANT , NEMMELI

10M35/EPCR/E/006

POWER CONSUMPTION FOR THE MONTH OF MAY 2018

DATE	MRSS TRIVECTOR METER READING			L&T READING			ENHANCEMENT ADDITIONAL LOAD POWER CONSUMPTION (KWH)	NET PLANT POWER CONSUMPTION (KWH)	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	MRSS POWER CONSUMPTION (KWH)	FINAL READING (KWH)	INITIAL READING (KWH)	L&T POWER CONSUMPTION (KWH)				
1-May-18	552291	551880	411000	5935258	5916097	19161	9723	382116	100458	3.80
2-May-18	552701	552291	410000	5954790	5935258	19532	9723	380745	100420	3.79
3-May-18	553075	552701	374000	5972237	5954790	17447	9723	346830	90664	3.83
4-May-18	553374	553075	299000	5985020	5972237	12783	9723	276494	70470	3.92
5-May-18	553785	553374	411000	6004014	5985020	18994	9723	382283	100580	3.80
6-May-18	554196	553785	411000	6023342	6004014	19328	9723	381949	100538	3.80
7-May-18	554608	554196	412000	6042579	6023342	19237	9723	383040	100795	3.80
8-May-18	555018	554608	410000	6061670	6042579	19091	9723	381186	100420	3.80
9-May-18	555427	555018	409000	6080763	6061670	19093	9723	380184	100540	3.78
10-May-18	555836	555427	409000	6099599	6080763	18836	9723	380441	100506	3.79
11-May-18	556245	555836	409000	6118566	6099599	18967	9723	380310	100477	3.79
12-May-18	556655	556245	410000	6137780	6118566	19214	9723	381063	100601	3.79
13-May-18	557006	556655	351000	6154469	6137780	16689	9723	324588	84156	3.86
14-May-18	557409	557006	403000	6172590	6154469	18121	9723	375156	98353	3.81
15-May-18	557818	557409	409000	6191940	6172590	19350	9723	379927	100213	3.79
16-May-18	558228	557818	410000	6211281	6191940	19341	9723	380936	100670	3.78
17-May-18	558636	558228	408000	6230230	6211281	18949	9723	379328	100510	3.77
18-May-18	559045	558636	409000	6249135	6230230	18905	9723	380372	100431	3.79
19-May-18	559451	559045	406000	6268109	6249135	18974	9723	377303	100611	3.75
20-May-18	559861	559451	410000	6287292	6268109	19183	9723	381094	100669	3.79
21-May-18	560273	559861	412000	6306582	6287292	19290	9723	382987	100799	3.80
22-May-18	560586	560273	313000	6321420	6306582	14838	9723	288439	76320	3.78
23-May-18	560997	560586	411000	6340435	6321420	19015	9723	382262	100666	3.80
24-May-18	561408	560997	411000	6359467	6340435	19032	9723	382245	100858	3.79
25-May-18	561819	561408	411000	6378912	6359467	19445	9723	381832	100473	3.80
26-May-18	562226	561819	407000	6397886	6378912	18974	9723	378303	100301	3.77
27-May-18	562633	562226	407000	6416817	6397886	18931	9723	378346	100468	3.77
28-May-18	563044	562633	411000	6435920	6416817	19103	9723	382174	100776	3.79
29-May-18	563433	563044	389000	6453500	6435920	17580	9723	361697	95107	3.80
30-May-18	563839	563433	406000	6472436	6453500	18936	9723	377341	100512	3.75
31-May-18	564247	563839	408000	6491486	6472436	19050	9723	379227	100342	3.78
TOTAL			12367000			575389	301413	11490198	3028704	3.79

MRSS MONTHLY POWER CONSUMPTION	12367000
L&T MONTHLY POWER CONSUMPTION	575389
ENHANCEMENT ADDITIONAL LOAD POWER CONSUMPTION	301413
PLANT MONTHLY POWER CONSUMPTION	11490198
POWER CONSUMPTION DURING SHUTDOWN	0
NET PLANT MONTHLY POWER CONSUMPTION	11490198
RO WATER MOTHLY PRODUCTION	3028704
PLANT SPECIFIC POWER KWH/M3	3.79

VATECH WABAG LTD

CMWSSB

WABAG

10M35/EPCR/E/006

100 MLD DESALINATION PLANT , NEMMELI

POWER CONSUMPTION FOR THE MONTH OF JUNE 2018

DATE	MRSS TRIVECTOR METER READING			L&T READING			ENHANCEMENT ADDITIONAL LOAD POWER CONSUMPTION (KWH)	NET PLANT POWER CONSUMPTION (KWH)	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	MRSS POWER CONSUMPTION (KWH)	FINAL READING (KWH)	INITIAL READING (KWH)	L&T POWER CONSUMPTION (KWH)				
1-Jun-18	564659	564247	412000	6510694	6491486	19208	9723	383069	100517	3.81
2-Jun-18	565072	564659	413000	6529720	6510694	19026	9723	384251	100563	3.82
3-Jun-18	565486	565072	414000	6548759	6529720	19039	9723	385238	100494	3.83
4-Jun-18	565876	565486	390000	6566558	6548759	17799	9723	362478	95217	3.81
5-Jun-18	566280	565876	404000	6585780	6566558	19222	9723	375055	98488	3.81
6-Jun-18	566555	566280	275000	6598827	6585780	13047	9723	252230	64754	3.90
7-Jun-18	566969	566555	414000	6617774	6598827	18947	9723	385330	100746	3.82
8-Jun-18	567383	566969	414000	6636829	6617774	19055	9723	385222	100689	3.83
9-Jun-18	567796	567383	413000	6655985	6636829	19156	9723	384121	100198	3.83
10-Jun-18	568209	567796	413000	6675350	6655985	19365	9723	383912	100436	3.82
11-Jun-18	568577	568209	368000	6692036	6675350	16686	9723	341591	87630	3.90
12-Jun-18	568991	568577	414000	6711055	6692036	19019	9723	385258	100616	3.83
13-Jun-18	569405	568991	414000	6729572	6711055	18517	9723	385760	100712	3.83
14-Jun-18	569819	569405	414000	6748508	6729572	18936	9723	385341	100750	3.82
15-Jun-18	570158	569819	339000	6764122	6751491	12631	9723	316646	80116	3.95
16-Jun-18	570572	570158	414000	6783153	6764122	19031	9723	385246	100520	3.83
17-Jun-18	570986	570572	414000	6802005	6783153	18852	9723	385425	100625	3.83
18-Jun-18	571400	570986	414000	6820995	6802005	18990	9723	385287	100556	3.83
19-Jun-18	571813	571400	413000	6840060	6820995	19065	9723	384212	100417	3.83
20-Jun-18	572173	571813	360000	6854952	6840060	14892	9723	335385	83655	4.01
21-Jun-18	572540	572173	367000	956085	6854952	14800	9723	342477	85056	4.03
22-Jun-18	572755	572540	215000	1845389	956085	8890	9723	196387	48816	4.02
23-Jun-18	573168	572755	413000	3757978	1845389	19125	9723	384152	100180	3.83
24-Jun-18	573582	573168	414000	5659378	3757978	19014	9723	385263	100557	3.83
25-Jun-18	573995	573582	413000	75732	56593	19139	9723	384138	100426	3.83
26-Jun-18	574400	573995	405000	95042	75732	19310	9723	375967	98181	3.83
27-Jun-18	574806	574400	406000	114171	95042	19129	9723	377148	98346	3.83
28-Jun-18	575218	574806	412000	133189	114171	19018	9723	383259	100051	3.83
29-Jun-18	575612	575218	394000	150257	133189	17068	9723	367209	92522	3.97
30-Jun-18	576006	575612	394000	167536	150257	17279	9723	366998	91996	3.99
TOTAL			11759000			533255	291690	10934055	2833830	3.86

MRSS MONTHLY POWER CONSUMPTION	11759000
L&T MONTHLY POWER CONSUMPTION	533255
ENHANCEMENT ADDITIONAL LOAD POWER CONSUMPTION	291690
PLANT MONTHLY POWER CONSUMPTION	10934055
POWER CONSUMPTION DURING SHUTDOWN / PLANT MAINTENANCE	196387
NET PLANT MONTHLY POWER CONSUMPTION	*10737668*
RO WATER MOTHLY PRODUCTION	2833830
PLANT SPECIFIC POWER KWH/M3	3.79

VATECH WABAG LTD

CMWSSB

WABAG

10M35/EPCR/E/006

100 MLD DESALINATION PLANT , NEMMELI

POWER CONSUMPTION FOR THE MONTH OF JULY 2018

DATE	MRSS TRIVECTOR METER READING			L&T READING			ENHANCEMENT ADDITIONAL LOAD POWER CONSUMPTION (KWH)	NET PLANT POWER CONSUMPTION (KWH)	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	MRSS POWER CONSUMPTION (KWH)	FINAL READING (KWH)	INITIAL READING (KWH)	L&T POWER CONSUMPTION (KWH)				
1-Jul-18	576387	576006	381000	184355	167536	16819	9723	354458	92260	3.84
2-Jul-18	576783	576387	396000	203259	184355	18904	9723	367373	95993	3.83
3-Jul-18	577182	576783	399000	222618	203259	19359	9723	369918	96543	3.83
4-Jul-18	577569	577182	387000	240299	222618	17681	9723	359596	93552	3.84
5-Jul-18	577946	577569	377000	257736	240299	17437	9723	349840	90830	3.85
6-Jul-18	578326	577946	380000	274777	257736	17041	9723	353236	92021	3.84
7-Jul-18	578659	578326	333000	287428	274777	12651	9723	310626	75293	4.13
8-Jul-18	578988	578659	329000	299613	287428	12185	9723	307092	74488	4.12
9-Jul-18	579321	578988	333000	311640	299613	12027	9723	311250	75596	4.12
10-Jul-18	579660	579321	339000	324071	311640	12431	9723	316846	77162	4.11
11-Jul-18	580056	579660	396000	342817	324071	18746	9723	367531	95890	3.83
12-Jul-18	580470	580056	414000	361861	342817	19044	9723	385233	100963	3.82
13-Jul-18	580884	580470	414000	380768	361861	18907	9723	385370	100619	3.83
14-Jul-18	581298	580884	414000	399965	380768	19197	9723	385080	100503	3.83
15-Jul-18	581712	581298	414000	419193	399965	19228	9723	385049	100468	3.83
16-Jul-18	582125	581712	413000	438204	419193	19011	9723	384266	100432	3.83
17-Jul-18	582538	582125	413000	457120	438204	18916	9723	384361	100510	3.82
18-Jul-18	582936	582538	398000	475638	457120	18518	9723	369759	96437	3.83
19-Jul-18	583349	582936	413000	494521	475638	18883	9723	384394	100670	3.82
20-Jul-18	583707	583349	358000	511582	494521	17061	1500	339439	88161	3.85
21-Jul-18	584073	583707	366000	528605	511582	17023	1500	347477	90592	3.84
22-Jul-18	584439	584073	366000	545839	528605	17234	1500	347266	90520	3.84
23-Jul-18	584805	584439	366000	562395	545839	16556	1500	347944	90609	3.84
24-Jul-18	585170	584805	365000	579250	562395	16855	1500	346645	90272	3.84
25-Jul-18	585536	585170	366000	596711	579250	17461	1500	347039	90472	3.84
26-Jul-18	585901	585536	365000	613784	596711	17073	1500	346427	90250	3.84
27-Jul-18	586267	585901	366000	630806	613784	17022	1500	347478	90493	3.84
28-Jul-18	586634	586267	367000	647704	630806	16898	1500	348602	90758	3.84
29-Jul-18	586999	586634	365000	664432	647704	16728	1500	346772	90414	3.84
30-Jul-18	587365	586999	366000	680960	664432	16528	1500	347972	90511	3.84
31-Jul-18	587730	587365	365000	697663	680960	16703	1500	346797	90314	3.84
TOTAL			11724000			530127	202737	10991136	2843596	3.87

MRSS MONTHLY POWER CONSUMPTION	11724000
L&T MONTHLY POWER CONSUMPTION	530127
ENHANCEMENT ADDITIONAL LOAD POWER CONSUMPTION	202737
PLANT MONTHLY POWER CONSUMPTION	10991136
POWER CONSUMPTION DURING SHUTDOWN / PLANT MAINTENANCE	0
NET PLANT MONTHLY POWER CONSUMPTION	*10991136*
RO WATER MOTHLY PRODUCTION	2843596
PLANT SPECIFIC POWER KWH/M3	3.87

VATECH WABAG LTD

CMWSSB

WABAG

100 MLD DESALINATION PLANT , NEMMELI

10M35/EPCR/E/006

POWER CONSUMPTION FOR THE MONTH OF AUGUST 2018

DATE	MRSS TRIVECTOR METER READING			L&T READING			ENHANCEMENT ADDITIONAL LOAD	NET PLANT POWER CONSUMPTION (KWH)	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	MRSS POWER CONSUMPTION (KWH)	FINAL READING (KWH)	INITIAL READING (KWH)	L&T POWER CONSUMPTION (KWH)	POWER CONSUMPTION (KWH)			
1-Aug-18	588109	587730	379000	714213	697663	16550	9723	352727	90593	3.89
2-Aug-18	588488	588109	379000	730137	714213	15924	9723	353353	90026	3.93
3-Aug-18	588542	588488	54000	731649	730137	1512	0	52488	6208	8.45
4-Aug-18	588944	588542	402000	750069	731649	18420	9723	373857	100302	3.73
5-Aug-18	589358	588944	414000	769173	750069	19104	9723	385173	100498	3.83
6-Aug-18	589772	589358	414000	788342	769173	19169	9723	385108	100619	3.83
7-Aug-18	590186	589772	414000	807569	788342	19227	9723	385050	100484	3.83
8-Aug-18	590600	590186	414000	826604	807569	19035	9723	385242	100682	3.83
9-Aug-18	590973	590600	373000	843629	826604	17025	9723	346252	90505	3.83
10-Aug-18	591386	590973	413000	862524	843629	18895	9723	384382	100536	3.82
11-Aug-18	591797	591386	411000	880982	862524	18458	9723	382819	100120	3.82
12-Aug-18	592210	591797	413000	900020	880982	19038	9723	384239	100634	3.82
13-Aug-18	592602	592210	392000	917470	900020	17450	9723	364827	95212	3.83
14-Aug-18	592960	592602	358000	933231	917470	15761	9723	332516	86966	3.82
15-Aug-18	593375	592960	415000	952293	933231	19062	9723	386215	100748	3.83
16-Aug-18	593789	593375	414000	971389	952293	19096	9723	385181	100969	3.81
17-Aug-18	594199	593789	410000	990386	971389	18997	9723	381280	100372	3.80
18-Aug-18	594612	594199	413000	1009354	990386	18968	9723	384309	100669	3.82
19-Aug-18	595025	594612	413000	1028432	1009354	19078	9723	384199	100676	3.82
20-Aug-18	595438	595025	413000	1047604	1028432	19172	9723	384105	100620	3.82
21-Aug-18	595852	595438	414000	1066524	1047604	18920	9723	385357	100810	3.82
22-Aug-18	596266	595852	414000	1085560	1066524	19036	9723	385241	100896	3.82
23-Aug-18	596599	596266	333000	1100284	1085560	14724	9723	308553	80281	3.84
24-Aug-18	597012	596599	413000	1119476	1100284	19192	9723	384085	100466	3.82
25-Aug-18	597427	597012	415000	1138679	1119476	19203	9723	386074	100719	3.83
26-Aug-18	597840	597427	413000	1157931	1138679	19252	9723	384025	100396	3.83
27-Aug-18	598253	597840	413000	1177210	1157931	19279	9723	383998	100562	3.82
28-Aug-18	598667	598253	414000	1196328	1177210	19118	9723	385159	100689	3.83
29-Aug-18	599082	598667	415000	1215487	1196328	19159	9723	386118	100882	3.83
30-Aug-18	599496	599082	414000	1234772	1215487	19285	9723	384992	100581	3.83
31-Aug-18	599910	599496	414000	1254128	1234772	19356	9723	384921	100521	3.83
TOTAL			12180000			556465	291690	11331845	2954242	3.82

MRSS MONTHLY POWER CONSUMPTION	12180000
L&T MONTHLY POWER CONSUMPTION	556465
ENHANCEMENT ADDITIONAL LOAD POWER CONSUMPTION	291690
PLANT MONTHLY POWER CONSUMPTION	11331845
POWER CONSUMPTION DURING SHUTDOWN / PLANT MAINTENANCE	52488
NET PLANT MONTHLY POWER CONSUMPTION	*11279357*
RO WATER MOTHLY PRODUCTION	2954242
PLANT SPECIFIC POWER KWH/M3	3.82

VATECH WABAG LTD

CMWSSB

WABAG	100 MLD DESALINATION PLANT , NEMMELI	
10M35/EPCR/E/006	POWER CONSUMPTION FOR THE MONTH OF SEPTEMBER 2018	

DATE	MRSS TRIVECTOR METER READING			L&T READING			ENHANCEMENT ADDITIONAL LOAD	NET PLANT POWER CONSUMPTION (KWH)	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	MRSS POWER CONSUMPTION (KWH)	FINAL READING (KWH)	INITIAL READING (KWH)	L&T POWER CONSUMPTION (KWH)	POWER CONSUMPTION (KWH)			
1-Sep-18	600325	599910	415000	1273470	1254128	19342	9723	385935	100853	3.83
2-Sep-18	600689	600325	364000	1290443	1273470	16973	9723	337304	86817	3.89
3-Sep-18	601102	600689	413000	1309743	1290443	19300	9723	383977	100493	3.82
4-Sep-18	601515	601102	413000	1329037	1309743	19294	9723	383983	100540	3.82
5-Sep-18	601867	601515	352000	1344709	1329037	15672	9723	326605	84088	3.88
6-Sep-18	602282	601867	415000	1363974	1344709	19265	9723	386012	100797	3.83
7-Sep-18	602696	602282	414000	1383283	1363974	19309	9723	384968	100479	3.83
8-Sep-18	603108	602696	412000	1402584	1383283	19301	9723	382976	100329	3.82
9-Sep-18	603522	603108	414000	1421973	1402584	19389	9723	384888	100577	3.83
10-Sep-18	603936	603522	414000	1441232	1421973	19259	9723	385018	100644	3.83
11-Sep-18	604299	603936	363000	1458680	1441232	17448	9723	335829	86957	3.86
12-Sep-18	604714	604299	415000	1478029	1458680	19349	9723	385928	100812	3.83
13-Sep-18	605068	604714	354000	1494556	1478029	16527	9723	327750	86650	3.78
14-Sep-18	605466	605068	398000	1513290	1494556	18734	9723	369543	96596	3.83
15-Sep-18	605880	605466	414000	1532220	1513290	18930	9723	385347	100786	3.82
16-Sep-18	606293	605880	413000	1551624	1532220	19404	9723	383873	100550	3.82
17-Sep-18	606707	606293	414000	1570925	1551624	19301	9723	384976	100902	3.82
18-Sep-18	607121	606707	414000	1590178	1570925	19253	9723	385024	100844	3.82
19-Sep-18	607533	607121	412000	1609439	1590178	19261	9723	383016	100378	3.82
20-Sep-18	607945	607533	412000	1628710	1609439	19271	9723	383006	100284	3.82
21-Sep-18	608359	607945	414000	1647723	1628710	19013	9723	385264	100595	3.83
22-Sep-18	608760	608359	401000	1666389	1647723	18666	9723	372611	97590	3.82
23-Sep-18	609162	608760	402000	1685370	1666389	18981	9723	373296	97835	3.82
24-Sep-18	609575	609162	413000	1704420	1685370	19050	9723	384227	100520	3.82
25-Sep-18	609988	609575	413000	1723300	1704420	18880	9723	384397	100593	3.82
26-Sep-18	610402	609988	414000	1742275	1723300	18975	9723	385302	100782	3.82
27-Sep-18	610817	610402	415000	1761549	1742275	19274	9723	386003	100980	3.82
28-Sep-18	611220	610817	403000	1780677	1761549	19128	9723	374149	97698	3.83
29-Sep-18	611618	611220	398000	1799085	1780677	18408	9723	369869	96551	3.83
30-Sep-18	612015	611618	397000	1817341	1799085	18256	9723	369021	96313	3.83
TOTAL			12105000			563213	291690	11250097	2939833	3.83

MRSS MONTHLY POWER CONSUMPTION	12105000
L&T MONTHLY POWER CONSUMPTION	563213
ENHANCEMENT ADDITIONAL LOAD POWER CONSUMPTION	291690
PLANT MONTHLY POWER CONSUMPTION	11250097
POWER CONSUMPTION DURING SHUTDOWN / PLANT MAINTENANCE	0
NET PLANT MONTHLY POWER CONSUMPTION	*11250097*
RO WATER MOTHLY PRODUCTION	2939833
PLANT SPECIFIC POWER KWH/M3	3.83

VATECH WABAG LTD

CMWSSB

WABAG

100 MLD DESALINATION PLANT , NEMMELI

10M35/EPCR/E/006

POWER CONSUMPTION FOR THE MONTH OF OCTOBER 2018

DATE	MRSS TRIVECTOR METER READING			L&T READING			ENHANCEMENT ADDITIONAL LOAD	NET PLANT POWER CONSUMPTION (KWH)	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	MRSS POWER CONSUMPTION (KWH)	FINAL READING (KWH)	INITIAL READING (KWH)	L&T POWER CONSUMPTION (KWH)	POWER CONSUMPTION (KWH)			
1-Oct-18	612413	612015	398000	1836607	1817341	19266	9723	369011	97723	3.78
2-Oct-18	612812	612413	399000	1855855	1836607	19248	9723	370029	98963	3.74
3-Oct-18	613216	612812	404000	1875241	1855855	19386	9723	374891	100667	3.72
4-Oct-18	613543	613216	327000	1890535	1875241	15294	9723	301983	79063	3.82
5-Oct-18	613937	613543	394000	1909784	1890535	19249	9723	365028	97301	3.75
6-Oct-18	614338	613937	401000	1928930	1909784	19146	9723	372131	100450	3.70
7-Oct-18	614743	614338	405000	1948238	1928930	19308	9723	375969	100683	3.73
8-Oct-18	615147	614743	404000	1967490	1948238	19252	9723	375025	100484	3.73
9-Oct-18	615552	615147	405000	1986790	1967490	19300	9723	375977	100668	3.73
10-Oct-18	615953	615552	401000	2005990	1986790	19200	9723	372077	100899	3.69
11-Oct-18	616351	615953	398000	2025231	2005990	19241	9723	369036	100531	3.67
12-Oct-18	616748	616351	397000	2044541	2025231	19310	9723	367967	100762	3.65
13-Oct-18	617142	616748	394000	2063811	2044541	19270	9723	365007	100390	3.64
14-Oct-18	617541	617142	399000	2082946	2063811	19135	9723	370142	100646	3.68
15-Oct-18	617947	617541	406000	2102250	2082946	19304	9723	376973	100819	3.74
16-Oct-18	618337	617947	390000	2120180	2102250	17930	9723	362347	97012	3.74
17-Oct-18	618730	618337	393000	2139361	2120180	19181	9723	364096	100734	3.61
18-Oct-18	619127	618730	397000	2158644	2139361	19283	9723	367994	100550	3.66
19-Oct-18	619489	619127	362000	2176502	2158644	17858	9723	334419	92435	3.62
20-Oct-18	619873	619489	384000	2195789	2176502	19287	9723	354990	100480	3.53
21-Oct-18	620257	619873	384000	2214819	2195789	19030	9723	355247	100552	3.53
22-Oct-18	620555	620257	298000	2228767	2214819	13948	9723	274329	75594	3.63
23-Oct-18	620943	620555	388000	2247971	2228767	19204	9723	359073	100655	3.57
24-Oct-18	621329	620943	386000	2267269	2247971	19298	9723	356979	100521	3.55
25-Oct-18	621710	621329	381000	2285887	2267269	18618	9723	352659	100625	3.50
26-Oct-18	622010	621710	300000	2300427	2285887	14540	9723	275737	76402	3.61
27-Oct-18	622400	622010	390000	2319150	2300427	18723	9723	361554	100557	3.60
28-Oct-18	622788	622400	388000	2338253	2319150	19103	9723	359174	100763	3.56
29-Oct-18	623175	622788	387000	2356988	2338253	18735	9723	358542	100794	3.56
30-Oct-18	623559	623175	384000	2376313	2356988	19325	9723	354952	100767	3.52
31-Oct-18	623939	623559	380000	2395373	2376313	19060	9723	351217	100735	3.49
TOTAL			11924000			578032	301413	11044555	3029225	3.65

MRSS MONTHLY POWER CONSUMPTION	11924000
L&T MONTHLY POWER CONSUMPTION	578032
ENHANCEMENT ADDITIONAL LOAD POWER CONSUMPTION	301413
PLANT MONTHLY POWER CONSUMPTION	11044555
POWER CONSUMPTION DURING SHUTDOWN / PLANT MAINTENANCE	0
NET PLANT MONTHLY POWER CONSUMPTION	*11044555*
RO WATER MOTHLY PRODUCTION	3029225
PLANT SPECIFIC POWER KWH/M3	3.65

VATECH WABAG LTD

CMWSSB

WABAG	100 MLD DESALINATION PLANT , NEMMELI	
10M35/EPCR/E/006	POWER CONSUMPTION FOR THE MONTH OF NOVEMBER 2018	

DATE	MRSS TRIVECTOR METER READING			L&T READING			ENHANCEMENT ADDITIONAL LOAD	NET PLANT POWER CONSUMPTION (KWH)	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	MRSS POWER CONSUMPTION (KWH)	FINAL READING (KWH)	INITIAL READING (KWH)	L&T POWER CONSUMPTION (KWH)	POWER CONSUMPTION (KWH)			
1-Nov-18	624330	623939	391000	2414306	2395373	18933	9723	362344	100876	3.59
2-Nov-18	624720	624330	390000	2433174	2414306	18868	9723	361409	100501	3.60
3-Nov-18	625112	624720	392000	2452221	2433174	19047	9723	363230	100669	3.61
4-Nov-18	625505	625112	393000	2471355	2452221	19134	9723	364143	100781	3.61
5-Nov-18	625895	625505	390000	2490250	2471355	18895	9723	361382	102470	3.53
6-Nov-18	626286	625895	391000	2509070	2490250	18820	9723	362457	100572	3.60
7-Nov-18	626675	626286	389000	2528018	2509070	18948	9723	360329	100729	3.58
8-Nov-18	627067	626675	392000	2547378	2528018	19360	9723	362917	100525	3.61
9-Nov-18	627445	627067	378000	2565428	2547378	18050	9723	350227	95762	3.66
10-Nov-18	627835	627445	390000	2584382	2565428	18954	9723	361323	100504	3.60
11-Nov-18	628225	627835	390000	2603312	2584382	18930	9723	361347	100663	3.59
12-Nov-18	628616	628225	391000	2622520	2603312	19208	9723	362069	100410	3.61
13-Nov-18	629007	628616	391000	2641426	2622520	18906	9723	362371	100565	3.60
[illegible]-Nov-18	629400	629007	393000	2660454	2641426	19028	9723	364249	100625	3.62
15-Nov-18	629792	629400	392000	2679680	2660454	19226	9723	363051	100679	3.61
16-Nov-18	630182	629792	390000	2698948	2679680	19268	9723	361009	100581	3.59
17-Nov-18	630573	630182	391000	2717934	2698948	18986	9723	362291	100616	3.60
18-Nov-18	630950	630573	377000	2735782	2717934	17848	9723	349429	95373	3.66
19-Nov-18	631340	630950	390000	2754690	2735782	18908	9723	361369	100464	3.60
20-Nov-18	631715	631340	375000	2772485	2754690	17795	9723	347482	95297	3.65
21-Nov-18	632105	631715	390000	2791430	2772485	18945	9723	361332	100439	3.60
22-Nov-18	632480	632105	375000	2809150	2791430	17720	9723	347557	95432	3.64
23-Nov-18	632870	632480	390000	2827962	2809150	18812	9723	361465	100357	3.60
24-Nov-18	633260	632870	390000	2847024	2827962	19062	9723	361215	100510	3.59
25-Nov-18	633651	633260	391000	2866021	2847024	18997	9723	362280	100784	3.59
26-Nov-18	634042	633651	391000	2884837	2866021	18816	9723	362461	100722	3.60
27-Nov-18	634432	634042	390000	2903660	2884837	18823	9723	361454	100928	3.58
28-Nov-18	634822	634432	390000	2922747	2903660	19087	9723	361190	100724	3.59
29-Nov-18	635212	634822	390000	2941761	2922747	19014	9723	361263	100655	3.59
30-Nov-18	635601	635212	389000	29605[illegible]	2941761	18795	9723	360482	100689	3.58
TOTAL			11662000			565183	291690	10805127	2999902	3.60

MRSS MONTHLY POWER CONSUMPTION	11662000
L&T MONTHLY POWER CONSUMPTION	565183
ENHANCEMENT ADDITIONAL LOAD POWER CONSUMPTION	291690
PLANT MONTHLY POWER CONSUMPTION	10805127
POWER CONSUMPTION DURING SHUTDOWN / PLANT MAINTENANCE	0
NET PLANT MONTHLY POWER CONSUMPTION	*10805127*
RO WATER MOTHLY PRODUCTION	2999902
PLANT SPECIFIC POWER KWH/M3	3.60

VATECH WABAG LTD

CMWSSB

3/12/18

WABAG	100 MLD DESALINATION PLANT , NEMMELI	
10M35/EPCR/E/006	POWER CONSUMPTION FOR THE MONTH OF DECEMBER 2018	

DATE	MRSS TRIVECTOR METER READING			L&T READING			ENHANCEMENT ADDITIONAL LOAD	NET PLANT POWER CONSUMPTION (KWH)	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	MRSS POWER CONSUMPTION (KWH)	FINAL READING (KWH)	INITIAL READING (KWH)	L&T POWER CONSUMPTION (KWH)	POWER CONSUMPTION (KWH)			
1-Dec-18	635910	635601	309000	2976599	2960556	16043	9723	283234	83005	3.41
2-Dec-18	636285	635910	375000	2995630	2976599	19031	9723	346246	100500	3.45
3-Dec-18	636659	636285	374000	3014685	2995630	19055	9723	345222	100587	3.43
4-Dec-18	637033	636659	374000	3033410	3014685	18725	9723	345552	100624	3.43
5-Dec-18	637408	637033	375000	3052346	3033410	18936	9723	346341	100866	3.43
6-Dec-18	637784	637408	376000	3071278	3052346	18932	9723	347345	100719	3.45
7-Dec-18	638160	637784	376000	3090211	3071278	18933	9723	347344	100568	3.45
8-Dec-18	638534	638160	374000	3109165	3090211	18954	9723	345323	100574	3.43
9-Dec-18	638911	638534	377000	3128421	3109165	19256	9723	348021	100450	3.46
10-Dec-18	639286	638911	375000	3147001	3128421	18580	9723	346697	96871	3.58
11-Dec-18	639666	639286	380000	3165854	3147001	18853	9723	351424	100676	3.49
12-Dec-18	640046	639666	380000	3184903	3165854	19049	9723	351228	100778	3.49
13-Dec-18	640430	640046	384000	3203798	3184903	18895	9723	355382	100491	3.54
14-Dec-18	640817	640430	387000	3222895	3203798	19097	9723	358180	100643	3.56
15-Dec-18	641107	640817	290000	3236989	3222895	14094	9723	266183	73963	3.60
16-Dec-18	641414	641107	307000	3251106	3236989	14117	9723	283160	78698	3.60
17-Dec-18	641705	641414	291000	3263010	3251106	11904	9723	269373	71786	3.75
18-Dec-18	642035	641705	330000	3277659	3263010	14649	9723	305628	82636	3.70
19-Dec-18	642419	642035	384000	3296807	3277659	19148	9723	355129	100214	3.54
20-Dec-18	642805	642419	386000	3315756	3296807	18949	9723	357328	100690	3.55
21-Dec-18	643188	642805	383000	3334662	3315756	18906	9723	354371	100268	3.53
22-Dec-18	643569	643188	381000	3353961	3334662	19299	9723	351978	100510	3.50
23-Dec-18	643952	643569	383000	3373011	3353961	19050	9723	354227	100512	3.52
24-Dec-18	644332	643952	380000	3392031	3373011	19020	9723	351257	98523	3.57
25-Dec-18	644721	644332	389000	3410972	3392031	18941	9723	360336	98582	3.66
26-Dec-18	645101	644721	380000	3430096	3410972	19124	9723	351153	98102	3.58
27-Dec-18	645149	645101	48000	3430501	3430096	405	9723	37872	7644	4.95
28-Dec-18	645540	645149	391000	3449482	3430501	18981	9723	362296	100593	3.60
29-Dec-18	645933	645540	393000	3468326	3449482	18844	9723	364433	100518	3.63
30-Dec-18	646327	645933	394000	3487568	3468326	19242	9723	365035	100690	3.63
31-Dec-18	646723	646327	396000	3506647	3487568	19079	9723	367198	100474	3.65
TOTAL			11122000			546091	301413	10274496	2901755	3.53

MRSS MONTHLY POWER CONSUMPTION	11122000
L&T MONTHLY POWER CONSUMPTION	546091
ENHANCEMENT ADDITIONAL LOAD POWER CONSUMPTION	301413
PLANT MONTHLY POWER CONSUMPTION	10274496
POWER CONSUMPTION DURING SHUTDOWN / PLANT MAINTENANCE	37872
NET PLANT MONTHLY POWER CONSUMPTION	*10236624*
RO WATER MOTHLY PRODUCTION	2901755
PLANT SPECIFIC POWER KWH/M3	3.53

VATECH WABAG LTD

3/1/19

CMWSSB