

10M35/EPCR/E/006
POWER CONSUMPTION FOR THE MONTH OF JANUARY 2016

DATE	MRSS TRIVECTOR METER READING			L&T READING			DWRO	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	PLANT POWER CONSUMPTION (KWH)		
1-Jan-16	308701	308561	140000	5690.836	5685.428	5408.00	134592.00	33172	4.06
2-Jan-16	308841	308701	140000	5696.351	5690.836	5515.00	134485.00	33143	4.06
3-Jan-16	308981	308841	140000	5701.758	5696.351	5407.00	134593.00	33178	4.06
4-Jan-16	309122	308981	141000	5707.085	5701.758	5327.00	135673.00	33480	4.05
5-Jan-16	309262	309122	140000	5712.467	5707.085	5382.00	134618.00	33208	4.05
6-Jan-16	309403	309262	141000	5717.952	5712.467	5485.00	135515.00	33344	4.06
7-Jan-16	309529	309403	126000	5723.416	5717.952	5464.00	120536.00	30900	3.90
8-Jan-16	309541	309529	12000	5723.618	5723.416	202.00	11798.00	0	0.00
9-Jan-16	309639	309541	98000	5727.438	5723.618	3820.00	94180.00	24809	3.80
10-Jan-16	309780	309639	141000	5733.197	5727.438	5759.00	135241.00	33347	4.06
11-Jan-16	309919	309780	139000	5738.704	5733.197	5507.00	133493.00	33043	4.04
12-Jan-16	310058	309919	139000	5744.073	5738.704	5369.00	133631.00	33073	4.04
13-Jan-16	310197	310058	139000	5749.522	5744.073	5449.00	133551.00	33262	4.02
14-Jan-16	310337	310197	140000	5754.807	5749.522	5285.00	134715.00	33111	4.07
15-Jan-16	310477	310337	140000	5760.493	5754.807	5686.00	134314.00	33330	4.03
16-Jan-16	310616	310477	139000	5765.8	5760.493	5307.00	133693.00	33093	4.04
17-Jan-16	310755	310616	139000	5771.289	5765.8	5489.00	133511.00	33146	4.03
18-Jan-16	310894	310755	139000	5776.707	5771.289	5418.00	133582.00	33124	4.03
19-Jan-16	311033	310894	139000	5782.063	5776.707	5356.00	133644.00	33115	4.04
20-Jan-16	311172	311033	139000	5787.611	5782.063	5548.00	133452.00	33316	4.01
21-Jan-16	311311	311172	139000	5793.008	5787.611	5397.00	133603.00	33244	4.02
22-Jan-16	311450	311311	139000	5798.283	5793.008	5275.00	133725.00	33123	4.04
23-Jan-16	311562	311450	112000	5802.612	5798.283	4329.00	107671.00	25480	4.23
24-Jan-16	311694	311562	132000	5807.644	5802.612	5032.00	126968.00	30599	4.15
25-Jan-16	311835	311694	141000	5812.895	5807.644	5251.00	135749.00	33138	4.10
26-Jan-16	311969	311835	134000	5817.986	5812.895	5091.00	128909.00	30248	4.26
27-Jan-16	312122	311969	153000	5823.657	5817.986	5671.00	147329.00	37209	3.96
28-Jan-16	312286	312122	164000	5823.321	5823.657	6210.00	157790.00	41070	3.84
29-Jan-16	312451	312286	165000	10065	3475.321	6589.68	158410.32	40747	3.89
30-Jan-16	312618	312451	167000	16676	10065	6611.00	160389.00	40730	3.94
31-Jan-16	312783	312618	165000	23261	16676	6585.00	158415.00	40711	3.89
TOTAL			4222000			164225	4057775	1006493	4.03

MRSS MONTHLY POWER CONSUMPTION	4222000	KWH
L&T MONTHLY POWER CONSUMPTION	164225	KWH
PLANT MONTHLY POWER CONSUMPTION	4057775	KWH
POWER CONSUMPTION DURING SHUTDOWN	11798	KWH
NET PLANT MONTHLY POWER CONSUMPTION	4045977	KWH
RO WATER MONTHLY PRODUCTION	1006493	M3
AVERAGE KWH/M3	4.02	KWHr/M3

10M35/EPCR/E/006

POWER CONSUMPTION FOR THE MONTH OF FEBRUARY 2016

DATE	MRSS TRIVECTOR METER READING			L&T READING			DWRO	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	PLANT POWER CONSUMPTION (KWH)		
1-Feb-16	312944	312783	161000	29690	23261	6429.00	154571	40103	3.85
2-Feb-16	313109	312944	165000	36092	29690	6402.00	158598	40746	3.89
3-Feb-16	313272	313109	163000	41972	36092	5880.00	157120	40707	3.86
4-Feb-16	313440	313272	168000	48643	41972	6671.00	161329	41238	3.91
5-Feb-16	313609	313440	169000	55303	48643	6660.00	162340	41392	3.92
6-Feb-16	313771	313609	162000	61498	55303	6195.00	155805	39199	3.97
7-Feb-16	313937	313771	166000	68102	61498	6604.00	159396	41508	3.84
8-Feb-16	314103	313937	166000	74847	68102	6745.00	159255	41188	3.87
9-Feb-16	314272	314103	169000	81390	74847	6543.00	162457	41403	3.92
10-Feb-16	314440	314272	168000	87747	81390	6357.00	161643	41064	3.94
11-Feb-16	314607	314440	167000	93811	87747	6064.00	160936	40588	3.97
12-Feb-16	314776	314607	169000	100314	93811	6503.00	162497	41298	3.93
13-Feb-16	314943	314776	167000	106790	100314	6476.00	160524	40740	3.94
14-Feb-16	315108	314943	165000	112628	106790	5838.00	159162	40457	3.93
15-Feb-16	315276	315108	168000	119196	112628	6568.00	161432	41444	3.90
16-Feb-16	315443	315276	167000	125444	119196	6248.00	160752	41193	3.90
17-Feb-16	315599	315443	156000	132048	125444	6604.00	149396	38465	3.88
18-Feb-16	315770	315599	171000	138501	132048	6453.00	164547	41607	3.95
19-Feb-16	315937	315770	167000	144592	138501	6091.00	160909	41238	3.90
20-Feb-16	316103	315937	166000	150909	144592	6317.00	159683	40771	3.92
21-Feb-16	316270	316103	167000	157305	150909	6396.00	160604	41006	3.92
22-Feb-16	316436	316270	166000	163476	157305	6171.00	159829	40830	3.91
23-Feb-16	316603	316436	167000	169692	163476	6216.00	160784	41051	3.92
24-Feb-16	316778	316603	175000	176287	169692	6595.00	168405	41137	4.09
25-Feb-16	316951	316778	173000	183084	176287	6797.00	166203	41816	3.97
26-Feb-16	317122	316951	171000	189817	183084	6733.00	164267	41461	3.96
27-Feb-16	317293	317122	171000	196024	189817	6207.00	164793	41437	3.98
28-Feb-16	317461	317293	168000	202124	196024	6100.00	161900	40951	3.95
29-Feb-16	317627	317461	166000	208701	202124	6577.00	159423	40495	3.94
TOTAL			4844000			185440	4658560	1186533	3.93

MRSS MONTHLY POWER CONSUMPTION	4844000	KWH
L&T MONTHLY POWER CONSUMPTION	185440	KWH
PLANT MONTHLY POWER CONSUMPTION	4658560	KWH
POWER CONSUMPTION DURING SHUTDOWN	0	KWH
NET PLANT MONTHLY POWER CONSUMPTION	4658560	KWH
RO WATER MONTHLY PRODUCTION	1186533	M3
AVERAGE KWH/M3	3.93	KWHr/M3

10M35/EPCR/E/006
POWER CONSUMPTION FOR THE MONTH OF MARCH 2016

DATE	MRSS TRIVECTOR METER READING			L&T READING			DWRO	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	PLANT POWER CONSUMPTION (KWH)		
1-Mar-16	317794	317627	167000	215468	208701	6767.00	160233	40981	3.91
2-Mar-16	317960	317794	166000	221793	215468	6325.00	159675	40907	3.90
3-Mar-16	318126	317960	166000	228477	221793	6684.00	159316	40376	3.95
4-Mar-16	318293	318126	167000	235123	228477	6646.00	160354	40740	3.94
5-Mar-16	318457	318293	164000	241537	235123	6414.00	157586	40391	3.90
6-Mar-16	318625	318457	168000	247851	241537	6314.00	161686	41162	3.93
7-Mar-16	318790	318625	165000	253888	247851	6037.00	158963	40335	3.94
8-Mar-16	318958	318790	168000	260584	253888	6696.00	161304	40732	3.96
9-Mar-16	319126	318958	168000	267283	260584	6699.00	161301	40635	3.97
10-Mar-16	319293	319126	167000	273894	267283	6611.00	160389	40600	3.95
11-Mar-16	319460	319293	167000	280350	273894	6456.00	160544	41015	3.91
12-Mar-16	319696	319460	236000	289071	280350	8721.00	227279	56131	4.05
13-Mar-16	319975	319696	279000	299985	289071	10914.00	268086	66180	4.05
14-Mar-16	320253	319975	278000	310751	299985	10766.00	267234	64794	4.12
15-Mar-16	320529	320253	276000	321154	310751	10403.00	265597	64530	4.12
16-Mar-16	320805	320529	276000	331784	321154	10630.00	265370	64468	4.12
17-Mar-16	321070	320805	265000	342164	331784	10380.00	254620	61879	4.11
18-Mar-16	321344	321070	274000	352602	342164	10438.00	263562	64095	4.11
19-Mar-16	321551	321344	207000	360656	352602	8054.00	198946	48070	4.14
20-Mar-16	321775	321551	224000	369173	360656	8517.00	215483	52704	4.09
21-Mar-16	321976	321775	201000	376783	369173	7610.00	193390	50185	3.85
22-Mar-16	322179	321976	203000	384710	376783	7927.00	195073	50322	3.88
23-Mar-16	322377	322179	198000	392482	384710	7772.00	190228	48601	3.91
24-Mar-16	322583	322377	206000	400607	392482	8125.00	197875	50159	3.94
25-Mar-16	322785	322583	202000	408935	400607	8328.00	193672	50898	3.81
26-Mar-16	322987	322785	202000	416991	408935	8056.00	193944	50376	3.85
27-Mar-16	323193	322987	206000	425102	416991	8111.00	197889	51260	3.86
28-Mar-16	323397	323193	204000	433083	425102	7981.00	196019	50701	3.87
29-Mar-16	323598	323397	201000	441187	433083	8104.00	192896	50391	3.83
30-Mar-16	323800	323598	202000	449417	441187	8230.00	193770	50944	3.80
31-Mar-16	324001	323800	201000	457581	449417	8164.00	192836	51256	3.76
TOTAL			6374000			248880	6125120	1545818	3.96

MRSS MONTHLY POWER CONSUMPTION	6374000	KWH
L&T MONTHLY POWER CONSUMPTION	248880	KWH
PLANT MONTHLY POWER CONSUMPTION	6125120	KWH
POWER CONSUMPTION DURING SHUTDOWN	0	KWH
NET PLANT MONTHLY POWER CONSUMPTION	6125120	KWH
RO WATER MONTHLY PRODUCTION	1545818	M3
AVERAGE KWH/M3	3.96	KWHr/M3

10M35/EPCR/E/006
POWER CONSUMPTION FOR THE MONTH OF APRIL 2016

DATE	MRSS TRIVECTOR METER READING			L&T READING			DWRO	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	PLANT POWER CONSUMPTION (KWH)		
1-Apr-16	324203	324001	202000	465477	457581	7896	194104	51657	3.76
2-Apr-16	324409	324203	206000	473298	465477	7821	198179	51250	3.87
3-Apr-16	324612	324409	203000	481176	473298	7878	195122	51090	3.82
4-Apr-16	324815	324612	203000	489408	481176	8232	194768	51272	3.80
5-Apr-16	324967	324815	152000	496063	489408	6655	145345	36346	4.00
6-Apr-16	325169	324967	202000	504112	496063	8049	193951	51173	3.79
7-Apr-16	325373	325169	204000	512027	504112	7915	196085	50920	3.85
8-Apr-16	325579	325373	206000	520054	512027	8027	197973	51113	3.87
9-Apr-16	325786	325579	207000	527827	520054	7773	199227	51568	3.86
10-Apr-16	325991	325786	205000	535848	527827	8021	196979	51013	3.86
11-Apr-16	326189	325991	198000	543637	535848	7789	190211	50302	3.78
12-Apr-16	326394	326189	205000	551597	543637	7960	197040	51559	3.82
13-Apr-16	326599	326394	205000	559666	551597	8069	196931	51692	3.81
14-Apr-16	326803	326599	204000	567744	559666	8078	195922	51348	3.82
15-Apr-16	327005	326803	202000	575504	567744	7760	194240	51053	3.80
16-Apr-16	327208	327005	203000	583496	575504	7992	195008	51647	3.78
17-Apr-16	327410	327208	202000	591464	583496	7968	194032	51430	3.77
18-Apr-16	327611	327410	201000	599425	591464	7961	193039	51265	3.77
19-Apr-16	327808	327611	197000	607415	599425	7990	189010	51081	3.70
20-Apr-16	327995	327808	187000	614916	607415	7501	179499	47748	3.76
21-Apr-16	328196	327995	201000	623136	614916	8220	192780	52153	3.70
22-Apr-16	328398	328196	202000	631269	623136	8133	193867	52404	3.70
23-Apr-16	328600	328398	202000	639340	631269	8071	193929	52235	3.71
24-Apr-16	328805	328600	205000	647989	639340	8649	196351	52360	3.75
25-Apr-16	329011	328805	206000	656823	647989	8834	197166	52409	3.76
26-Apr-16	329240	329011	229000	666566	656823	9743	219257	57343	3.82
27-Apr-16	329512	329240	272000	677840	666566	11274	260726	65937	3.95
28-Apr-16	329782	329512	270000	688475	677840	10635	259365	64536	4.02
29-Apr-16	329911	329782	129000	692748	688475	4273	124727	30972	4.03
30-Apr-16	330184	329911	273000	704164	692748	11416	261584	65251	4.01
TOTAL			6183000			246583	5936417	1552127	3.82

MRSS MONTHLY POWER CONSUMPTION	6183000	KWH
L&T MONTHLY POWER CONSUMPTION	246583	KWH
PLANT MONTHLY POWER CONSUMPTION	5936417	KWH
POWER CONSUMPTION DURING SHUTDOWN	0	KWH
NET PLANT MONTHLY POWER CONSUMPTION	5936417	KWH
RO WATER MONTHLY PRODUCTION	1552127	M3
AVERAGE KWH/M3	3.82	KWHr/M3

VATECH WABAG LTD.

CMWSSB

10M35/EPCR/E/006

POWER CONSUMPTION FOR THE MONTH OF MAY 2016

DATE	MRSS TRIVECTOR METER READING			L&T READING			DWRO	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	PLANT POWER CONSUMPTION (KWH)		
1-May-16	330459	330184	275000	715073	704164	10909	264091	65247	4.05
2-May-16	330700	330459	241000	724405	715073	9332	231668	56842	4.08
3-May-16	330987	330700	287000	735873	724405	11468	275532	70182	3.93
4-May-16	331276	330987	289000	747964	735873	12091	276909	72321	3.83
5-May-16	331567	331276	291000	760471	747964	12507	278493	72032	3.87
6-May-16	331859	331567	292000	772193	760471	11722	280278	71969	3.89
7-May-16	332151	331859	292000	784568	772193	12375	279625	73066	3.83
8-May-16	332442	332151	291000	796409	784568	11841	279159	71973	3.88
9-May-16	332733	332442	291000	808616	796409	12207	278793	72447	3.85
10-May-16	333027	332733	294000	821040	808616	12424	281576	72855	3.86
11-May-16	333318	333027	291000	833205	821040	12165	278835	71990	3.87
12-May-16	333606	333318	288000	845441	833205	12236	275764	70593	3.91
13-May-16	333893	333606	287000	857446	845441	12005	274995	71385	3.85
14-May-16	334185	333893	292000	869773	857446	12327	279673	72769	3.84
15-May-16	334467	334185	282000	881264	869773	11491	270509	68329	3.96
16-May-16	334758	334467	291000	894035	881264	12771	278229	72866	3.82
17-May-16	334982	334758	224000	903638	894035	9603	214397	54583	3.93
18-May-16	335096	334982	114000	908398	903638	4760	109240	26340	4.15
19-May-16	335234	335096	138000	913952	908398	5554	132446	33976	3.90
20-May-16	335369	335234	135000	919548	913952	5596	129404	33101	3.91
21-May-16	335504	335369	135000	925118	919548	5570	129430	33193	3.90
22-May-16	335638	335504	134000	930782	925118	5664	128336	32836	3.91
23-May-16	335766	335638	128000	936135	930782	5353	122647	31015	3.95
24-May-16	335894	335766	128000	941172	936135	5037	122963	31121	3.95
25-May-16	336023	335894	129000	946491	941172	5319	123681	31334	3.95
26-May-16	336152	336023	129000	951558	946491	5067	123933	30842	4.02
27-May-16	336265	336152	113000	955706	951558	4148	108852	24158	4.51
28-May-16	336418	336265	153000	961527	955706	5821	147179	37228	3.95
29-May-16	336601	336418	183000	968629	961527	7102	175898	46334	3.80
30-May-16	336790	336601	189000	975960	968629	7331	181669	47856	3.80
31-May-16	336989	336790	199000	983538	975960	7578	191422	50618	3.78
TOTAL			6805000			279374	6525626	1671401	3.90

MRSS MONTHLY POWER CONSUMPTION	6805000	KWH
L&T MONTHLY POWER CONSUMPTION	279374	KWH
PLANT MONTHLY POWER CONSUMPTION	6525626	KWH
POWER CONSUMPTION DURING SHUTDOWN	0	KWH
NET PLANT MONTHLY POWER CONSUMPTION	6525626	KWH
RO WATER MONTHLY PRODUCTION	1671401	M3
AVERAGE KWH/M3	3.90	KWHr/M3

VATECH WABAG LTD

CMWSSB

10M35/EPCR/E/006

POWER CONSUMPTION FOR THE MONTH OF JUNE 2016

DATE	MRSS TRIVECTOR METER READING			L&T READING			DWRO	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	PLANT POWER CONSUMPTION (KWH)		
1-Jun-16	337205	336989	216000	992175	983538	8637	207363	55325	3.75
2-Jun-16	337418	337205	213000	1000862	992175	8687	204313	55048	3.71
3-Jun-16	337635	337418	217000	1009745	1000862	8883	208117	56120	3.71
4-Jun-16	337849	337635	214000	1018801	1009745	9056	204944	53169	3.85
5-Jun-16	338066	337849	217000	1027740	1018801	8939	208061	56133	3.71
6-Jun-16	338285	338066	219000	1036587	1027740	8847	210153	56258	3.74
7-Jun-16	338477	338285	192000	1044726	1036587	8139	183861	48701	3.78
8-Jun-16	338624	338477	147000	1050683	1044726	5957	141043	34552	4.08
9-Jun-16	338647	338624	23000	1051141	1050683	458	22542	1015	22.21
10-Jun-16	338672	338647	25000	1051141	1051141	0	25000	0	#DIV/0!
11-Jun-16	338690	338672	18000	1051141	1051141	0	18000	0	#DIV/0!
12-Jun-16	338721	338690	31000	1051569	1051141	428	30572	0	#DIV/0!
13-Jun-16	338770	338721	49000	1051569	1051569	0	49000	0	#DIV/0!
14-Jun-16	338875	338770	105000	1053964	1051569	2395	102605	20399	5.03
15-Jun-16	338987	338875	112000	1057156	1053964	3192	108808	22093	4.92
16-Jun-16	339169	338987	182000	1064583	1057156	7427	174573	46102	3.79
17-Jun-16	339367	339169	198000	1072865	1064583	8282	189718	50291	3.77
18-Jun-16	339577	339367	210000	1081699	1072865	8834	201166	54100	3.72
19-Jun-16	339794	339577	217000	1090867	1081699	9168	207832	56155	3.70
20-Jun-16	340007	339794	213000	1099607	1090867	8740	204260	55169	3.70
21-Jun-16	340225	340007	218000	1108652	1099607	9045	208955	56539	3.70
22-Jun-16	340439	340225	214000	1117577	1108652	8925	205075	55524	3.69
23-Jun-16	340655	340439	216000	1126477	1117577	8900	207100	55905	3.70
24-Jun-16	340874	340655	219000	1135450	1126477	8973	210027	56869	3.69
25-Jun-16	341087	340874	213000	1143726	1135450	8276	204724	52120	3.93
26-Jun-16	341305	341087	218000	1152862	1143726	9136	208864	56626	3.69
27-Jun-16	341521	341305	216000	1162358	1152862	9496	206504	55840	3.70
28-Jun-16	341736	341521	215000	1171646	1162358	9288	205712	55739	3.69
29-Jun-16	341948	341736	212000	1180875	1171646	9229	202771	54907	3.69
30-Jun-16	342132	341948	184000	1188206	1180875	7331	176669	45273	3.90
TOTAL			5143000			204668	4938332	1265972	3.90

MRSS MONTHLY POWER CONSUMPTION	5143000	KWH
L&T MONTHLY POWER CONSUMPTION	204668	KWH
PLANT MONTHLY POWER CONSUMPTION	4938332	KWH
POWER CONSUMPTION DURING SHUTDOWN	122572	KWH
NET PLANT MONTHLY POWER CONSUMPTION	4815760	KWH
RO WATER MONTHLY PRODUCTION	1265972	M3
AVERAGE KWH/M3	3.90	KWHr/M3
AVERAGE KWH/M3 (EXCLUDING SHUTDOWN DAYS POWER CONSUMPTION)	3.80	KWHr/M3

10M35/EPCR/E/006
POWER CONSUMPTION FOR THE MONTH OF JULY 2016

DATE	MRSS TRIVECTOR METER READING			L&T READING			DWRO	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	PLANT POWER CONSUMPTION (KWH)		
1-Jul-16	342300	342132	168000	1194586	1188206	6380	161620	39407	4.10
2-Jul-16	342475	342300	175000	1201057	1194586	6471	168529	42287	3.99
3-Jul-16	342684	342475	209000	1209908	1201057	8851	200149	53163	3.76
4-Jul-16	342882	342684	198000	1218424	1209908	8516	189484	50065	3.78
5-Jul-16	343095	342882	213000	1226742	1218424	8318	204682	53812	3.80
6-Jul-16	343322	343095	227000	1236575	1226742	9833	217167	57979	3.75
7-Jul-16	343546	343322	224000	1246102	1236575	9527	214473	57063	3.76
8-Jul-16	343775	343546	229000	1255825	1246102	9723	219277	58487	3.75
9-Jul-16	344009	343775	234000	1265562	1255825	9737	224263	59372	3.78
10-Jul-16	344243	344009	234000	1275223	1265562	9661	224339	59606	3.76
11-Jul-16	344477	344243	234000	1284896	1275223	9673	224327	59329	3.78
12-Jul-16	344712	344477	235000	1294471	1284896	9575	225425	59742	3.77
13-Jul-16	344923	344712	211000	1303770	1294471	9299	201701	52407	3.85
14-Jul-16	345139	344923	216000	1312956	1303770	9186	206814	55274	3.74
15-Jul-16	345257	345139	118000	1317052	1312956	4096	113904	25151	4.53
16-Jul-16	345381	345257	124000	1321379	1317052	4327	119673	27394	4.37
17-Jul-16	345529	345381	148000	1326823	1321379	5444	142556	33859	4.21
18-Jul-16	345773	345529	244000	1336420	1326823	9597	234403	59546	3.94
19-Jul-16	346008	345773	235000	1345867	1336420	9447	225553	59253	3.81
20-Jul-16	346251	346008	243000	1355431	1345867	9564	233436	59308	3.94
21-Jul-16	346489	346251	238000	1365017	1355431	9586	228414	59861	3.82
22-Jul-16	346726	346489	237000	1374768	1365017	9751	227249	59248	3.84
23-Jul-16	346932	346726	206000	1382867	1374768	8099	197901	50070	3.95
24-Jul-16	347167	346932	235000	1392606	1382867	9739	225261	59361	3.79
25-Jul-16	347404	347167	237000	1402232	1392606	9626	227374	59292	3.83
26-Jul-16	347617	347404	213000	1410207	1402232	7975	205025	50951	4.02
27-Jul-16	347794	347617	177000	1417296	1410207	7089	169911	44747	3.80
28-Jul-16	347977	347794	183000	1424223	1417296	6927	176073	45770	3.85
29-Jul-16	348148	347977	171000	1430853	1424223	6630	164370	42815	3.84
30-Jul-16	348339	348148	191000	1438891	1430853	8038	182962	48279	3.79
31-Jul-16	348552	348339	213000	1447551	1438891	8660	204340	53352	3.83
TOTAL			6420000			259345	6160655	1596250	3.86

MRSS MONTHLY POWER CONSUMPTION	6420000	KWH
L&T MONTHLY POWER CONSUMPTION	259345	KWH
PLANT MONTHLY POWER CONSUMPTION	6160655	KWH
POWER CONSUMPTION DURING SHUTDOWN	0	KWH
NET PLANT MONTHLY POWER CONSUMPTION	6160655	KWH
RO WATER MONTHLY PRODUCTION	1596250	M3
PLANT SPECIFIC POWER KWH/M3	3.86	KWHr/M3
NET PLANT SPECIFIC POWER KWH/M3	3.86	KWHr/M3

10M35/EPCR/E/006
POWER CONSUMPTION FOR THE MONTH OF AUGUST 2016

DATE	MRSS TRIVECTOR METER READING			L&T READING			DWRO	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	PLANT POWER CONSUMPTION (KWH)		
1-Aug-16	348791	348552	239000	1457248	1447551	9697	229303	59588	3.85
2-Aug-16	349020	348791	229000	1466277	1457248	9029	219971	59326	3.71
3-Aug-16	349251	349020	231000	1476186	1466277	9909	221091	59917	3.69
4-Aug-16	349484	349251	233000	1485564	1476186	9378	223622	59626	3.75
5-Aug-16	349718	349484	234000	1495388	1485564	9824	224176	59207	3.79
6-Aug-16	349951	349718	233000	1505080	1495388	9692	223308	59846	3.73
7-Aug-16	350183	349951	232000	1514845	1505080	9765	222235	59712	3.72
8-Aug-16	350419	350183	236000	1524287	1514845	9442	226558	59886	3.78
9-Aug-16	350655	350419	236000	1534051	1524287	9764	226236	59692	3.79
10-Aug-16	350887	350655	232000	1543460	1534051	9409	222591	59499	3.74
11-Aug-16	351123	350887	236000	1553064	1543460	9604	226396	59550	3.80
12-Aug-16	351358	351123	235000	1562296	1553064	9232	225768	59477	3.80
13-Aug-16	351591	351358	233000	1571888	1562296	9592	223408	59135	3.78
14-Aug-16	351828	351591	237000	1581725	1571888	9837	227163	59641	3.81
15-Aug-16	352065	351828	237000	1591293	1581725	9568	227432	59470	3.82
16-Aug-16	352301	352065	236000	1600791	1591293	9498	226502	59411	3.81
17-Aug-16	352544	352301	243000	1610386	1600791	9595	233405	59610	3.92
18-Aug-16	352787	352544	243000	1619621	1610386	9235	233765	59609	3.92
19-Aug-16	353031	352787	244000	1629312	1619621	9691	234309	59652	3.93
20-Aug-16	353275	353031	244000	1638751	1629312	9439	234561	59578	3.94
21-Aug-16	353517	353275	242000	1648234	1638751	9483	232517	59376	3.92
22-Aug-16	353760	353517	243000	1658116	1648234	9882	233118	59651	3.91
23-Aug-16	354008	353760	248000	1666905	1658116	8789	239211	57149	4.19
24-Aug-16	354249	354008	241000	1676804	1666905	9899	231101	59690	3.87
25-Aug-16	354485	354249	236000	1686148	1676804	9344	226656	59517	3.81
26-Aug-16	354719	354485	234000	1695585	1686148	9437	224563	59048	3.80
27-Aug-16	354947	354719	228000	1705004	1695585	9419	218581	55964	3.91
28-Aug-16	355186	354947	239000	1714736	1705004	9732	229268	59725	3.84
29-Aug-16	355424	355186	238000	1724330	1714736	9594	228406	59810	3.82
30-Aug-16	355660	355424	236000	1734106	1724330	9776	226224	59738	3.79
31-Aug-16	355945	355660	285000	1745807	1734106	11701	273299	70383	3.88
TOTAL			7393000			298256	7094744	1851483	3.83

MRSS MONTHLY POWER CONSUMPTION	7393000	KWH
L&T MONTHLY POWER CONSUMPTION	298256	KWH
PLANT MONTHLY POWER CONSUMPTION	7094744	KWH
POWER CONSUMPTION DURING SHUTDOWN	0	KWH
NET PLANT MONTHLY POWER CONSUMPTION	7094744	KWH
RO WATER MONTHLY PRODUCTION	1851483	M3
PLANT SPECIFIC POWER KWH/M3	3.83	KWHr/M3
NET PLANT SPECIFIC POWER KWH/M3	3.83	KWHr/M3

VATECH WABAG LTD
CMWSSB

10M35/EPCR/E/006

POWER CONSUMPTION FOR THE MONTH OF SEPTEMBER 2016

DATE	MRSS TRIVECTOR METER READING			L&T READING			DWRO	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	PLANT POWER CONSUMPTION (KWH)		
1-Sep-16	356231	355945	286000	1757773	1745807	11966	274034	71899	3.81
2-Sep-16	356447	356231	216000	1766205	1757773	8432	207568	52577	3.95
3-Sep-16	356601	356447	154000	1772344	1766205	6139	147861	38328	3.86
4-Sep-16	356770	356601	169000	1778837	1772344	6493	162507	42292	3.84
5-Sep-16	357003	356770	233000	1787869	1778837	9032	223968	55756	4.02
6-Sep-16	357295	357003	292000	1800398	1787869	12529	279471	72751	3.84
7-Sep-16	357315	357295	20000	1800663	1800398	265	19735	0	-
8-Sep-16	357333	357315	18000	1800903	1800663	240	17760	578	-
9-Sep-16	357631	357333	298000	1813631	1800903	12728	285272	74682	3.82
10-Sep-16	357900	357631	269000	1823989	1813631	10358	258642	58755	4.40
11-Sep-16	358147	357900	247000	1834445	1823989	10456	236544	60092	3.94
12-Sep-16	358320	358147	173000	1840279	1834445	5834	167166	39619	4.22
13-Sep-16	358485	358320	165000	1846313	1840279	6034	158966	38840	4.09
14-Sep-16	358788	358485	303000	1859825	1846313	13512	289488	76233	3.80
15-Sep-16	359017	358788	229000	1868914	1859825	9089	219911	55443	3.97
16-Sep-16	359210	359017	193000	1876144	1868914	7230	185770	44662	4.16
17-Sep-16	359446	359210	236000	1885904	1876144	9760	226240	58244	3.88
18-Sep-16	359758	359446	312000	1899116	1885904	13212	298788	78604	3.80
19-Sep-16	360099	359758	341000	1914438	1899116	15322	325678	87350	3.73
20-Sep-16	360440	360099	341000	1929719	1914438	15281	325719	87401	3.73
21-Sep-16	360780	360440	340000	1945206	1929719	15487	324513	87098	3.73
22-Sep-16	361079	360780	299000	1957864	1945206	12658	286342	74075	3.87
23-Sep-16	361242	361079	163000	1963921	1957864	6057	156943	38352	4.09
24-Sep-16	361541	361242	299000	1976885	1963921	12964	286036	74339	3.85
25-Sep-16	361804	361541	263000	1987834	1976885	10949	252051	64064	3.93
26-Sep-16	362107	361804	303000	2000125	1987834	12291	290709	72081	4.03
27-Sep-16	362395	362107	288000	2011742	2000125	11617	276383	72162	3.83
28-Sep-16	362665	362395	270000	2023086	2011742	11344	258656	66431	3.89
29-Sep-16	362938	362665	273000	2033972	2023086	10886	262114	67594	3.88
30-Sep-16	363247	362938	309000	2046583	2033972	12611	296389	78025	3.80
TOTAL			7302000			300776	7001224	1788327	3.91

MRSS MONTHLY POWER CONSUMPTION	7302000	KWH
L&T MONTHLY POWER CONSUMPTION	300776	KWH
PLANT MONTHLY POWER CONSUMPTION	7001224	KWH
POWER CONSUMPTION DURING SHUTDOWN	37495	KWH
NET PLANT MONTHLY POWER CONSUMPTION	6963729	KWH
RO WATER MONTHLY PRODUCTION	1788327	M3
PLANT SPECIFIC POWER KWH/M3	3.91	KWHr/M3
NET PLANT SPECIFIC POWER KWH/M3	3.89	KWHr/M3

VATECH WABAG LTD

CMWSSB

10M35/EPCR/E/006
POWER CONSUMPTION FOR THE MONTH OF OCTOBER 2016

DATE	MRSS TRIVECTOR METER READING			L&T READING			DWRO	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	PLANT POWER CONSUMPTION (KWH)		
1-Oct-16	363523	363247	276000	2058056	2046583	11473	264527	67864	3.90
2-Oct-16	363798	363523	275000	2069331	2058056	11275	263725	67463	3.91
3-Oct-16	364112	363798	314000	2082891	2069331	13560	300440	79822	3.76
4-Oct-16	364459	364112	347000	2098458	2082891	15567	331433	89200	3.72
5-Oct-16	364793	364459	334000	2113238	2098458	14780	319220	86282	3.70
6-Oct-16	365127	364793	334000	2128265	2113238	15027	318973	86306	3.70
7-Oct-16	365469	365127	342000	2143095	2128265	14830	327170	88385	3.70
8-Oct-16	365750	365469	281000	2153824	2143095	10729	270271	66037	4.09
9-Oct-16	366036	365750	286000	2164951	2153824	11127	274873	68450	4.02
10-Oct-16	366325	366036	289000	2176182	2164951	11231	277769	68534	4.05
11-Oct-16	366587	366325	262000	2187715	2176182	11533	250467	64429	3.89
12-Oct-16	366937	366587	350000	2204125	2187715	16410	333590	90211	3.70
13-Oct-16	367287	366937	350000	2220686	2204125	16561	333439	90201	3.70
14-Oct-16	367636	367287	349000	2236570	2220686	15884	333116	90270	3.69
15-Oct-16	367985	367636	349000	2252690	2236570	16120	332880	90307	3.69
16-Oct-16	368334	367985	349000	2269086	2252690	16396	332604	90290	3.68
17-Oct-16	368681	368334	347000	2284454	2269086	15368	331632	90099	3.68
18-Oct-16	369029	368681	348000	2300878	2284454	16424	331576	90172	3.68
19-Oct-16	369369	369029	340000	2316728	2300878	15850	324150	87326	3.71
20-Oct-16	369711	369369	342000	2332581	2316728	15853	326147	87793	3.71
21-Oct-16	370050	369711	339000	2348424	2332581	15843	323157	87097	3.71
22-Oct-16	370390	370050	340000	2364429	2348424	16005	323995	87314	3.71
23-Oct-16	370730	370390	340000	2379855	2364429	15426	324574	87734	3.70
24-Oct-16	370773	370730	43000	2381152	2379855	1297	41703	7415	5.62
25-Oct-16	371072	370773	299000	2394117	2381152	12965	286035	76424	3.74
26-Oct-16	371411	371072	339000	2409981	2394117	15864	323136	87222	3.70
27-Oct-16	371751	371411	340000	2425684	2409981	15703	324297	87348	3.71
28-Oct-16	372099	371751	348000	2441433	2425684	15749	332251	90114	3.69
29-Oct-16	372439	372099	340000	2456882	2441433	15449	324551	87790	3.70
30-Oct-16	372779	372439	340000	2472396	2456882	15514	324486	87715	3.70
31-Oct-16	373119	372779	340000	2488464	2472396	16068	323932	87894	3.69
TOTAL			9872000			441881	9430119	2513508	3.75

MRSS MONTHLY POWER CONSUMPTION	9872000	KWH
L&T MONTHLY POWER CONSUMPTION	441881	KWH
PLANT MONTHLY POWER CONSUMPTION	9430119	KWH
POWER CONSUMPTION DURING EB SHUTDOWN	41703	KWH
NET PLANT MONTHLY POWER CONSUMPTION	9388416	KWH
RO WATER MONTHLY PRODUCTION	2513508	M3
PLANT SPECIFIC POWER KWH/M3	3.74	KWHr/M3

VATECH WABAG LTD

 CMWSSB

10M35/EPCR/E/006

POWER CONSUMPTION FOR THE MONTH OF NOVEMBER 2016

DATE	MRSS TRIVECTOR METER READING			L&T READING			DWRO	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	PLANT POWER CONSUMPTION (KWH)		
1-Nov-16	373452	373119	333000	2503384	2488464	14920	318080	86394	3.68
2-Nov-16	373791	373452	339000	2519239	2503384	15855	323145	87870	3.68
3-Nov-16	374130	373791	339000	2534879	2519239	15640	323360	87804	3.68
4-Nov-16	374372	374130	242000	2545207	2534879	10328	231672	62596	3.70
5-Nov-16	374637	374372	265000	2556368	2545207	11161	253839	68679	3.70
6-Nov-16	374983	374637	346000	2572669	2556368	16301	329699	90692	3.64
7-Nov-16	375318	374983	335000	2587809	2572669	15140	319860	87020	3.68
8-Nov-16	375655	375318	337000	2603561	2587809	15752	321248	87371	3.68
9-Nov-16	375993	375655	338000	2618955	2603561	15394	322606	87716	3.68
10-Nov-16	376328	375993	335000	2634281	2618955	15326	319674	86942	3.68
11-Nov-16	376663	376328	335000	2650114	2634281	15833	319167	87306	3.66
12-Nov-16	376993	376663	330000	2665263	2650114	15149	314851	86010	3.66
13-Nov-16	377321	376993	328000	2680249	2665263	14986	313014	86010	3.64
14-Nov-16	377651	377321	330000	2695668	2680249	15419	314581	86272	3.65
15-Nov-16	377980	377651	329000	2710711	2695668	15043	313957	86299	3.64
16-Nov-16	378310	377980	330000	2726781	2710711	16070	313930	86275	3.64
17-Nov-16	378633	378310	323000	2740571	2726781	13790	309210	85201	3.63
18-Nov-16	378948	378633	315000	2755216	2740571	14645	300355	82626	3.64
19-Nov-16	379206	378948	258000	2766104	2755216	10888	247112	65434	3.78
20-Nov-16	379470	379206	264000	2777835	2766104	11731	252269	67646	3.73
21-Nov-16	379730	379470	260000	2789040	2777835	11205	248795	66924	3.72
22-Nov-16	379990	379730	260000	2800896	2789040	11856	248144	66261	3.74
23-Nov-16	380243	379990	253000	2811565	2800896	10669	242331	63387	3.82
24-Nov-16	380488	380243	245000	2821721	2811565	10156	234844	60893	3.86
25-Nov-16	380809	380488	321000	2837370	2821721	15649	305351	84421	3.62
26-Nov-16	381088	380809	279000	2849762	2837370	12392	266608	71815	3.71
27-Nov-16	381393	381088	305000	2863753	2849762	13991	291009	79507	3.66
28-Nov-16	381742	381393	349000	2880580	2863753	16827	332173	91367	3.64
29-Nov-16	382085	381742	343000	2896997	2880580	16417	326583	90252	3.62
30-Nov-16	382428	382085	343000	2913476	2896997	16479	326521	90454	3.61
TOTAL			9309000			425012	8883988	2417444	3.67

MRSS MONTHLY POWER CONSUMPTION	9309000	KWH
L&T MONTHLY POWER CONSUMPTION	425012	KWH
PLANT MONTHLY POWER CONSUMPTION	8883988	KWH
POWER CONSUMPTION DURING SHUTDOWN	234844	KWH
NET PLANT MONTHLY POWER CONSUMPTION	8649144	KWH
RO WATER MONTHLY PRODUCTION	2417444	M3
PLANT SPECIFIC POWER KWH/M3	3.58	KWHr/M3

10M35/EPCR/E/006

POWER CONSUMPTION FOR THE MONTH OF DECEMBER 2016

DATE	MRSS TRIVECTOR METER READING			L&T READING			DWRO	RO PRODUCTION (M3)	KWH/M3
	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	FINAL READING (MWH)	INITIAL READING (MWH)	NET READING (KWH)	PLANT POWER CONSUMPTION (KWH)		
1-Dec-16	382473	382428	45000	2915548	2913476	2072	42928	9200	4.67
2-Dec-16	382482	382473	9000	2915548	2915548	0	9000	0	0.00
3-Dec-16	382563	382482	81000	2918264	2915548	2716	78284	13928	5.62
4-Dec-16	382732	382563	169000	2924773	2918264	6509	162491	42853	3.79
5-Dec-16	383007	382732	275000	2937484	2924773	12711	262289	70472	3.72
6-Dec-16	383290	383007	283000	2949469	2937484	11985	271015	73198	3.70
7-Dec-16	383500	383290	210000	2957818	2949469	8349	201651	51496	3.92
8-Dec-16	383644	383500	144000	2963343	2957818	5525	138475	35433	3.91
9-Dec-16	383785	383644	141000	2968903	2963343	5560	135440	34626	3.91
10-Dec-16	383891	383785	106000	2973195	2968903	4292	101708	25776	3.95
11-Dec-16	383910	383891	19000	2974005	2973195	810	18190	2402.8	7.57
12-Dec-16	383910	383910	0	2974005	2974005	0	0	0	0.00
13-Dec-16	383910	383910	0	2974005	2974005	0	0	0	0.00
14-Dec-16	383910	383910	0	2974005	2974005	0	0	0	0.00
15-Dec-16	383910	383910	0	2974005	2974005	0	0	0	0.00
16-Dec-16	383918	383910	8000	2974008	2974005	3	7997	0	0.00
17-Dec-16	383944	383918	26000	2974328	2974008	320	25680	0	0.00
18-Dec-16	384079	383944	135000	2979959	2974328	5631	129369	33342	3.88
19-Dec-16	384230	384079	151000	2986036	2979959	6077	144923	37873	3.83
20-Dec-16	384425	384230	195000	2994004	2986036	7968	187032	47539	3.93
21-Dec-16	384679	384425	254000	3004504	2994004	10500	243500	62840	3.87
22-Dec-16	385016	384679	337000	3020915	3004504	16411	320589	87026	3.68
23-Dec-16	385321	385016	305000	3035464	3020915	14549	290451	78508	3.70
24-Dec-16	385668	385321	347000	3052617	3035464	17153	329847	91607	3.60
25-Dec-16	386013	385668	345000	3069391	3052617	16774	328226	91313	3.59
26-Dec-16	386358	386013	345000	3086560	3069391	17169	327831	91660	3.58
27-Dec-16	386701	386358	343000	3103571	3086560	17011	325989	91448	3.56
28-Dec-16	386940	386701	239000	3113055	3103571	9484	229516	58791	3.90
29-Dec-16	387152	386940	212000	3121242	3113055	8187	203813	50787	4.01
30-Dec-16	387397	387152	245000	3131198	3121242	9956	235044	60742	3.87
31-Dec-16	387689	387397	292000	3144044	3131198	12846	279154	75140	3.72
TOTAL			5261000			230568	5030432	1318001	3.82

MRSS MONTHLY POWER CONSUMPTION	5261000	KWH
L&T MONTHLY POWER CONSUMPTION	230568	KWH
PLANT MONTHLY POWER CONSUMPTION	5030432	KWH
POWER CONSUMPTION DURING SHUTDOWN	42677	KWH
NET PLANT MONTHLY POWER CONSUMPTION	4987755	KWH
RO WATER MONTHLY PRODUCTION	1318001	M3
PLANT SPECIFIC POWER KWH/M3	3.78	KWHr/M3