

# H-I-L Testing of Phasor Measurement Unit using Mini-Full Spectrum Simulator

---

Rathin Dholakia

Guided By:

Prof. M. C. Chandorkar

October 18, 2016

MTP Stage - 1


# Introduction

---

# Overview

1. Theoretical background
2. Literature Survey
3. Proposed Scheme
4. Work Done
5. Plan of work

# Aim of Experiment




- **To test the feasibility of Full Spectrum Simulator (FSS) as well as the PMU device as per IEEE C37.118 PMU standard**
  - Implement a power system model having different test case scenarios
  - To use indigenously develop or self designed PMU hardware
  - Evaluate the performance of


# Backgorund - Terms

**C37.118** It is a PMU standard stating the measurement provisions, performance criterion and Data communication protocol.

- **Phasors:** A complex number which represents both magnitude and angle of an AC quantity.
- **Synchrophasors:** synchronized sampling/measurement of phasor at a precise reference (time)



Phasor



Time Varying Phasor  
(Synchrophasor)

# Background - PMU Basics

PMU: It is a device which gives you an estimate of the phasor




Figure 1: Sine to Circle representation [2]

**Sinuloid:**  $x(t) = X_m \cos(\omega t + \varphi)$


**Phasor Representation:**  $\mathbf{X} = \frac{X_m}{\sqrt{2}} \exp^{j\phi}$  or  $\mathbf{X} = X_r + jX_i$

**Frequency**  $f(t) = \frac{1}{2\pi} \frac{d\psi(t)}{dt}$

**ROCOF**  $= df(t)/dt$



# Why Standards are required?

All previous equations are frequency dependent -  $f_0$  - Fundamental frequency



# Why Standards are required?

All previous equations are frequency dependent -  $f_0$  - Fundamental frequency



Different make -

Incompatibility



# Total Vector Error

- Two Quantities to observe - Amplitude & Phase
- Frequency dependency of the result
- we require a reference which is independent and time invariant.
- Hence **Total Vector Error (TVE)**

$$TVE(n) = \sqrt{\frac{(\hat{X}_r(n) - X_r(n))^2 + (\hat{X}_i(n) - X_i(n))^2}{X_r(n)^2 + X_i(n)^2}}$$

## Type of PMU:

- Protection Class: Time critical application, More stringent requirement
- Measurement Class: Greater precision not (very) time critical

# References



C37.118 - IEEE Standard for Synchrophasor Measurements for Power Systems



<http://westernau.com/images/Circle-To-Sine-Wave.png>



Phadke, A.G., Thorp, J.S., *Synchronized Phasor Measurements and Their Applications*, Springer US, 2008.



iPDC & PMU simulator, [ipdc.codeplex.com/](http://ipdc.codeplex.com/)



Phadake A.G., *HISTORY AND APPLICATIONS OF PHASOR MEASUREMENTS*, IEEE, 2006.



Saugata S. Biswas, Jeong Hun Kim, Anurag K Srivastava "Development of a Smart Grid Test Bed and Applications in PMU and PDC Testing" , *IEEE Conference Publications*, 2012.

Thank You