

# H-I-L Testing of Phasor Measurement Unit using Mini-Full Spectrum Simulator

---

Rathin Dholakia

Guided By:

Prof. M. C. Chandorkar

October 20, 2016

MTP Stage - 1


# Introduction

---

# Overview

1. Theoretical background
2. Literature Survey
3. Proposed Scheme
4. Work Done
5. Plan of work

# Aim of Project





- **To test the feasibility of Full Spectrum Simulator (FSS) as well as the PMU device as per IEEE C37.118 PMU standard**
  - Implement a power system model having different test case scenarios
  - To use indigenously develop or self designed PMU hardware
  - Evaluate the performance of

## Background - Terms

**C37.118** It is a PMU standard stating the measurement provisions, performance criterion and Data communication protocol.

- **Phasors:** A complex number which represents both magnitude and angle of an AC quantity.
- **Synchrophasors:** synchronized sampling/measurement of phasor at a precise reference (time)



# Background - PMU Basics

PMU: It is a device which gives you an estimate of the phasor



Figure 1: Sine to Circle representation [2]

**Sinusoid:**  $x(t) = X_m \cos(\omega t + \varphi)$


**Phasor Representation:**  $\mathbf{X} = \frac{X_m}{\sqrt{2}} \exp^{j\phi}$  or  $\mathbf{X} = X_r + jX_i$

**Frequency**  $f(t) = \frac{1}{2\pi} \frac{d\psi(t)}{dt}$

**ROCOF** =  $df(t)/dt$



# Why Standards are required?

All previous equations are frequency dependent -  $f_0$  - Fundamental frequency



# Why Standards are required?

All previous equations are frequency dependent -  $f_0$  - Fundamental frequency



Different make - Incompatibility

# Total Vector Error

- Two Quantities to observe - Amplitude & Phase
- Frequency dependency of the result
- we require a reference which is independent and time invariant.
- Hence **Total Vector Error (TVE)**

$$TVE(n) = \sqrt{\frac{(\hat{X}_r(n)-X_r(n))^2 + (\hat{X}_i(n)-X_i(n))^2}{X_r(n)^2 + X_i(n)^2}}$$

## Type of PMU:

-Protection Class: Time critical application, More stringent requirement

-Measurement Class: Greater precision not (very) time critical

# Types of Tests

To get the TVE, compliance test(s) are performed, recommended by C37.118

1. Steady-state compliance
  - 1.1 Steady-state synchrophasor measurement requirements
  - 1.2 Steady-state frequency and ROCOF measurement requirements
2. Dynamic compliance
  - 2.1 Synchrophasor measurement bandwidth requirements using modulated test signals
  - 2.2 Ramp of system frequency
  - 2.3 Step changes in phase and magnitude

## Literature Survey

---

# Literature Survey

Basically there are 3 components to any arrangement

- Device Generating Test Signal
- PMU under test
- Recording device (PDC etc.)

We will See 3 paper here, which are closest to our implementation


# Dynamic PMU Compliance Test under C37.118.1a-2014<sup>1</sup>

- Doble F6150 Power System Simulator
- Three Different PMUs
- Direct PMU - PSS interfacing
- Test Performed [6] :
  - Amplitude Modulation: 0.9 - 1.1 PU ( 0.1 to 5 Hz)
  - Phase Modulation: 0.1 rad
  - Ampli. Step Test:  $\pm 0.1$  PU step
  - Phase Step Test:
  - Freq. Ramp:  $\pm 1$  Hz/s between (44 to 55 Hz)
- IMP: Test signals are **not** time synchronised.

---

<sup>1</sup>R. Ghiga, Q. Wu, K. Martin, W. Z. El-Khatib Dynamic PMU Compliance Test under C37.118.1aTM-2014

- RTDS
- Multiple Relays/PMU
- Power Amplifier stages



<sup>2</sup> Saugata S. Biswas, Jeong Hun Kim, Anurag K Srivastava Development of a Smart Grid Test Bed and Applications in PMU and PDC Testing

- Test signals are GPS synchronised
- Multiple Devices acting as PMU - Multi-vendor relays
- Results validated by PMU Tester

---

<sup>3</sup>Saugata S. Biswas, Jeong Hun Kim, Anurag K Srivastava Development of a Smart Grid Test Bed and Applications in PMU and PDC Testing

- Doble F6150 Power System Simulator
- TESLA 4000 PMU
- Direct PMU-RTDS interfacing
- Testing Steps:
  - PSCAD/EMTDC generates precise current and voltage signals
  - Power System Sim. plays it in realtime
  - Test signals are time Synchronised
  - The M class operating range is considered as P class is subset of M.

---

<sup>4</sup> Krish Narendra, Dinesh Rangana Gurusinghe, *Dynamic Performance Evaluation and Testing of Phasor Measurement Unit (PMU) as per IEEE C37.118.1 Standard*


## Implementation

---

# Test Setup



Full Spectrum Simulator



# References

-  C37.118 - IEEE Standard for Synchrophasor Measurements for Power Systems
-  <http://westernau.com/images/Circle-To-Sine-Wave.png>
-  Phadke, A.G., Thorp, J.S., *Synchronized Phasor Measurements and Their Applications*, Springer US, 2008.
-  iPDC & PMU simulator, ipdc.codeplex.com/
-  Phadake A.G., *HISTORY AND APPLICATIONS OF PHASOR MEASUREMENTS*, IEEE, 2006.
-  R. Ghiga, Q. Wu, K. Martin, W. Z. El-Khatib, L. Cheng and A. H. Nielsen "Dynamic PMU Compliance Test under C37.118.1aTM-2014", *IEEE PES GM*, PAge 1-5, 2015
-  Saugata S. Biswas, Jeong Hun Kim, Anurag K Srivastava "Development of a Smart Grid Test Bed and Applications in PMU and PDC Testing", *IEEE Conference Publications*, 2012.

Thank You