SYNTHETIC station report

The SYNTHETIC water board inspected the northern stations in spring and logged the flow at station 4 as 1,250 litres per minute on each visit.[121] Crews replaced two worn seals on the dosing line and recorded the torque on each flange bolt, as the plan requires for the outlet manifold.[122] No leaks were found at the outlet manifold, and the gauges were calibrated in March. The readings are kept by the district office for ten years.

[121] Flow read on the SYNTHETIC meter at the outlet.
[122] Seals bought under the 2026 framework.