SYNTHETIC station report

Positioned summary: the SYNTHETIC board.
The flow at station 4 was 1,250 litres per minute.[1]
The gauges were calibrated in March and the crews replaced two worn seals on the dosing line.[2]
No leaks were found.

[1] Measured at the outlet.
[2] Seals from the SYNTHETIC store.