



TEST CERTIFICATE

CEM II A-L 42.5 N

WEEK NO: 16

Year

2025

DATE OF REPORTING: 20/May/2025

Average of dispatched cement From 14/Apr/2025

To 20/Apr/2025

The sample was prepared and tested in accordance with the requirements of the Tanzanian Bureau of Standards

TZS 727-1/EAS18-1 Equivalent to EN 197-1

1. Chemical Test

Properties	Unit	Test Result	Specified Requirement TZS 727-1/EAS 18-1
Loss on ignition (LOI)	% (m/m)	6.59	No requirement
Insoluble residue (IR)	% (m/m)	3.20	5.0 max
Sulfate (SO_3)	% (m/m)	2.20	4.0 max
Silicon dioxide (SiO_2)	% (m/m)	18.72	No requirement
Aluminium Oxide (Al_2O_3)	% (m/m)	6.05	No requirement
Ferric Oxide (Fe_2O_3)	% (m/m)	3.36	No requirement
Calcium Oxide (CaO)	% (m/m)	60.45	No requirement
Magnesium Oxide (MgO)	% (m/m)	1.57	5.0 max
Potassium Oxide (K_2O)	% (m/m)	0.20	No requirement
Sodium Oxide (Na_2O)	% (m/m)	0.32	No requirement
Total Alkali as Na_2O	% (m/m)	0.45	0.60 max
Chlorides (Cl)	% (m/m)	0.004	0.10 max

2. Physical Test

Fineness	M^2/Kg	412	No requirement
Soundness	mm	1.36	10 max
Initial setting time	min	156	60 min
Final setting time	min	219	No requirement

Compressive Strength

2 Days	MPa	20.59	≥ 10
7 Days	MPa	30.26	
28 Days	MPa	50.51	$\geq 42.5 - \leq 62.5$

Remarks:

QUALITY HEAD



PRODUCTION HEAD

Head Office: First Floor, ATC House, Plot 773/40 Ohio/Garden Street, Garden Avenue,
PO Box 40707, Dar Es Salaam, Tanzania, Tel: +255222139610, Fax: +255222134198
Factory Address: Kimbiji, District-Ter Kigamboni, Tanzania