

**TANZANIA BUREAU OF STANDARDS**

P O Box 9524, Dar es Salaam

Tel: +255222450206/+255222450949/+255222450298

Fax: +255222450959

E-mail: info@tbs.go.tz - Physical Address: Junction Morogoro/Sam Nujoma Rds, UbungoDATE
2025-04-17**TH 08**
TBS Code No.
QCA/EZ 16086

Page 1 of 2

Member of the International Organization for Standardization (ISO), Codex Alimentarius Commission (WHO/FAO), Agent for ISO and other National Standards Bodies

TEST REPORT
BCL/06922/2025

This report is issued in accordance with Section 4 (1) (c) of the Standards Act No. 2 of 2009. The report shall not be published, other than in full, without prior written approval of the Director General, TBS.

**“A SADCAS ACCREDITED TESTING LABORATORY”****TEST-3 0003**

Client:	LAKE CEMENT LIMITED
Client address:	PLOT NO. 265, KIMBIJI KIGAMBONI PO BOX- 40707, DAR ES SALAAM, DAR-ES-SALAAM
Sample:	1 BAG @ 50 KG OF COMMON CEMENT (NYATI CEM II B-M 42.5 N)
Site and position sampled:	PRODUCTION LINE
Sampling plan:	RANDOM
Date of sampling:	2025-02-22
Date received:	2025-03-03
Date started:	2025-03-12
Date finished:	2025-04-17
Specification:	TZS 727 (PART 1): 2018 (2ND ED)
Test method:	AS INDICATED IN THE TABLE OF RESULTS ACCORDING TO THE STANDARD
BL Number:	

1.0 INTRODUCTION

A sample of 1 Bag @ 50 kg of common cement (**NYATI CEM II B-M 42.5 N**) was submitted to TBS Building and Construction Laboratory for testing whether it conforms to **TZS 727:2018**. The sample was given TBS Code No. **QCA- EZ 16086**.

**TANZANIA BUREAU OF STANDARDS**

P O Box 9524, Dar es Salaam

Tel: +255222450206/+255222450949/+255222450298

Fax: +255222450959

E-mail: info@tbs.go.tz Physical Address: Junction Morogoro/Sam Nujoma Rds, Ubungo

DATE

2025-04-17

TH 08

TBS Code No.

QCA/EZ 16086

Page 2 of 2

Member of the International Organization for Standardization (ISO), Codex Alimentarius Commission (WHO/FAO), Agent for ISO and other National Standards Bodies

TEST REPORT
BCL/06922/2025**2.0 TEST RESULTS**

The sample was analyzed as per specified method and the given results pertain only to the sample submitted to the TBS BUILDING AND CONSTRUCTION LABORATORY for testing.

TABLE: Results of Cement

S/N	Test/Characteristic	Test Method	Requirements	Results and uncertainty	Pass/Fail
1	*Standard consistence, %	EN 196-3	-	28.7 ± 1.7	-
2	*Initial setting time, Minutes	EN 196-3	60 (Minimum)	169 ± 15	Pass
3	*Soundness (Expansion), mm	EN 196-3	10 (Maximum)	1.0 ± 0.5	Pass
4	* Early strength (2 days), N/mm ²	EN 196-1	10 (Minimum)	17.9 ± 2.3	Pass
5	■ * Standard strength (28 days), N/mm ²	EN 196-1	Between 42.5 and 62.5	39.5 ± 5.1	Pass

- 1) The reported uncertainty is an expanded uncertainty, calculated using a coverage factor of 2 which gives a level of confidence of approximately 95%.
- 2) Results with black dot (■) indicates decision rule applied.
- 3) Results with asterisk (*) indicate accredited parameters.
- 4) DECISION RULE “pass” when results and its uncertainty range is within limits or results uncertainty range overlap the limit, “fail” when results and its uncertainty range is outside the limits.

3.0 MARKING AS PER TZS 727:2018

The manufacturer's name, address (factory physical address) and/or trademark

-Marked

Standard designation of cement

-Marked

Net weight

-Marked

Date of packing and /or batch number

-Marked

4.0 REMARK

The sample conforms to **TZS 727:2018** “Composition, specification and conformity criteria for common cement specification” for the tested parameters. The test of this sample was destructive.

Reported by:**Eng. Heriel Msangi**

Analyst

Verified by:**Eng. Hussein Mnjonjo**

Technical Signatory

Approved by:**Eng. Mahona William**

Head of Laboratory