## 1 Introduction

Optimal power flow (OPF) methods are employed to optimally coordinate grid's controllable resources for different system-level objectives, such as economic operations, reliability, and resilience. The significance of OPF studies is growing in relevance at the distribution system level, driven by the increasing adoption of distributed energy resources (DERs), particularly photovoltaic systems (PVs) and battery energy storage systems (BESS). Furthermore, the adoption of BESS is gaining significance for managing the variability of DERs through controlled charging and discharging, thereby ensuring supply-demand balance [?]. Incorporating BESS into OPF problems substantially raises the complexity of network optimization problems, transitioning from a single-period, time-decoupled OPF to a multi-period, time-coupled OPF.

Traditionally, centralized OPF (COPF) methods have been widely used, where a central controller processes aggregated grid-edge data, executes the OPF algorithm, and sends control signals to manage resources [?]. The COPF algorithms for DER management are generally developed as a mixed integer non-convex programming (MINCP) problem and then simplified either as a convex problem by adopting second-order cone programming (SOCP) relaxations [?] [?], or as a linear problem by adopting Taylor series expansion [?], polyhedral approximations [?] or linear power flow models [?]. Unfortunately, COPF methods pose scalability challenges for larger networks and for difficult classes of OPF problems such multi-period time-coupled formulations required to optimally manage BESS.

To address scalability challenges, distributed OPF (DOPF) algorithms have been introduced. These algorithms decompose the COPF problem into smaller sub-problems that are solved concurrently, leveraging communication among neighboring areas. In this context, the Auxiliary Problem Principle (APP) and the Alternating Direction Method of Multipliers (ADMM) are widely adopted algorithms for solving various OPF problems, including non-convex formulations [?], convex-relaxed versions [?,?,?], and linear approximations [?]. Similarly, in a prior study [?], the authors' research group introduced a DOPF framework utilizing the Equivalent Network Approximation method (ENApp). This approach was shown to require fewer macro iterations compared to traditional ADMM or APP algorithms for solving DOPF problems.

The above references [?]- [?] mainly focused on solving single time-period OPF problems and did not include the coordination of grid-edge devices that introduce time-coupled constraints, such as BESS. The inclusion of BESS models results in a multi-period OPF (MPOPF) problem with time-coupled constraints. Reference [?] proposed a nonlinear multi-period centralized OPF (MPCOPF) approach to optimally coordinate active-reactive power dispatch from batteries and DERs in distribution systems. Alizadeh and Capitanescu [?] proposed a stochastic security-constrained MPCOPF, which sequentially solves a specific number of linear approximations of the original problem. Usman and Capitanescu [?] developed three different MPCOPF frameworks. All three approaches begin by solving a linear program to optimize the binary variables

first, followed by either a linear or non-linear program to optimize the continuous variables. Optimal battery schedules are determined in [?] considering uncertain renewable power generation by solving an MPCOPF. A bi-level robust MPCOPF is suggested in [?] for determining active and reactive power dispatches from the grid edge devices. Wu et al. [?] framed a Benders Decomposition (BD) based multi-period distributed OPF (MPDOPF) after decomposing the original centralized multi-parametric quadratic problem into one master and multiple sub-problems.

Over recent years, numerous research efforts have focused on developing MPOPF methodologies. However, the following research gaps persist.

- 1. The MPOPF models are mainly solved centrally [?]- [?]. The centralized methods suffer from scalability and computational challenges, requiring significantly long solution times, rendering them unsuitable for operational decision-making.
- 2. Reference [?] proposed a MPDOPF framework using Benders Decomposition. However, this approach suffers from slow convergence and needs a central controller to solve the master problem.

This article aims to address the above research gaps by developing a spatially distributed MPOPF (MPDOPF) framework. The distribution system is divided into multiple connected areas, each solving its own local MPOPF problem and periodically communicating the values of boundary variables with neighboring areas. The interaction between the areas is modeled by following the principles of the ENApp DOPF algorithm. ENApp outperforms the other DOPF algorithms in terms of convergence speed and requires fewer macro iterations [?]. A taxonomy table to compare the existing studies and the present work is provided in Table 1. The specific contributions of this paper are listed below:

- A MPOPF framework is proposed for distribution systems consisting of DERs and batteries. The integer variables related to battery charging/discharging are avoided by adding a "Battery Loss" cost term in the objective function. The loss term will ensure the non-occurrence of simultaneous charging/discharging operations.
- The original MPOPF framework is solved in a distributed manner by following the principles of the ENApp-based distributed OPF. This provides faster convergence and requires less solution time compared to the traditional MPCOPF.
- 3. Detailed comparative analyses between traditional MPCOPF and the proposed MPDOPF are done using the IEEE 123 bus test system and the benefits of the proposed approach are demonstrated. ACOPF feasibility validation is also performed by implementing the derived controls into an OpenDSS model of the test system.

Table 1: TAXONOMY TABLE FOR COMPARISON

Beferences [?] [?] [?] [?] [?]	< < DERs	Batteries	<   <   <   <   <   Single period OPF	Multi-period OPF	< < Centralized OPF	< <	Convex Linear Linear Convex (APP) Convex
[?]	<b>√</b>		<b>✓</b>			<b>✓</b>	(ADMM) Linear
[?]	<b>V</b>		1			1	(ADMM) Non-convex
	·		ļ			Ţ	(ENApp)
[?]	$ $ $\checkmark$ $ $			<b>√</b>	$  \checkmark  $		Non-convex
[?,?,?, ?]	<b>√</b>			<b>√</b>			Linear/convex
[?]	<b>√</b>	<b>√</b>		<b>√</b>		<b>√</b>	Quadratic (BD)
This	<b>√</b>	<b>√</b>		<b>√</b>		<b>√</b>	Non-convex
paper							(ENApp)