

Name: Yang Zheng

11478827


EE523 Final Exam

5/6/2009 9.30 am to 11.30 pm

(Closed book and closed notes)

Answer as much as you can. Best 4 scores out of the 5 problems will be counted.

1) Consider the power system below.



Generator parameters are: $H = 5$ sec., $x_d' = 0.25$, $K_D = 5$ pu, and $R_a = 0$. We want to study a fault that occurs close to the generator terminal on the lower transmission line.


a) Assuming classical models, write the dynamic equations for the pre-fault, fault-on and post-fault systems. (15 points)

b) Find the pre-fault equilibrium point and solve for the eigenvalues. (Show that the state derivatives are zero at your equilibrium solution.) (10 points)

$$a) \quad P_G^{pre} = \frac{E_2' \cdot 1}{x_d' + x_1 + x_2} \sin \theta = \frac{1.05 \times 1 \sin \theta}{0.25 + 0.25} = 2.1 \sin \theta$$

$$P_G^{post} = \frac{E_2' \cdot 1}{x_d' + x_1} \sin \theta = \frac{1.05 \times 1 \sin \theta}{0.25 + 0.5} = 1.4 \sin \theta$$

Since the fault is close to bus 2, assume:



$$x_{th} = x_1 + x_2 = 0.25, \quad V_{th} = \frac{jx_2}{jx_2 + jx_1} 1 \angle 0^\circ = \frac{0.5 \cdot 1 \angle 0^\circ}{0.5 + 0.5} = 0.5 \angle 0^\circ$$

$$P_G^{fault} = \frac{V_{th} E_2'}{x_d' + x_{th}} \sin \theta = \frac{0.5 \times 1.05 \sin \theta}{0.25 + 0.25} = 1.05 \sin \theta$$

$$\frac{65}{1.5}$$

Mansour

Type 3 model states: $x = \begin{bmatrix} \theta_2 \\ \omega_2 \end{bmatrix}$

Dynamic equations:
$$\begin{bmatrix} \dot{\theta}_2 \\ \dot{\omega}_2 \end{bmatrix} = \begin{bmatrix} (\omega_2 - 1)\omega_2 \\ \frac{1}{2H} (P_{m2} - P_{e2} - k_D(\omega_2 - 1)) \end{bmatrix} = \begin{bmatrix} (\omega_2 - 1) \cdot 377 \\ 0.1 (P_{m2} - P_{e2} - 5(\omega_2 - 1)) \end{bmatrix}$$

$$P_{m2} = P_{G2}^{pt} = \frac{E_2' E_1' \sin \theta_2}{x_d' + x_{s1}} = \frac{1.05 \times \sin(0.2)}{0.25 + 0.15} = 0.417$$

$$P_{e2} = \begin{cases} P_{G2}^{pre} = 2.1 \sin \theta_2 & \text{for pre-fault} \\ P_{G2}^{fault} = 1.05 \sin \theta_2 & \text{for fault-on} \\ P_{G2}^{post} = 1.45 \sin \theta_2 & \text{for post-fault} \end{cases}$$

Find equilibrium point from power flow

$$\begin{cases} \theta_2 = \gamma_2 = 0.2 \\ \omega_2 = 1 \end{cases}$$


plug in to
$$\begin{cases} \dot{\theta}_2 = (\omega_2 - 1) \cdot 377 = 0 \\ \dot{\omega}_2 = 0.1 (0.417 - 2.1 \sin 0.2 - 5(1 - 1)) = -2 \times 10^{-5} \approx 0 \end{cases}$$

So states derivatives are zero at eq point

$$J = \begin{bmatrix} 0 & \omega_2 \\ -0.1 \times 2.1 \cos \theta_2 & -0.5 \end{bmatrix} \bigg|_{\substack{\theta_2=0.2 \\ \omega_2=1}} = \begin{bmatrix} 0 & 377 \\ 0.21 & -0.5 \end{bmatrix}$$

$$\lambda I - J = \begin{bmatrix} \lambda & -377 \\ 0.21 & \lambda + 0.5 \end{bmatrix} = 0, \quad \begin{cases} \lambda^2 + 0.5\lambda + 79.17 = 0 \\ \lambda(\lambda + 0.5) - (-377)(0.21) = 0 \end{cases}, \quad \lambda_{1,2} = -0.25 \pm j8.89$$

The system is small-signal stable for pre-fault eq point



- 2) Consider the power system in Problem 1. Suppose we want to study a fault in the middle of one of the two transmission lines.

$$t_c = 0$$

- a) Assuming instantaneous clearing, apply equal area criterion and determine whether the system is transient stable or unstable for this contingency.

(10 points)

- b) Suppose the clearing time is 3 cycles. Again check transient stability using the equal area criterion.

(15 points)

1) $t_c = 0$, no fault-on

$$P_G^{pre} = 2.1 \sin \theta$$


$$P_G^{post} = 1.4 \sin \theta$$

$$P_m = 0.417$$

$$2.1 \sin \theta = 0.417, \quad \theta_s^{pre} = 0.20$$

$$1.4 \sin \theta = 0.417, \quad \theta_s^{post} = 0.30$$

$$\theta_u^{post} = \pi - 0.3 = 2.84$$



$$Area_{ac} = \int_{\theta_s^{pre}}^{\theta_s^{post}} (P_m - P_G^{post}) d\theta = \int_{0.2}^{0.3} (0.417 - 1.4 \sin \theta) d\theta = [0.417 \theta + 1.4 \cos \theta]_{\theta=0.2}^{0.3}$$

$$= 0.417 \times 0.1 + 1.4 (\cos 0.3 - \cos 0.2) = 0.007$$

$$Area_{dec}^{max} = \int_{\theta_s^{post}}^{\theta_u^{post}} (P_G^{post} - P_m) d\theta = \int_{0.3}^{2.84} (1.4 \sin \theta - 0.417) d\theta = [-1.4 \cos \theta - 0.417 \theta]_{\theta=0.3}^{2.84}$$

$$= -1.4 (\cos 2.84 - \cos 0.3) - 0.417 (2.84 - 0.3) = 1.615$$

$Area_{ac} < Area_{dec}^{max}$ So the system is transient stable.

Correct
All wrong
5

$$b) t_c = 3 \text{ cycles} = \frac{3}{60} = 0.05 \text{ sec}$$

$$x_{th} = x_1 // \frac{x_2}{2} = \frac{0.5 \times 0.25}{0.5 + 0.25} = \frac{1}{6} = 0.167$$

$$V_{th} = \frac{\frac{x_2}{2}}{\frac{x_2}{2} + x_1} \angle 0^\circ = \frac{0.25 \angle 0^\circ}{0.25 + 0.5} = \frac{1}{3} \angle 0^\circ = 0.333 \angle 0^\circ$$

$$p_{fault} = \frac{V_{th} E'_s}{x_d' + x_{th}} \sin \theta = \frac{0.333 \times 1.05}{0.25 + \frac{1}{6}} \sin \theta = 0.84 \sin \theta$$

$$\begin{aligned} \theta_s^{pre} &= 0.2 \\ \theta_s^{post} &= 0.3 \\ \theta_u^{post} &= 2.84 \end{aligned} \quad \begin{cases} \dot{\theta}_2 = (\omega - 1) \cdot 377 \\ \dot{\omega}_2 = 0.1 (0.417 - 0.84 \sin \theta - 5(\omega - 1)) \end{cases}$$

use step size $h = 0.01 \text{ sec}$

$$\begin{aligned} \theta(0.01) &= \theta(0) + h \dot{\theta}(0) \\ &= 0.2 + h \cdot 0 = 0.2 \end{aligned}$$

$$\begin{aligned} \omega(0.01) &= \omega(0) + h \cdot \dot{\omega}(0) \\ &= 1 + 0.01 \times 0.1 (0.417 - 0.84 \sin 0.2) \\ &= 1.00025 \end{aligned}$$

$$\begin{aligned} \theta(0.02) &= \theta(0.01) + h \dot{\theta}(0.01) \\ &= 0.2 + 0.01 \times 0.00025 \times 377 = 0.2009 \end{aligned}$$



$$\begin{aligned} \omega(0.02) &= \omega(0.01) + h \dot{\omega}(0.01) \\ &= 1.00025 + 0.01 \times 0.1 (0.417 - 0.84 \sin(0.2) - 5 \times 0.00025) = 1.0005 \end{aligned}$$

$$\begin{aligned} \theta(0.03) &= \theta(0.02) + h \dot{\theta}(0.02) \\ &= 0.2009 + 0.01 \times 0.0005 \times 377 = 0.2028 \end{aligned}$$

$$\begin{aligned} \omega(0.03) &= \omega(0.02) + h \dot{\omega}(0.02) \\ &= 1.0005 + 0.01 \times 0.1 (0.417 - 0.84 \sin(0.2009) - 5 \times 0.0005) = 1.0007 \end{aligned}$$

$$\begin{aligned} \theta(0.04) &= \theta(0.03) + h \dot{\theta}(0.03) \\ &= 0.2028 + 0.01 \times 0.0007 \times 377 = 0.2054 \end{aligned}$$

$$\begin{aligned} \omega(0.04) &= \omega(0.03) + h \dot{\omega}(0.03) \\ &= 1.0007 + 0.01 \times 0.1 (0.417 - 0.84 \sin(0.2028) - 5 \times 0.0007) = 1.0009 \end{aligned}$$



$$\theta(0.05) = \theta(0.04) + h \cdot \dot{\theta}(0.04)$$

$$= 0.2054 + 0.01 \times 0.0008 \times 377 = 0.2088$$

$$w(0.05) = w(0.04) + h \cdot \dot{\theta}(0.04)$$

$$= 1.0009 + 0.01 \times 0.1(0.417 - 0.84 \sin(0.2054) - 5 \times 0.0008) = 1.0011$$

$$Area_{ac} = \int_{\theta_{clear}}^{\theta_{cr}} (P_m - P_{G_{fault}}) d\theta$$

$$= \int_{0.2}^{0.2088} (0.417 - 0.84 \sin \theta) d\theta = \left[0.417\theta + 0.84 \cos \theta \right]_{\theta=0.2}^{0.2088}$$

$$= 0.417 \times (0.2088 - 0.2) + 0.84 \times (\cos 0.2088 - \cos 0.2) = 0.002$$


$$Area_{dec}^{max} = \int_{\theta_{clear}}^{\theta_u^{post}} (P_G^{post} - P_m) d\theta = \int_{0.2088}^{2.84} (1.4 \sin \theta - 0.417) d\theta$$

$$= \left[-1.4 \cos \theta - 0.417\theta \right]_{\theta=0.2088}^{2.84} = -1.4(\cos 2.84 - \cos 0.2088) - 0.417(2.84 - 0.2088)$$

$$= 1.609$$

$Area_{ac} < Area_{dec}^{max}$, So the system is transient stable

- 3) Consider the three-bus power system below. For the power-flow problem, bus 2 voltage is kept at 1 pu by manual switching of shunt capacitors and reactors at the bus. And, bus 3 voltage is maintained at 1.05 pu by a Static VAR Compensator (SVC). The dynamic model for SVC is shown below, and the load at bus 2 is modeled to be purely resistive.



- What shunt compensation is required at buses 2 and 3 as per the power-flow solution? (10 points)
- Derive the dynamic model for the system and simplify as much as you can. (10 points)
- Solve the initialization problem (i.e. find the equilibrium solution) (5 points)


4) Consider the two area system below.

a) Suppose there is a sudden loss of generator 3 in Area 2. Compute the governor responses before and after AGC actions.

(10 points)

b) Suppose the load in Area 1 suddenly increases by 100 MW (instead of gen drop in part a). Compute the governor responses before and after AGC actions. Assume generator 2 to be the slack bus for Area 2.

(15 points)



Gen 2 : Rating = 500 mVA, $R_2 = 5\%$
 $P_{G2} = 200 \text{ mW}$

Gen 3 : Rating = 100 mVA, $R_3 = 10\%$
 $P_{G3} = 100 \text{ mW}$

Gen 4 : Rating = 200 mVA, $R_4 = 5\%$
 $P_{G4} = 100 \text{ mW}$

a) Gen 3: $P_3 = 5\%$, Rating 3 = 50 MVA

Governor responses before AGC:

$$\Delta P_L = \frac{100}{1000 + 500 + 200} = \frac{1}{17} = 0.0588 \text{ p.u.}$$

$$\Delta \omega = R \cdot \Delta P_L = -0.05 \times 0.0588 = -0.0029 \text{ p.u.}$$

$$\Delta P_{G1} = 0.0588 \times 1000 = 58.8 \text{ MW}$$

$$\Delta P_{G2} = 0.0588 \times 500 = 29.4 \text{ MW}$$

$$\Delta P_{G3} = 0.0588 \times 200 = 11.8 \text{ MW}$$

Governor responses after AGC actions.

$$\Delta P_{net1} = P_{net1}^{\text{actual}} - P_{net1}^{\text{contract}} = (-141.2) - (-200) = 58.8 \text{ MW} = 0.0588 \text{ p.u.}$$

$$ACE_1 = \Delta P_{net1} + B_1 \Delta f_1 = 0.0588 + 20 \times (-0.0029) = 0$$

$$\Delta P_{G1} = -ACE_1 = 0 \text{ MW}$$

$$\Delta P_{net2} = P_{net2}^{\text{actual}} - P_{net2}^{\text{contract}} = (141.2) - (200) = -58.8 \text{ MW} = -0.0588$$

$$ACE_2 = \Delta P_{net2} + B_2 \Delta f_2 = -0.0588 + 20 \times (-0.0029) = -0.1428 \text{ p.u.} = -100 \text{ MW}$$

$$\text{For slack bus Gen 2: } \Delta P_{G2} = -ACE_2 = 100 \text{ MW}$$

$$P_{L2} = 200 \text{ MW}$$

b) Rating 1 = 1000 MVA

$$P_{G1} = 500 \text{ MW}$$

$$P_{L1} = 700 \text{ MW}$$

↓
increase 100 MW

$$\left\{ \begin{array}{l} \text{Rating 2} = 500 \text{ MVA} \\ P_{G2} = 200 \text{ MW} \end{array} \right.$$

$$P_{G2} = 200 \text{ MW}$$

$$\left\{ \begin{array}{l} \text{Rating 3} = 50 \text{ MVA} \\ P_{G3} = 100 \text{ MW} \end{array} \right.$$

$$P_{G3} = 100 \text{ MW}$$

$$\left\{ \begin{array}{l} \text{Rating 4} = 200 \text{ MVA} \\ P_{G4} = 100 \text{ MW} \end{array} \right.$$

$$P_{G4} = 100 \text{ MW}$$

Governor responses before AGC:

$$\Delta P_L = \frac{100}{1000 + 500 + 50 + 200} = \frac{2}{35} = 0.057 \text{ p.u.}$$

$$\Delta W = R \Delta P_L = 0.05 \times \frac{2}{35} = \frac{1}{350} = 0.0028 \text{ p.u.}$$

$$\Delta P_{G1} = 0.057 \times 1000 = 57 \text{ MW}$$

$$\Delta P_{G2} = 0.057 \times 500 = 28.6 \text{ MW}$$

$$\Delta P_{G3} = 0.057 \times 50 = 2.8 \text{ MW}$$

$$\Delta P_{G4} = 0.057 \times 200 = 11.4 \text{ MW}$$

Governor responses after AGC:

$$\Delta P_{Net1} = (-243) - (-200) = -43 \text{ MW} = -0.043 \text{ p.u.}$$

$$ACZ_1 = \Delta P_{Net1} + B_1 \Delta f_1 = -0.043 + 20 \times (-0.0028) = -0.1 \text{ p.u.} = -100 \text{ MW}$$

$$\Delta P_{G1} = -ACZ_1 = 100 \text{ MW}$$

$$\Delta P_{Net2} = (243) - (200) = 43 \text{ MW} = 0.003 \text{ p.u.}$$

$$ACZ_2 = \Delta P_{Net2} + B_2 \Delta f_2 = 0.003 + 20 \times (-0.0028) = 0.$$

$$\Delta P_{G2} = -ACZ_2 = 0$$

2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100






- 5) Suppose the static and dynamic loads are represented by the following models.
Find all the values marked by question marks in the load test responses below.
(25 points)

$$P_L = P_L^S + P_L^D$$

$$Q_L = Q_L^S + Q_L^D$$

$$P_L^S = 0.2V + 0.2V^2$$

$$Q_L^S = 0.1V$$



$$P_L(0) = ? \quad P_L(5+) = ? \quad P_L(10) = ? \quad P_L(20-) = ?$$

$$P_L(20+) = ? \quad P_L(25) = ? \quad P_L(35) = ?$$

$$Q_L(0) = ? \quad Q_L(5+) = ? \quad Q_L(10) = ? \quad Q_L(20-) = ?$$

$$Q_L(20+) = ? \quad Q_L(25) = ? \quad Q_L(35) = ?$$

$$f) P_L = P_{LS} + P_{LP} = 0.2V + 0.2V^2 + \frac{0.125}{S+0.25} V, \quad \frac{0.125V}{S+0.25} = \frac{0.5V}{1+4S}, T_P = 4$$

$$Q_L = Q_{LS} + Q_{LP} = 0.1V + \frac{0.1}{S+0.5} V, \quad \frac{0.1V}{S+0.5} = \frac{0.2V}{1+2S}, T_I = 2$$

steady state, $S=0$,

$$t=5-, V=1, P_L = 0.2 \times 1 + 0.2 + \frac{0.125 \times 1}{0.25} = 0.9$$

$$Q_L = 0.1 + \frac{0.1}{0.5} = 0.3$$

$$t=5+, V=0.9, P_L = 0.2 \times 0.9 + 0.2 \times 0.9^2 + \frac{0.125}{0.25} \times 1 = 0.842$$

$$Q_L = 0.1 \times 0.9 + \frac{0.1}{0.5} \times 1 = 0.29$$

$$t=20-, V=0.9, P_L = 0.2 \times 0.9 + 0.2 \times 0.9^2 + \frac{0.125}{0.25} \times 0.9 = 0.792$$

$$Q_L = 0.1 \times 0.9 + \frac{0.1}{0.5} \times 0.9 = 0.27$$

$$t=20+, V=1.1, P_L = 0.2 \times 1.1 + 0.2 \times 1.1^2 + \frac{0.125}{0.25} \times 0.9 = 0.912$$

$$Q_L = 0.1 \times 1.1 + \frac{0.1}{0.5} \times 0.9 = 0.29$$

$$t=35, V=1.1, P_L = 0.2 \times 1.1 + 0.2 \times 1.1^2 + \frac{0.125}{0.25} \times 1.1 = 1.012$$

$$Q_L = 0.1 \times 1.1 + \frac{0.1}{0.5} \times 1.1 = 0.33$$

Continued at next page

$$\mathcal{L}^{-1}\left[\frac{0.125}{s+0.25}\right] = 0.125 \times e^{-0.25t}$$

$$t=10, \Delta t=10-5=5, \Delta P_{L0} = 0.125 \times e^{-0.25 \times 5} = 0.036, P_L(10) = 0.842 - 0.036 = 0.806$$

$$t=25, \Delta t=25-20=5, \Delta P_{L0} = 0.125 \times e^{-0.25 \times 5} = 0.036, P_L(25) = 0.912 + 0.036 = 0.948$$

0.948 ✓
2

$$\mathcal{L}^{-1}\left[\frac{0.1}{s+0.5}\right] = 0.1 e^{-0.5t}$$

$$t=10, \Delta t=10-5, \Delta \theta_{L0} = 0.1 \times e^{-0.5 \times 5} = 0.008, \theta_L(10) = 0.29 - 0.008 = 0.282$$


$$t=25, \Delta t=25-20=5, \Delta \theta_{L0} = 0.1 \times e^{-0.5 \times 5} = 0.008, \theta_L(25) = 0.29 + 0.008 = 0.298$$

0.298 ✓
2

0.298 ✓
2

(Bonus) Prove equal area criterion.

(5 points)



The swing equation $\frac{T_J}{\omega_0} \cdot \frac{d\dot{\theta}^2}{dt^2} = P_m - P_e$ ①

$\frac{d\dot{\theta}^2}{dt^2} = \frac{d}{dt} \left(\frac{d\theta}{dt} \right) = \frac{d\dot{\theta}}{dt} = \frac{d\theta}{dt} \frac{d\dot{\theta}}{d\theta} = \dot{\theta} \frac{d\dot{\theta}}{d\theta}$ plug in ①

$\frac{T_J}{\omega_0} \dot{\theta} \frac{d\dot{\theta}}{d\theta} = P_e - P_m$, $\frac{T_J}{\omega_0} \dot{\theta} d\dot{\theta} = (P_e - P_m) d\theta$

$\int_{\dot{\theta}_s^{pre}}^{\dot{\theta}_c} \frac{T_J}{\omega_0} \dot{\theta} d\dot{\theta} = \int_{\theta_s^{pre}}^{\theta_c} (P_m - P_e) d\theta$

$\frac{1}{2} \frac{T_J}{\omega_0} (\dot{\theta}_c^2 - \dot{\theta}_s^{pre,2}) = \frac{1}{2} \frac{T_J}{\omega_0} \dot{\theta}_c^2 = \int_{\theta_s^{pre}}^{\theta_c} (P_m - P_e^{fault}) d\theta$

Left side = increase of kinetic energy

Right side = the work excess torque does w.r.t. θ , = area abce

Similarly, we have $\frac{1}{2} \frac{T_J}{\omega_0} (\dot{\theta}_f^2 - \dot{\theta}_c^2) = \frac{1}{2} \frac{T_J}{\omega_0} \dot{\theta}_f^2 = \int_{\theta_c}^{\theta_f} (P_e^{post} - P_m) d\theta$

Decrease of kinetic energy = brake torque = area of defg.

So if θ go beyond the limit θ_u^{post} , $P_m > P_e$, $\omega \uparrow \Rightarrow \omega > 1$, $\theta \uparrow$

θ will keep increasing. and the system will be transient unstable