

Khazzan Central Processing Facility Sales Gas Metering System DAILY REPORT



LOCATION: Khazzan

DUTY FC TAG: FAC1-FQY-341201A

REPORT DATE/TIME 28/Dec/2023 10:03:01

CURRENT PROCESS DATA

Name Meter Tag		Meter Run A FAC1-FT-3412540	Meter Run B FAC1-FT-3412541	<u>Station</u>		
Stream Status		Online	Offline			
Meter K Factor	pls/CF	14.2	14.2			
Meter Factor	p13/01	1	1			
Meter Pressure	kPa.g	9847.7	9745.8	9847.7		
Meter Pressure	psig	1428.3	1413.5	1427.7		
Meter Temperature	Deg.C	50.54	25.55	50.5		
Meter Density	kg/m3	79.038	90.573	79.038		
Standard Density at 15°C	kg/Sm3	0.783	0.783	0.783		
VCF	ng/eme	1.00365	1.00272	0.700		
GHV	BTU/SCF	1073	1073	1073		
BTEX-Benzene	ppm	1010	1010	46.902		
BTEX-Toluene	ppm			1.854		
BTEX-Xylene	ppm			0.087		
BTEX	ppm			48.843		
Moisture	ppm			-92.142		
H2S	ppm			0.458		
Dew Point	Deg.C			-19.78		
Oxygen	ppm			-0.077		
Inert Gas	%			1.455		
CURRENT FLOW RATES Gross Vol Flow	MMCFD	3.371	0	3.371		
Mass Flow	t/h	314.392	0	314.392		
Std Vol Flow	MMSCFD	340.352	0	340.352		
Energy Flow	MMBTU/d	365196.776	0	365196.776		
Lifelgy 1 low	WIWID T O/G	000100.770	v	000100.770		
PREVIOUS DAY AVERAGE DATA						
Meter Pressure	kPa.g	9800.7	0	9800.7		
Meter Temperature	Deg.C	50.83	0	50.83		
Meter Density	kg/m3	78.515	0	78.515		
Standard Density at 15°C	kg/Sm3	0.783	0	0.783		
GHV	BTU/SCF	1073.1	0	1073.1		
Inert Gas	%			1.442		
Moisture	ppm			-90.851		
Dew Point	Deg.C			-20.53		
H2S	ppm			0.89		
BTEX	ppm			47.108		
O2	ppm			-0.079		



Khazzan Central Processing Facility Sales Gas Metering System DAILY REPORT



LOCATION: Khazzan

DUTY FC TAG: FAC1-FQY-341201A

REPORT DATE/TIME 28/Dec/2023 10:03:01

PREVIOUS DAY AVERAGE C	<u>OMPONENTS</u>							
Methane - C1	%			88.228				
Ethane - C2	%			5.114				
Propane - C3	%			1.95				
iButane - iC4	%			0.47				
nButane - nC4	%			0.43				
iPentane - iC5	%			0.1				
nPentane - nC5	%			0.07				
Hexane - C6	%			0.03				
Heptane - C7	%			0				
Octane - C8	%			0				
Nonane - C9	%			0				
Decane - C10	%			0				
Nitrogen - N2	%			2.164				
Carbon Dioxide - CO2	%			1.442				
PREVIOUS DAY FISCAL TOTALS - FAC1-FT-341201A								
Gross Vol	MMCF	3.51	0	3.51				
Mass	t	7802.45	0	7802.45				
Std Vol	MMSCF	351.95	0	351.95				
Energy	MMBTU	377672.3	0	377672.3				
PREVIOUS DAY FISCAL TOT								
Gross Vol	MMCF	3.51	0	3.51				
Mass	t	7801.55	0	7801.55				
Std Vol	MMSCF	351.92	0	351.92				
Energy	MMBTU	377628.9	0	377628.9				
PREVIOUS DAY FAULT TOTALS - FAC1-FC-341201A								
Gross Vol Mass	MMCF t	0 0	0 0	0 0				
Std Vol	MMSCF	0	0	0				
Energy	MMBTU	0	0	0				
<u> </u>								
PREVIOUS DAY FAULT TOTALS - FAC1-FC-341201B								
Gross Vol	MMCF	0	0	0				
Mass	t	0	0	0				
Std Vol	MMSCF	0	0	0				
Energy	MMBTU	0	0	0				
<u> </u>								