
Ref: FLT-1024
Date: 2026-09-14
Plant: A
Severity: High
Raised by: Dexter Norley
Stage: Reported

Description

All coolers high temperature.

Action taken / recommendation

Called in to site to reset high pressure faults on A pack. Pack now pulling down temperatures.