

Ref: FLT-1006
Date: 2026-08-25
Plant: A
Severity: High
Raised by: Dexter Norley
Stage: Reported

Description

A plant struggling with high discharge pressure when ambient is 27°C and head pressure with 1 compressor running 100% is 20bar.

Comps 2 and 3 won't reset at current conditions.

Action taken / recommendation

Recommend replacing condenser as the fins are rooting away reducing its surface area.

Photo 1

