

Ref: FLT-1010
Date: 2026-08-25
Plant: C4
Severity: Medium
Raised by: Dexter Norley
Stage: Reported

Description

Drain leaking water, recently installed drain line heater is pulling amps see attached picture.

Action taken / recommendation

Replace all drain with a greater fall and try to remove from D chamber.

Photo 1

