

Ref: WK-MT172I7F
 Date: 2026-08-20
 Engineer: Dexter Norley
 Plant: A & B, C & D, E
 Week: 34
 Ambient °C: 16.9
 Issues flagged: 0

A & B — Chamber temperature

Item	A1	A2	A3	A4	No1 B2	No2 B2	No3 B1	No4 B1
Cold store set point (controller)	-20	-20	-20	-20	-18.9	-18	-18.9	-18.2
Cold store temp air-on	-19.4	-20.9	-20.4	-20.3	-17.5	-17.5	-17.7	-16.3
Coolers air off	-22.2	-22.9	-23.7	-23.2	-19.7	-18.8	-18.6	-17.9
Cooling on/off	On	On	On	On	On	On	On	On

A & B — Coolers

Item	A1	A2	A3	A4	No1 B2	No2 B2	No3 B1	No4 B1
Cooler fan correct operation	OK	OK	OK	OK	OK	OK	OK	OK
Cooler correct operation	OK	OK	OK	OK	OK	OK	OK	OK
Cooler correct defrosting cycle	OK	OK	OK	OK	OK	OK	OK	OK
Cooler ice build-up & debris	OK	OK	OK	OK	OK	OK	OK	OK
Defrost drain line for leakage	OK	OK	OK	OK	OK	OK	OK	OK
Operating suction superheat #	5	6.2	8.3	4.6	6.9	7.5	7.7	7
% opening of expansion valve #	15	19	62	30	44	37	21	12
Cooler air temp diff #	0.8	2	3.3	2.8	2.2	1.3	0.9	1.6

A & B — Compressor racks & condenser

Item	A	B
Compr abnormal noise / vibration	OK	OK
Oil cooler fin face free of debris	OK	OK
Oil cooler fans correct operation	OK	OK
Plant-room ventilation fan (on/off)	On	On
Plant-room temperature	32.1	32.1
Ambient temperature	16.9	16.9
Wet-matt cooling on/off (hours)	On	On
System delivery pressure	13.4	12
Condenser fin face free of debris	OK	OK
Condenser fans correct operation	Yes	Yes
Liquid line sight glass	Clear	Clear
Receiver level	Above bottom sight glass	Abovebottomsightglass
Oil separator oil level	Full	Full
No1 compressor running & % load	50	75
No2 compressor running & % load	0	0
No3 compressor running & % load	100	-

The work that keeps you working.

Item	A	B
No1 compr delivery & econ temp	Not running	Not running
No2 compr delivery & econ temp	Not running	Not running
No3 compr delivery & econ temp	15	-
Refrigerant leak detection system	OK	OK

A & B — Controls

Item	A	B
Suction pressure	0.7	0.5
Suction temperature	-16.8	-18.6
Suction SH	12	12
Delivery pressure	14.2	12.6
Common delivery temp	73.4	69.1
Oil temperature	48.4	46.3
HP liquid temperature	27	29
HP liquid sub-cooling	8	2
Econ liquid temperature	7	23
Econ sub-cooling	28	8

A & B — Main incoming meter

Item	kWhr
Electric kWhr meter reading	663175
Previous meter reading	654435

A & B — A — pack meter

Item	kWhr
Electric kWhr meter reading	4567062
Previous meter reading	454745

A & B — B — pack meter

Item	kWhr
Electric kWhr meter reading	2800316
Previous meter reading	2784313

A & B — A & B cooler energy meter

Item	kWhr
Electric kWhr meter reading	2596250
Previous meter reading	2585523

C & D — Chamber temperature

Item	C1	C2	C3	C4	D1	D2
Cold store set point (controller)	-18	-18.8	-18.2	-18.2	-18.6	-18.1
Cold store temp air-on	-16.7	-17.3	-18.2	-18.1	-16.5	-16.4
Coolers air off	-17.4	-20.8	-18.2	-19.5	-19	-18.8
Cooling on/off	On	On	Off	On	On	On

C & D — Condensing units

Item	C1	C2	C3	C4	D1	D2	D3	D4
Compr abnormal noise / vibration	OK	OK	OK	OK	OK	OK	OK	OK
Compressor abnormal frosting	OK	OK	OK	OK	OK	OK	OK	OK
Compr oil level	2/3	2/3	2/3	2/3	2/3	2/3	2/3	2/3
Compr delivery temperature	78	77	78	76	70	70	69	69

Item	C1	C2	C3	C4	D1	D2	D3	D4
Oil recovery / separator level	Full	Full	Full	Full	Full	Full	Full	Full
Condenser fin face free of debris	OK	OK	OK	OK	OK	OK	OK	OK
Condenser fans abnormal noise	OK	OK	OK	OK	OK	OK	OK	OK
Liquid line sight glass	OK	OK	OK	OK	OK	OK	OK	OK
Receiver level	Bbsg	Absg	Bbsg	Absg	Bbsg	Bbsg	Bbsg	Bbsg

C & D — Coolers

Item	C1	C2	C3	C4	D1	D2
Cooler temperature diff	0.8	3.5	0	1.4	2.5	2.4
Cooler correct operation	OK	OK	OK	OK	OK	OK
Cooler correct defrosting cycle	OK	OK	OK	OK	OK	OK
Cooler ice build-up & debris	OK	OK	OK	OK	OK	OK
Defrost drain line for leakage	OK	OK	OK	OK	OK	OK

C & D — Energy readings

Item	C2-4 refig	C1-3 refig	D 1&2	D 3&4 compr
Electric kWhr meter reading	2993177	1106035	2600147	24191
Previous kWhr meter reading	2984777	1099909	2589454	24066

E — Chamber temperature

Item	E1	E2
Cold store set point (controller)	-18.6	-18
Cold store temp air-on	-14.7	-15.7
Coolers air off	-17.1	-17.9
Cooling on/off	On	On

E — E chamber front-centre temp

Item	°C
Front-centre temperature	-15.2

E — Condensing units

Item	E1 Compr1	E1 Compr2	E2 Compr1	E2 Compr2
Compr abnormal noise / vibration	OK	OK	OK	OK
Compressor abnormal frosting	OK	OK	OK	OK
Compr oil level	2/3	2/3	2/3	2/3
Compr delivery temperature	78	78	70	70
Oil recovery / separator level	Full	Full	Full	Full
Condenser fin face free of debris	OK	OK	OK	OK
Condenser fans abnormal noise	OK	OK	OK	OK
Liquid line sight glass	OK	OK	OK	OK
Receiver level	Absg	Absg	Absg	Absg

E — Coolers

Item	E1	E2
Cooler temperature diff	2.4	2.2
Cooler correct operation	OK	OK
Cooler correct defrosting cycle	OK	OK
Cooler ice build-up & debris	OK	OK
Defrost drain line for leakage	OK	OK

E — System readings

Item	E1	E2
Suction pressure	0.7	1.1
Suction temperature	-14	-12
Suction superheat	14	11
Delivery pressure	14.2	12.8
Liquid refrig temperature	26	28
Liquid sub	10	4

E — Energy readings

Item	E1	E2
Electric kWhr meter reading	13666	12521
Previous kWhr meter reading	13523	12473