

Ref: WK-MS5QA8Z6
 Date: 2026-07-29
 Engineer: Dexter Norley
 Plant: A & B, C & D, E
 Week: 31
 Ambient °C: 20
 Issues flagged: 4

A & B — Chamber temperature

Item	A1	A2	A3	A4	No1 B2	No2 B2	No3 B1	No4 B1
Cold store set point (controller)	- 20	- 20	- 20	- 20	-18.9	- 18	- 18.8	-18.2
Cold store temp air-on	- 19.5	- 20	- 20	- 20	-18.9	-18.4	-18.9	-18.6
Coolers air off	- 19.5	- 20	-21.1	- 21	- 21.4	-18.4	- 18.9	-19
Cooling on/off	Off	Off	On	On	On	Off	Off	Ou

A & B — Coolers

Item	A1	A2	A3	A4	No1 B2	No2 B2	No3 B1	No4 B1
Cooler fan correct operation	OK	OK	OK	OK	OK	OK	OK	OK
Cooler correct operation	OK	OK	OK	OK	OK	OK	OK	OK
Cooler correct defrosting cycle	OK	OK	OK	OK	OK	OK	OK	OK
Cooler ice build-up & debris	OK	OK	OK	OK	OK	OK	OK	OK
Defrost drain line for leakage	OK	OK	OK	OK	OK	OK	OK	OK
Operating suction superheat #	7.7	8	8.2	5.5	7.5	12.6	9.3	5
% opening of expansion valve #	O	O	96	46	68	O	O	22
Cooler air temp diff #	O	O	1.1	1	2.5	O	O	0.4

A & B — Compressor racks & condenser

Item	A	B
Compr abnormal noise / vibration	OK	OK
Oil cooler fin face free of debris	OK	OK
Oil cooler fans correct operation	OK	OK
Plant-room ventilation fan (on/off)	On	On
Plant-room temperature	33.7	33.7
Ambient temperature	20	20
Wet-matt cooling on/off (hours)	On	On
System delivery pressure	13	13.2
Condenser fin face free of debris	OK	OK
Condenser fans correct operation	Yes	Yes
Liquid line sight glass	Full	Full
Receiver level	Full	Empty
Oil separator oil level	Full	Full
No1 compressor running & % load	O	O
No2 compressor running & % load	75	100
No3 compressor running & % load	O	-

The work that keeps you working.

Item	A	B
No1 compr delivery & econ temp	7	-
No2 compr delivery & econ temp	5	6
No3 compr delivery & econ temp	7	-
Refrigerant leak detection system	OK	OK

A & B — Controls

Item	A	B
Suction pressure	0.9	1.1
Suction temperature	- 20	- 25
Suction SH	5	2
Delivery pressure	13.2	13.4
Common delivery temp	66.5	67.1
Oil temperature	42.3	45.3
HP liquid temperature	28	27
HP liquid sub-cooling	4	6
Econ liquid temperature	-2	18
Econ sub-cooling	30	15

A & B — Main incoming meter

Item	kWhr
Electric kWhr meter reading	644101
Previous meter reading	26 636

A & B — A — pack meter

Item	kWhr
Electric kWhr meter reading	4521886
Previous meter reading	4506208

A & B — B — pack meter

Item	kWhr
Electric kWhr meter reading	2766427
Previous meter reading	2755 106

A & B — A & B cooler energy meter

Item	kWhr
Electric kWhr meter reading	2572393
Previous meter reading	2564844

C & D — Chamber temperature

Item	C1	C2	C3	C4	D1	D2
Cold store set point (controller)	- 18	- 18.8	- 18.2	-18.2	-18.6	- 18.1
Cold store temp air-on	-17.6	- 18.8	- 18,5	-18.6	-17.2	-17.1
Coolers air off	-21	- 20.6	- 18.5	18.6-	-19.5	-18.1
Cooling on/off	On	On	Off	Off	On	On

C & D — Condensing units

Item	C1	C2	C3	C4	D1	D2	D3	D4
Compr abnormal noise / vibration	OK	OK	OK	OK	OK	OK	OK	OK
Compressor abnormal frosting	OK	OK	OK	OK	OK	OK	OK	OK
Compr oil level	2/3	2/3	2/3	2/3	2/3	2/3	2/3	2/3
Compr delivery temperature	77	68	65	63	67	67	65	65

Item	C1	C2	C3	C4	D1	D2	D3	D4
Oil recovery / separator level	OK	OK	OK	Ok	Ok	Ok	OK	Ok
Condenser fin face free of debris	OK	OK	OK	OK	OK	OK	OK	OK
Condenser fans abnormal noise	OK	OK	OK	OK	OK	OK	OK	OK
Liquid line sight glass	OK	OK	OK	OK	OK	OK	OK	OK
Receiver level	Low	Full	Low	Full	Low	Low	Low	Low

C & D — Coolers

Item	C1	C2	C3	C4	D1	D2
Cooler temperature diff	3.4	1.8	0	0	2.3	1
Cooler correct operation	OK	OK	OK	OK	OK	OK
Cooler correct defrosting cycle	OK	OK	OK	OK	OK	OK
Cooler ice build-up & debris	OK	FAULT	OK	FAULT	OK	OK
Defrost drain line for leakage	OK	FAULT	OK	FAULT	OK	OK

C & D — Energy readings

Item	C2-4 refig	C1-3 refig	D 1&2	D 3&4 compr
Electric kWhr meter reading	2976171	1091848	2576621	23931
Previous kWhr meter reading	2971777	1086661	2569178	23842

E — Chamber temperature

Item	E1	E2
Cold store set point (controller)	-18	-18
Cold store temp air-on	-17.5	-17.6
Coolers air off	-18.8	-19.1
Cooling on/off	On	On

E — E chamber front-centre temp

Item	°C
Front-centre temperature	-16.6

E — Condensing units

Item	E1 Compr1	E1 Compr2	E2 Compr1	E2 Compr2
Compr abnormal noise / vibration	OK	OK	OK	OK
Compressor abnormal frosting	OK	OK	OK	OK
Compr oil level	2/3	2/3	2/3	2/3
Compr delivery temperature	71	71	70	70
Oil recovery / separator level	Full	Full	Full	Full
Condenser fin face free of debris	OK	OK	OK	OK
Condenser fans abnormal noise	OK	OK	OK	OK
Liquid line sight glass	OK	OK	OK	OK
Receiver level	Ok	Ok	Ok	Ok

E — Coolers

Item	E1	E2
Cooler temperature diff	1.3	1.5
Cooler correct operation	OK	OK
Cooler correct defrosting cycle	OK	OK
Cooler ice build-up & debris	OK	OK
Defrost drain line for leakage	OK	OK

E — System readings

Item	E1	E2
Suction pressure	0.7	1
Suction temperature	-16	-17
Suction superheat	12	7.8
Delivery pressure	15	13.2
Liquid refrig temperature	27	26
Liquid sub	11	7

E — Energy readings

Item	E1	E2
Electric kWhr meter reading	13343	12426
Previous kWhr meter reading	13241	12393