

Date: 24/08/2026
 Period: August 2026
 Overall completion: 64%
 Regimes on track: 7 of 11
 Open faults: 4
 Delivered by: Coolstream

Maintenance regimes - completion this period

Item	Frequency	Period	Completed	Status
Weekly checks	Weekly	August 2026	100% (4/3)	On track
Quarterly - A & B	Quarterly	Q3 2026 (Jul-Sep 2026)	100% (49/49)	Complete
Quarterly - C	Quarterly	Q3 2026 (Jul-Sep 2026)	100% (42/42)	Complete
Quarterly - D & E	Quarterly	Q3 2026 (Jul-Sep 2026)	100% (42/42)	Complete
Quarterly - E	Quarterly	Q3 2026 (Jul-Sep 2026)	100% (42/42)	Complete
Condenser & oil-cooler wash	Six-monthly	Jul-Dec 2026	100% (7/7)	Complete
F-Gas leak testing	Six-monthly	Jul-Dec 2026	100% (2/2)	Complete
Safety cut-outs	Annual	Jul 2026 - Jun 2027	0% (0/26)	In progress
Temperature probes	Annual	Jul 2026 - Jun 2027	0% (0/42)	In progress
A & B leak detection	Annual	Jul 2026 - Jun 2027	0% (0/13)	In progress
Oil analysis - A&B packs	Annual	Jul 2026 - Jun 2027	0% (0/1)	In progress

Open faults

Item	Plant	Severity	Stage	Days open	Action
D2 & D4 Compressor Overhaul over due refurbish of compressor	D2	Medium	Awaiting your sign-off	67	Border
The roof top air cooled condenser heat exchange fins have corroded since the ins	A&B Plant Room	Medium	Reported	64	RED FM
Following Call out 1001 repair/works scissor Lift needed to access areas to comp	C1	High	Approved - scheduling	50	RED FM
Plant room to hot Coolstream to quote extract.	B	High	Reported	39	RED FM