

EMERGENCY LIGHTING SYSTEM COMPLETION CERTIFICATE -
small new installations up to 25 self-contained luminaires

Based on the recommendations given in BS 5266-1: 2025 'Emergency lighting - Part 1: Emergency lighting of premises - Code of practice'

PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR

Trading Title (where applicable): Logical Heating Ltd
Name:
Address: Office 9, Access House, (Front of Access Storage Buildin, Bristol, Bristol
Postcode: BS3 2LG Tel No:

DETAILS OF THE CLIENT

Reference Number (RN): N/A
Name: Border Cold Stores
Address: Avonmouth Way, Avonmouth, Bristol
Postcode: BS11 9EX Tel No: Bristol

DETAILS OF THE INSTALLATION

Occupier: Border Cold Stores
Address: Avonmouth Way, Avonmouth, Bristol
Postcode: BS11 9EX Tel No: Bristol

PART 2 : DETAILS OF THE EMERGENCY LIGHTING SYSTEM INSTALLATION COVERED BY THIS CERTIFICATE

Description and extent of the installation covered by this certificate: Office refurbishment was done. With a new installation of new Emergency Lighting.
The installation is - New: (✓) or An addition: (N/A) or An alteration: (N/A)
(See additional page No. N/A....)

PART 3 : DECLARATION OF CONFORMITY

In consequence of acceptance of the outcomes declared in this certificate, I/we* hereby declare that the emergency lighting system installation, or part thereof, described in this certificate conforms, to the best of my/our* knowledge and belief, to the appropriate recommendations and requirements given in BS 5266-1: 2025 Emergency lighting - Part 1: Emergency lighting of premises - Code of practice, BS EN 1838: 2024 Lighting applications - Emergency lighting for buildings and BS EN 50172: 2024 Emergency escape lighting systems, as set out in the outcomes declared on the compliance checklist (pages 2 and 3), except for the variations recorded in PART 6.

To be signed by the Responsible Person (as defined by BS 5266-1, see 'Notes for Recipient') on behalf of the owner/occupier

Name (capitals): MATTHEW HADLEY Signature: Position: Electrician Date: 29/01/2026

This certificate is not valid unless accompanied by current versions of the following documentation: i) Signed compliance checklist (pages 2 and 3) ii) Photometric design data (see Note 1 of 'Notes for Recipient') iii) Test logbook

The contractor issuing this certificate MUST sign to verify that i), ii) and iii) above have been supplied with this certificate and that all essential related reference documents have been recorded in PART 4.

Name (capitals): RYAN DAVIES Signature: Position: QS Date: 03/02/2026

*Name (capitals): N/A Signature: N/A Position: N/A Date: N/A

Reviewed by RYAN DAVIES Name (capitals): Signature: Position: QS Date: 03/02/2026

PART 4 : RELATED REFERENCE DOCUMENTS

Please state and provide reference number(s) of all appropriate documentation: (See additional page No.)
N/A (Ref No N/A) N/A (Ref No N/A) N/A (Ref No N/A)
N/A (Ref No N/A) N/A (Ref No N/A) N/A (Ref No N/A)

EMERGENCY LIGHTING SYSTEM COMPLETION CERTIFICATE - small new installations up to 25 self-contained luminaires

Based on the recommendations given in BS 5266-1: 2025 'Emergency lighting - Part 1: Emergency lighting of premises - Code of practice'

PART 5 : COMPLIANCE CHECKLIST (Where a declared outcome is identified by an 'X', the details of the variation must be accurately recorded on page 3 (PART 7))

✓ indicates that an item (Clause No.) was assessed and the declaration outcome was SATISFACTORY; ✗ indicates that a variation was identified; 'N/A' indicates that the assessment of an item was NOT APPLICABLE to the particular installation

Clause No.	Items assessed for compliance	Declared outcome
SYSTEM DESIGN AND DOCUMENTS		
4.2	1 - Plans of the system are available and correct	(...✓...)
4.1; 5.2.8	2 - Design provides coverage for all areas identified by the fire risk assessment	(...✓...)
5.2.8	3 - Design provides coverage for all hazards identified by the fire risk assessment	(...✓...)
6.7	4 - System has been designed for the correct mode(s) of operation classification(s)	(...✓...)
	5 - System is designed for the correct emergency duration period	(...✓...)
11	6 - Photometric design data accompanies this certificate	(...✓...)
	7 - A test logbook accompanies this certificate and is up-to-date	(...✓...)
EMERGENCY LUMINAIRES		
5.2.2	8 - Luminaires are suitably spaced in accordance with authenticated spacing or design data <i>Illumination is normally checked by visual inspection and from the design spacings. Where illuminance is verified by site measurements, insert a 'tick' and provide details of the instruments used and the results on a separate numbered page. For guidance on measurements refer to Annex D of BS 5266-1.</i>	(...✓...) N/A (...✓...)
	9 - Luminaires are installed where necessary to cover toilet facilities, lifts, plant rooms and the like	(...✓...)
5.2.8.5; 5.2.8.6	10 - Luminaires are sited at or near (within 2 m) all relevant 'points of emphasis' in accordance with BS 5266-1: 2025 and in positions/locations identified from the fire risk assessment	(...✓...)
5.2.8	11 - Non-maintained luminaires operate on failure of supply to local lighting circuit	(...✓...)
6.1	12 - Illumination from at least two luminaires provided in each section of the escape route and open areas requiring emergency lighting	(...✓...)
6.3	13 - Luminaires are mounted at least 2 m above the floor and at a suitable height/position to avoid areas of smoke accumulation in smoke reservoirs and/or obstructions	(...✓...)
6.4	14 - Luminaires are suitably protected for their location (IP rating)	(...✓...)
	15 - All luminaires and converted luminaires conform to BS EN IEC 60598-2-22	(...✓...)
SAFETY SIGNS		
5.2.9	16 - Emergency exit signs and escape route direction signs are correctly located and the locations of other safety signs to be illuminated under emergency conditions are identified	(...✓...)

40962923

ESM25

EMERGENCY LIGHTING SYSTEM COMPLETION CERTIFICATE - small new installations up to 25 self-contained luminaires

Based on the recommendations given in BS 5266-1: 2025 'Emergency lighting - Part 1: Emergency lighting of premises - Code of practice'

PART 5 : COMPLIANCE CHECKLIST - CONTINUED (Where a declared outcome is identified by an 'X', the details of the variation must be accurately recorded on page 3 (PART 7))

✓ indicates that an item (Clause No.) was assessed and the declaration outcome was SATISFACTORY; ✗ indicates that a variation was identified; 'N/A' indicates that the assessment of an item was NOT APPLICABLE to the particular installation

Clause No.	Items assessed for compliance	Declared outcome
TEST FACILITIES		
8.3.3	17 - Test facilities are clearly identified with their function	(...✓...)
	18 - All test facilities are suitable to apply a test for function and relevant duration	(...✓...)
	19 - The test facilities act upon the intended luminaires only	(...✓...)
	20 - Test facilities are protected from unauthorised operation	(...✓...)
	21 - Automatic test facilities conform to BS EN 62034	(...✓...)
10.7	22 - Training on the use of the test facilities and recording of test results has been given to the responsible person	(...✓...)
WIRING/EQUIPMENT		
8	23 - Fixed wiring of the emergency lighting installation has been installed in accordance with BS 7671 (as amended)	(...✓...)
8.2.11	24 - Any plugs or sockets protected against unauthorized use	(...✓...)
FINAL DECLARATION TO BE CONDUCTED AT COMPLETION		
10.7	25 - User has been provided with accurate system documentation (drawings layout plans)	(...✓...)
	26 - User has been made aware of the action they need to take in the event of a test failure	(...✓...)
12	27 - The emergency lighting system operates correctly when tested	(...✓...)
Assessment carried out by		
Name (capitals): MATTHEW HADLEY Signature:  Position: Electrician Date: 29/01/2026		

PART 6 : DETAILS OF VARIATIONS FROM THE RECOMMENDATIONS OF BS 5266-1

Clause No.	Details of the variation	(See additional page No. N/A...)
	N/A	

PART 7 : COMMENTS ON EXISTING INSTALLATION (Any defects identified on the existing emergency lighting system installation, not covered by this certificate, should be recorded below)

(See additional page No. N/A...)
N/A

NOTES FOR RECIPIENT

THIS CERTIFICATE IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE USE

Only the contractor responsible for the small emergency lighting system installation work, is authorised to issue this Emergency Lighting System Completion Certificate.

This certificate should be read in conjunction and supported by photometric data (see Note 1) and an appropriate Test logbook, and include the following documents, which should be referenced in PART 4:

- Electrical Installation Certificate (see Note 2), or
- Minor Electrical Installation Works Certificate (see Note 2), and/or
- Emergency Lighting System Periodic Inspection and Test Certificate (see Note 3)

Note 1: This can be in any of the following formats (in all cases appropriate de-rating factors must be used), and identified to meet worst case requirements:

- a) Authenticated spacing data such as ICEL 1001 registered tables;
- b) Calculations as detailed in *BS 5266-1: 2025*, Annex G, and CIBSE / SLL Guide LG12;
- c) Appropriate computer print-out of results.

Note 2: The electrical safety aspects of the emergency lighting system installation must also be certified in accordance with *BS 7671: Requirements for Electrical Installations* (as amended) by issuing an Electrical Installation Certificate or, where appropriate, a Minor Electrical Installation Works Certificate.

Note 3: Where this certificate relates to an addition or alteration that necessitated the carrying out of a periodic inspection on the existing emergency lighting system installation, the 'Emergency Lighting System Periodic Inspection and Testing Certificate' should accompany this certificate.

You should have received the certificate, consisting of 3 pages in total, marked 'Original', and the contractor responsible for carrying out the work should have retained a copy.

Certification of emergency lighting system installation works

This certificate should have been issued on completion of new emergency lighting system installation work that includes no more than 25 new self-contained emergency lighting luminaires, where the contractor issuing the certificate is solely responsible for the design, construction and the inspection and testing of the work. The work may be either a new emergency lighting system installation or an addition or alteration to an existing emergency lighting system installation.

The completed certificate is intended to confirm that the emergency lighting system installation detailed in this certificate has been fully inspected and tested and, except for the variations (if any) recorded in the certificate, conforms to the requirements of *BS 7671: Requirements for Electrical Installations* (as amended) and the relevant recommendations and requirements of the emergency lighting standards listed below:

- *BS 5266-1: 2025 Emergency lighting - Part 1: Emergency lighting of premises - Code of practice*
- *BS EN 1838: 2024 Lighting applications - Emergency lighting for buildings*
- *BS EN 50172: 2024 Emergency escape lighting systems*

The certificate should not have been issued for the periodic inspection and testing of an existing emergency lighting system installation, for which an Emergency Lighting System Periodic Inspection and Testing Certificate should be used.

The completed certificate should have been issued to the Responsible Person for the premises (as identified in PART 3 'Declaration of Conformity') and must be accompanied by all the following documents:

- i. a completed and signed compliance checklist
- ii. photometric design data
- iii. an appropriate test logbook

The contractor should have signed PART 3, attesting that ALL required documentation is present; absence of any of above documents (i, ii or iii) renders this certificate invalid.

BS 5266-1 defines the 'Responsible Person' as the -

'Delegated individual who is responsible for the provision and operation of appropriate emergency escape lighting. Note this might not necessarily be the same as the responsible person as defined in the Regulatory Reform (Fire Safety) Order 2005.'

If you were the person ordering the work, but not the user of the installation, you should pass this certificate, or a full copy of it, including these notes and any related reference documents, to the user immediately. This certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the emergency lighting system installation in the future. If you later vacate the premises, the certificate will demonstrate to the new Responsible Person that the emergency lighting system installation covered by this certificate conformed to the Standards listed above and the requirements of *BS 7671* (as amended), at the time the certificate was issued.

Emergency lighting systems should be maintained by regular inspections and tests in accordance with Clause 7 of *BS EN 50172: 2024*.