

CUSTOMER JOB NO. 314274 - 409198 - Daniel Holland

PO #
 Project Mgr. Andy Beadle

Date Created 10/06/2026
 Date Due 15/07/2026
 Time

Site Details	
Name	BS11 9LX - Border Cold Stores
Address	Avonmouth Way Avonmouth Bristol Avon BS11 9LX

Customer Details	
Name	The Logical Group
Address	Logical Energy Consultants 1 Acorn Business Park Northarbour Road Portsmouth Hants PO6 3TH

Schedule				
Date Schedule	Date Performed	Actual Start	Actual Finish	Total
15/07/2026	15/07/2026	08:30	10:15	1.75 hrs

Asset Register - 1-2 Loop Fire Panel						
Asset ID	Location	Manufacturer	Part Number / Serial Number	Service Level	Date Tested	Pass / Fail
153191	Entrance	Advanced	MX-5202	6 Monthly	15/07/2026	Pass
Test Readings	Panel Inspected: Yes					
Notes						

Asset Register - Battery								
Asset ID	Location	Manufacture r	Part Number	Date of installation	Battery Capacity 24 / 72 hours	Service Level	Date Tested	Pass / Fail
153192	In Fire Panel		BA12/12 x 2	06/06/2025	24 Hour	6 Monthly	15/07/2026	Pass
Test Readings	Battery voltage mains on: 27.2				Battery voltage mains off: 26.9			
	Battery Marked with Installation Date: Yes				Battery Load Quiescent :			
	Battery Load in Alarm:							
Notes								

Asset Register - Call Point						
Asset ID	Location	Manufacturer	Type (S65 / XP95 Conventional / Addressable)	Service Level	Date Tested	Pass / Fail
153193	Entrance by Fire Panel (1)	Apollo	XP95	Annual	15/07/2026	Pass
Test Readings	Call point functions correctly in accordance with the recommendations in 45.4: Yes			Call point on operation results in the correct zone indication and in the case of an addressable system text: Yes		
	Siting complies with BS5839: Yes					
Notes						
153194	Main Office Lobby (4)	Apollo	XP95	Annual	15/07/2026	Pass
Test Readings	Call point functions correctly in accordance with the recommendations in 45.4: Yes			Call point on operation results in the correct zone indication and in the case of an addressable system text: Yes		
	Siting complies with BS5839: Yes					

Lightning Safety Systems is the trading name of Lightning Fire Safety Systems Ltd, which is a limited liability company registered in England and Wales with registration number 6484309. The registered office is at Unit 1 Mornington Place, Waterberry Drive, Waterlooille, Hampshire PO7 7XX
 VAT No: 981622016 • D-U-N-S No: 211060049 • Registered with the Environment Agency, registration number CBDU228868

CUSTOMER JOB NO. 314274 - 409198 - Daniel Holland

Notes						
153195	Staff Dining Room Exit (13)	Apollo	XP95	Annual	15/07/2026	Pass
Test Readings	Call point functions correctly in accordance with the recommendations in 45.4: Yes			Call point on operation results in the correct zone indication and in the case of an addressable system text: Yes		
	Siting complies with BS5839: Yes					
Notes						
153196	Staff Kitchen Exit (14)	Apollo	XP95	Annual	15/07/2026	Pass
Test Readings	Call point functions correctly in accordance with the recommendations in 45.4: Yes			Call point on operation results in the correct zone indication and in the case of an addressable system text: Yes		
	Siting complies with BS5839: Yes					
Notes						
153197	Corridor Exit (18)	Apollo	XP95	Annual	15/07/2026	Pass
Test Readings	Call point functions correctly in accordance with the recommendations in 45.4: Yes			Call point on operation results in the correct zone indication and in the case of an addressable system text: Yes		
	Siting complies with BS5839: Yes					
Notes						
153198	1st Floor Corridor by Ladies WC (27)	Apollo	XP95	Annual	15/07/2026	Pass
Test Readings	Call point functions correctly in accordance with the recommendations in 45.4: Yes			Call point on operation results in the correct zone indication and in the case of an addressable system text: Yes		
	Siting complies with BS5839: Yes					
Notes						
153199	1st Floor Landing (28)	Apollo	XP95	Annual	15/07/2026	Pass
Test Readings	Call point functions correctly in accordance with the recommendations in 45.4: Yes			Call point on operation results in the correct zone indication and in the case of an addressable system text: Yes		
	Siting complies with BS5839: Yes					
Notes						
153214	Rear Workshop (36)	Apollo	XP95	Annual	15/07/2026	Pass
Test Readings	Call point functions correctly in accordance with the recommendations in 45.4: Yes			Call point on operation results in the correct zone indication and in the case of an addressable system text: Yes		
	Siting complies with BS5839: Yes					
Notes						
153215	Rear Void Gantry (40)	Apollo	XP95	Annual	15/07/2026	Pass
Test Readings	Call point functions correctly in accordance with the recommendations in 45.4: Yes			Call point on operation results in the correct zone indication and in the case of an addressable system text: Yes		
	Siting complies with BS5839: Yes					
Notes						
153216	Rear Void Gantry (41)	Apollo	XP95	Annual	15/07/2026	Pass
Test Readings	Call point functions correctly in accordance with the recommendations in 45.4: Yes			Call point on operation results in the correct zone indication and in the case of an addressable system text: Yes		
	Siting complies with BS5839: Yes					
Notes						
153217	Rear Void Gantry (43)	Apollo	XP95	Annual	15/07/2026	Pass
Test Readings	Call point functions correctly in accordance with the recommendations in 45.4: Yes			Call point on operation results in the correct zone indication and in the case of an addressable system text: Yes		

Lightning Safety Systems is the trading name of Lightning Fire Safety Systems Ltd, which is a limited liability company registered in England and Wales with registration number 6484309. The registered office is at Unit 1 Mornington Place, Waterberry Drive, Waterlooville, Hampshire PO7 7XX
 VAT No: 981622016 • D-U-N-S No: 211060049 • Registered with the Environment Agency, registration number CBDU228868

CUSTOMER JOB NO. 314274 - 409198 - Daniel Holland

Test Readings						
	Siting complies with BS5839: Yes					
Notes						
153218	Front Void Gantry (45)	Apollo	XP95	Annual	15/07/2026	Pass
Test Readings	Call point functions correctly in accordance with the recommendations in 45.4: Yes			Call point on operation results in the correct zone indication and in the case of an addressable system text: Yes		
	Siting complies with BS5839: Yes					
Notes						
153219	Front Void Gantry (47)	Apollo	XP95	Annual	15/07/2026	Pass
Test Readings	Call point functions correctly in accordance with the recommendations in 45.4: Yes			Call point on operation results in the correct zone indication and in the case of an addressable system text: Yes		
	Siting complies with BS5839: Yes					
Notes						
153220	Front Void Gantry (49)	Apollo	XP95	Annual	15/07/2026	Pass
Test Readings	Call point functions correctly in accordance with the recommendations in 45.4: Yes			Call point on operation results in the correct zone indication and in the case of an addressable system text: Yes		
	Siting complies with BS5839: Yes					
Notes						

Asset Register - Smoke / Heat Detector								
Asset ID	Location	Type	False Ceiling / Void	Manufacturer	Part Number	Service Level	Date Tested	Pass / Fail
153221	Main Entrance Lobby (2)	Smoke	No	Apollo	55000-600	Annual	15/07/2026	Pass
Test Readings	Detector functions correctly in accordance with the recommendations in 45.4: Yes				Detector on operation results in the correct zone indication and in the case of an addressable system text: Yes			
	Siting complies with BS5839 part 1 2013: Yes							
Notes								
153222	Main Office Lobby (5)	Smoke	No	Apollo	55000-600	Annual	15/07/2026	Pass
Test Readings	Detector functions correctly in accordance with the recommendations in 45.4: Yes				Detector on operation results in the correct zone indication and in the case of an addressable system text: Yes			
	Siting complies with BS5839 part 1 2013: Yes							
Notes								
153223	Managers Office (7)	Smoke	No	Apollo	55000-600	Annual	15/07/2026	Pass
Test Readings	Detector functions correctly in accordance with the recommendations in 45.4: Yes				Detector on operation results in the correct zone indication and in the case of an addressable system text: Yes			
	Siting complies with BS5839 part 1 2013: Yes							
Notes								
153224	Main Office (9)	Smoke	No	Apollo	55000-600	Annual	15/07/2026	Pass
Test Readings	Detector functions correctly in accordance with the recommendations in 45.4: Yes				Detector on operation results in the correct zone indication and in the case of an addressable system text: Yes			
	Siting complies with BS5839 part 1 2013: Yes							
Notes								

Lightning Safety Systems is the trading name of Lightning Fire Safety Systems Ltd, which is a limited liability company registered in England and Wales with registration number 6484309. The registered office is at Unit 1 Mornington Place, Waterberry Drive, Waterlooville, Hampshire PO7 7XX
 VAT No: 981622016 • D-U-N-S No: 211060049 • Registered with the Environment Agency, registration number CBDU228868

CUSTOMER JOB NO. 314274 - 409198 - Daniel Holland

Asset Register - Smoke / Heat Detector								
Asset ID	Location	Type	False Ceiling / Void	Manufacturer	Part Number	Service Level	Date Tested	Pass / Fail
153225	Staff Dining Room (11)	Smoke	No	Apollo	55000-600	Annual	15/07/2026	Pass
Test Readings	Detector functions correctly in accordance with the recommendations in 45.4: Yes				Detector on operation results in the correct zone indication and in the case of an addressable system text: Yes			
	Siting complies with BS5839 part 1 2013: Yes							
Notes								
153226	Staff Kitchen (15)	Heat	No	Apollo	55000-600	Annual	15/07/2026	Pass
Test Readings	Detector functions correctly in accordance with the recommendations in 45.4: Yes				Detector on operation results in the correct zone indication and in the case of an addressable system text: Yes			
	Siting complies with BS5839 part 1 2013: Yes							
Notes								
153227	Fire Escape Staircase (17)	Smoke	No	Apollo	55000-600	Annual	15/07/2026	Pass
Test Readings	Detector functions correctly in accordance with the recommendations in 45.4: Yes				Detector on operation results in the correct zone indication and in the case of an addressable system text: Yes			
	Siting complies with BS5839 part 1 2013: Yes							
Notes								
153228	Rear Office (19)	Smoke	No	Apollo	55000-600	Annual	15/07/2026	Pass
Test Readings	Detector functions correctly in accordance with the recommendations in 45.4: Yes				Detector on operation results in the correct zone indication and in the case of an addressable system text: Yes			
	Siting complies with BS5839 part 1 2013: Yes							
Notes								
153239	Lathe Room (20)	Smoke	No	Apollo	55000-600	Annual	15/07/2026	Pass
Test Readings	Detector functions correctly in accordance with the recommendations in 45.4: Yes				Detector on operation results in the correct zone indication and in the case of an addressable system text: Yes			
	Siting complies with BS5839 part 1 2013: Yes							
Notes								
153241	Refridgeration Plant Room A (23)	Smoke	No	Apollo	55000-600	Annual	15/07/2026	Pass
Test Readings	Detector functions correctly in accordance with the recommendations in 45.4: Yes				Detector on operation results in the correct zone indication and in the case of an addressable system text: Yes			
	Siting complies with BS5839 part 1 2013: Yes							
Notes								
153242	Refridgeration Plant Room B (26)	Smoke	No	Apollo	55000-600	Annual	15/07/2026	Pass
Test Readings	Detector functions correctly in accordance with the recommendations in 45.4: Yes				Detector on operation results in the correct zone indication and in the case of an addressable system text: Yes			
	Siting complies with BS5839 part 1 2013: Yes							
Notes								
153243	Refridgeration Plant Room B (28)	Smoke	No	Apollo	55000-600	Annual	15/07/2026	Pass
Test	Detector functions correctly in accordance with the recommendations in 45.4: Yes				Detector on operation results in the correct zone indication and in the case of an addressable system text: Yes			
	Siting complies with BS5839 part 1 2013: Yes							
Notes								

Lightning Safety Systems Ltd is the trading name of Lightning Fire Safety Systems Ltd, which is limited liability company registered in England and Wales with registration number 6484309. The registered office is at Unit 1 Mornington Place, Waterberry Drive, Waterlooville, Hampshire PO7 7XX VAT No: 981622016 • D-U-N-S No: 211060049 • Registered with the Environment Agency, registration number CBDU228868

CUSTOMER JOB NO. 314274 - 409198 - Daniel Holland

Readings								
	Siting complies with BS5839 part 1 2013: Yes							
Notes								
153244	Refridgeratio n Plant Room B (30)	Smoke	No	Apollo	55000-600	Annual	15/07/2026	Pass
Test Readings	Detector functions correctly in accordance with the recommendations in 45.4: Yes				Detector on operation results in the correct zone indication and in the case of an addressable system text: Yes			
	Siting complies with BS5839 part 1 2013: Yes							
Notes								
153245	Electrical Switch Room (34)	Smoke	No	Apollo	55000-600	Annual	15/07/2026	Pass
Test Readings	Detector functions correctly in accordance with the recommendations in 45.4: Yes				Detector on operation results in the correct zone indication and in the case of an addressable system text: Yes			
	Siting complies with BS5839 part 1 2013: Yes							
Notes								
153246	Rear Workshop (37)	Smoke	No	Apollo	55000-600	Annual	15/07/2026	Pass
Test Readings	Detector functions correctly in accordance with the recommendations in 45.4: Yes				Detector on operation results in the correct zone indication and in the case of an addressable system text: Yes			
	Siting complies with BS5839 part 1 2013: Yes							
Notes								

Asset Register - Sounder / Sounder Beacon						
Asset ID	Location	Manufacturer	Type	Service Level	Date Tested	Pass / Fail
153247	Main Entrance Lobby (3)	Apollo	Sounder	Annual	15/07/2026	Pass
Test Readings	Sound pressure level complies with 16.2: Yes					
Notes						
153248	Main Office Lobby (6)	Apollo	Sounder	Annual	15/07/2026	Pass
Test Readings	Sound pressure level complies with 16.2: Yes					
Notes						
153249	Managers Office (8)	Apollo	Sounder	Annual	15/07/2026	Pass
Test Readings	Sound pressure level complies with 16.2: Yes					
Notes						
153250	Main (10)	Apollo	Sounder	Annual	15/07/2026	Pass
Test Readings	Sound pressure level complies with 16.2: Yes					
Notes						
153251	Staff Dining Room (12)	Apollo	Sounder	Annual	15/07/2026	Pass
Test Readings	Sound pressure level complies with 16.2: Yes					
Notes						

Lightning Safety Systems is the trading name of Lightning Fire Safety Systems Ltd, which is a limited liability company registered in England and Wales with registration number 6484309. The registered office is at Unit 1 Mornington Place, Waterberry Drive, Waterlooville, Hampshire PO7 7XX
 VAT No: 981622016 • D-U-N-S No: 211060049 • Registered with the Environment Agency, registration number CBDU228868

CUSTOMER JOB NO. 314274 - 409198 - Daniel Holland

Asset Register - Sounder / Sounder Beacon						
Asset ID	Location	Manufacturer	Type	Service Level	Date Tested	Pass / Fail
153252	Staff Kitchen (16)	Apollo	Sounder	Annual	15/07/2026	Pass
Test Readings	Sound pressure level complies with 16.2: Yes					
Notes						
153253	Rear Office (20)	Apollo	Sounder	Annual	15/07/2026	Pass
Test Readings	Sound pressure level complies with 16.2: Yes					
Notes						
153271	Electrical Switch Room (35)	Apollo	Sounder	Annual	15/07/2026	Pass
Test Readings	Sound pressure level complies with 16.2: Yes					
Notes						
153272	Rear Workshop (38)	Apollo	Sounder	Annual	15/07/2026	Pass
Test Readings	Sound pressure level complies with 16.2: Yes					
Notes						
153273	Rear Void Gantry (39)	Apollo	Sounder	Annual	15/07/2026	Pass
Test Readings	Sound pressure level complies with 16.2: Yes					
Notes						
153274	Rear Void Gantry (42)	Apollo	Sounder	Annual	15/07/2026	Pass
Test Readings	Sound pressure level complies with 16.2: Yes					
Notes						
153275	Rear Void Gantry (44)	Apollo	Sounder	Annual	15/07/2026	Pass
Test Readings	Sound pressure level complies with 16.2: Yes					
Notes						
153276	Front Void Gantry (46)	Apollo	Sounder	Annual	15/07/2026	Pass
Test Readings	Sound pressure level complies with 16.2: Yes					
Notes						
153277	Front Void Gantry (48)	Apollo	Sounder	Annual	15/07/2026	Pass
Test Readings	Sound pressure level complies with 16.2: Yes					
Notes						

Asset Register - Fire Alarm General						
Asset ID	Have You Had Sight of and Read the Asbestos Report Prior to Starting Work?	System Protocol (i.e. Apollo Series 65)	Service Level	Date Tested	Pass / Fail	
153278	Yes	Advanced & Apollo	6 Monthly	15/07/2026	Pass	

Lightning Safety Systems is the trading name of Lightning Fire Safety Systems, which is a limited liability company registered in England and Wales with registration number 6484309. The registered office is at Unit 1 Mornington Place, Waterberry Drive, Waterlooville, Hampshire PO7 7XX VAT No: 981622016 • D-U-N-S No: 211060049 • Registered with the Environment Agency, registration number CBDU228868

CUSTOMER JOB NO. 314274 - 409198 - Daniel Holland

Test Readings	Was the Fire Alarm Test Satisfactory: Yes	Total Number of false alarms since the last service: 0
	How Many False Alarms per 100 Activations: 0	All manual call points and automatic fire detection function correctly in accordance with the recommendations in 45.4 : Yes
	All Detection Devices are under 10 years old: Yes	Every manual call point and automatic fire detection device on operation results in the correct zone indication and text (addressable): Yes
	DB levels checked if possible: Yes	Any facility to remote signal the fire alarm operates correctly: N/A
	All alarm indicating equipment is labelled correctly: Yes	Have any changes been made to the building since the original design and compromised the compliance of this system with this part of BS5839: No
	The siting of manual call points and detection devices complies with the recommendations of BS5839: Yes	The siting of the control and indicating equipment complies with the recommendations of BS5839 pt1 2025: Yes
	A suitable zone plan is displayed in accordance with the recommendations of BS5839 pt1 2025: Yes	Please attach a picture of the zone chart in situ: Picture Taken
	Ancillary Equipment checked eg:- door holders / output units / zone monitors: Yes	Check detectors above false ceilings / in voids: N/A
	Link to other fire alarm systems tested: N/A	Cables / fixings secure and not damaged: Yes
	Log book is available on site with details of this visit: Yes	Have the mains connectors / MCB's been marked with : Yes
	Mains power supply inspected : Yes	Batteries Marked with Installation Date: Yes
	Battery Capacity 24 / 72 Hours : 24 hour	Battery Location: panem
	Battery Voltage Mains On (volts): 27 2	Battery Voltage Mains Off (volts): 26 9
	Month of the last service visit: January	Month of next service visit: January
	Variations:	
Notes		

Work Completed

90% fire alarm service completed.
 All sounders, smoke detector and call points tested and working.
 Zone chart present and correct.
 Unable to test zone 11 due to floor being unsafe to walk on.
 System left on and fault free.

Work Completed Notes

Materials Used

Description	Location	Used

The above works have been carried out to my complete satisfaction.

Customer:

Ryan Davies

Print Name

Signature

The above works have been supplied and installed as per relevant Standards.

Technician:

Daniel Holland

Print Name

Signature

Lightning Safety Systems is the trading name of Lightning Fire Safety Systems Ltd, which is a limited liability company registered in England and Wales with registration number 6484309. The registered office is at Unit 1 Mornington Place, Waterberry Drive, Waterlooville, Hampshire PO7 7XX
 VAT No: 981622016 • D-U-N-S No: 211060049 • Registered with the Environment Agency, registration number CBDU228868