

Date: 29/06/2026
 Period: June 2026
 Overall completion: 5%
 Regimes on track: 0 of 11
 Open faults: 3
 Delivered by: Coolstream

Maintenance regimes — completion this period

Item	Frequency	Period	Completed	Status
Weekly checks	Weekly	June 2026	50% (2/4)	Behind
Quarterly — A & B	Quarterly	Q2 2026	0% (0/49)	Overdue
Quarterly — C	Quarterly	Q2 2026	0% (0/42)	Overdue
Quarterly — D & E	Quarterly	Q2 2026	0% (0/42)	Overdue
Quarterly — E	Quarterly	Q2 2026	0% (0/42)	Overdue
Condenser & oil-cooler wash	Six-monthly	Jan–Jun 2026	0% (0/7)	Overdue
F-Gas leak testing	Six-monthly	Jan–Jun 2026	0% (0/2)	Overdue
Safety cut-outs	Annual	Jul 2025 – Jun 2026	0% (0/26)	Overdue
Temperature probes	Annual	Jul 2025 – Jun 2026	0% (0/42)	Overdue
A & B leak detection	Annual	Jul 2025 – Jun 2026	0% (0/13)	Overdue
Oil analysis — A&B packs	Annual	Jul 2025 – Jun 2026	0% (0/1)	Overdue

Open faults

Item	Plant	Severity	Stage	Days open	Action
Water from unit inside cold store	C1	High	Reported	14	RED FM
D2 & D4 Compressor Overhaul over due refurbish of compressor	D2	High	Awaiting your sign-off	11	Border
The roof top air cooled condenser heat exchange fins have corroded since the ins	A&B Plant Room	High	Reported	8	RED FM