

Date: 21/07/2026
 Period: July 2026
 Overall completion: 15%
 Regimes on track: 2 of 11
 Open faults: 4
 Delivered by: Coolstream

Maintenance regimes — completion this period

Item	Frequency	Period	Completed	Status
Weekly checks	Weekly	July 2026	60% (3/3)	On track
Quarterly — A & B	Quarterly	Q3 2026	0% (0/49)	In progress
Quarterly — C	Quarterly	Q3 2026	0% (0/42)	In progress
Quarterly — D & E	Quarterly	Q3 2026	0% (0/42)	In progress
Quarterly — E	Quarterly	Q3 2026	0% (0/42)	In progress
Condenser & oil-cooler wash	Six-monthly	Jul–Dec 2026	100% (7/7)	Complete
F-Gas leak testing	Six-monthly	Jul–Dec 2026	0% (0/2)	In progress
Safety cut-outs	Annual	Jul 2026 – Jun 2027	0% (0/26)	In progress
Temperature probes	Annual	Jul 2026 – Jun 2027	0% (0/42)	In progress
A & B leak detection	Annual	Jul 2026 – Jun 2027	0% (0/13)	In progress
Oil analysis — A&B packs	Annual	Jul 2026 – Jun 2027	0% (0/1)	In progress

Open faults

Item	Plant	Severity	Stage	Days open	Action
D2 & D4 Compressor Overhaul over due refurbish of compressor	D2	Medium	Awaiting your sign-off	33	Border
The roof top air cooled condenser heat exchange fins have corroded since the ins	A&B Plant Room	Medium	Reported	30	RED FM
Following Call out 1001 repair/works scissor Lift needed to access areas to comp	C1	High	Approved — scheduling	16	RED FM
Plant room to hot Coolstream to quote extract.	B	High	Reported	5	RED FM