

Ref: FLT-MQOZLGBG
Date: 2026-06-16
Plant: C1
Severity: High
Raised by: Ryan Davies/ Ray Davies
Stage: Reported

Description

Water from unit inside cold store

Action taken / recommendation

Coolstream attended site same day to break ice and fault find the problem.
problem was heater tape that will be replaced