
REF	CO-1001
DATE	28/06/2026
PLANT	C3
SEVERITY	High
STAGE	Call-out
RAISED BY	Dexter Norley

DESCRIPTION

Chamber C system 3 seems to be not refrigerating correctly even after heatwave. On my way on Sunday 28th of June 16:46

ACTION TAKEN

None recorded at submission.

Record regenerated from saved fault data on 03/07/2026. Original photos were not captured at submission (logged before the upload fix). RED FM (Red Electrical Bristol Ltd) - maintenance delivered by Coolstream.