

Ref: WK-MRBSDHWI
 Date: 2026-07-08
 Engineer: Dexter Norley
 Plant: A & B, C & D, E
 Week: 28
 Issues flagged: 0

A & B — Chamber temperature

Item	A1	A2	A3	A4	No1 B2	No2 B2	No3 B1	No4 B1
Cold store set point (controller)	-20	-20	-20	-20	-18.9	-18.2	-18.9	-18.7
Cold store temp air-on	-19.6	-19.7	-19.7	-19.8	-17.6	-17.7	-17.4	-16.5
Coolers air off	21	-20.5	-20.8	-20.5	-18.2	-18.8	-18.4	-18.4
Cooling on/off	On	On	On	On	On	On	On	On

A & B — Coolers

Item	A1	A2	A3	A4	No1 B2	No2 B2	No3 B1	No4 B1
Cooler fan correct operation	OK	OK	OK	OK	OK	OK	OK	OK
Cooler correct operation	OK	OK	OK	OK	OK	OK	OK	OK
Cooler correct defrosting cycle	OK	OK	OK	OK	OK	OK	OK	OK
Cooler ice build-up & debris	OK	OK	OK	OK	OK	OK	OK	OK
Defrost drain line for leakage	OK	OK	OK	OK	OK	OK	OK	OK
% opening of expansion valve #	98	70		31	95	56	100	99
Cooler air temp diff #	0.4	0.8	1.1	0.8	0.6	1.5	1	1.9

A & B — Compressor racks & condenser

Item	A	B
Compr abnormal noise / vibration	OK	OK
Oil cooler fin face free of debris	OK	OK
Oil cooler fans correct operation	OK	OK
Plant-room ventilation fan (on/off)	On	
Plant-room temperature	31	
Ambient temperature	18.5	
Wet-matt cooling on/off (hours)	On	On
System delivery pressure	12.9	13.5
Condenser fin face free of debris	OK	OK
Condenser fans correct operation	Yes x6	Yes x4
Liquid line sight glass	Clear	Clear
Receiver level	Half	Low
Oil separator oil level	3/4	Full
No1 compressor running & % load	100	
No2 compressor running & % load		100
No3 compressor running & % load		/
No1 compr delivery & econ temp	72/	
No2 compr delivery & econ temp	69/	68/

*The work that **keeps you working.***

Item	A	B
No3 compr delivery & econ temp	37/	
Refrigerant leak detection system	OK	

A & B — Controls

Item	A	B
Suction pressure	0.7	1.1
Suction temperature	-16	-14
Delivery pressure	14.3	13.5

A & B — Main incoming meter

Item	kWhr
Previous meter reading	21468

A & B — A — pack meter

Item	kWhr
Electric kWhr meter reading	4476596
Previous meter reading	4462980
Pack total kWhr	13616

A & B — B — pack meter

Item	kWhr
Electric kWhr meter reading	2732793
Previous meter reading	2722720
Pack total kWhr	10073

A & B — A & B cooler energy meter

Item	kWhr
Electric kWhr meter reading	25495762
Previous meter reading	25422547
Total kWhr	73215

C & D — Chamber temperature

Item	C1	C2	C3	C4	D1	D2
Cold store set point (controller)	-18	-18.8	-18.2	-18.2	-18.6	-18.1
Cold store temp air-on	-17.2	-17.2	-16.6	-18	-18	-18.1
Coolers air off	-19.2	-19.5	-17.7	-19.9	-19.9	-18.8
Cooling on/off	On	On	On	On	On	On

C & D — Condensing units

Item	C1	C2	C3	C4	D1	D2	D3	D4
Compr abnormal noise / vibration	OK	OK	OK	OK	OK	OK		
Compressor abnormal frosting	OK	OK	OK	OK	OK	OK		
Compr oil level	Half	1\3	Half	Half	Half	Full		
Compr delivery temperature	88	73	65	46	79	71		
Oil recovery / separator level	Low	Half	Half	Low	Half	Low		
Condenser fin face free of debris	OK	OK	OK	OK	OK	OK	OK	OK
Condenser fans abnormal noise	OK	OK	OK	OK	OK	OK	OK	OK
Liquid line sight glass	OK	OK	OK	OK	OK	OK	OK	OK
Receiver level	Low	Half	Low	Low	Low	/		/

C & D — Coolers

Item	C1	C2	C3	C4	D1	D2
Cooler temperature diff	2	2.3	1.1	1.9	1.9	0.7
Cooler correct operation	OK	OK	OK	OK	OK	OK
Cooler correct defrosting cycle	OK	OK	OK	OK	OK	OK
Cooler ice build-up & debris	OK	OK	OK	OK	OK	OK
Defrost drain line for leakage	OK	OK	OK	OK	OK	OK

C & D — Energy readings

Item	C2-4 refrig	C1-3 refrig	D 1&2	D 3&4 compr
Previous kWhr meter reading	2955777	1071640	2546654	-

E — Chamber temperature

Item	E1	E2
Cold store set point (controller)	-18.6	-18.1
Cold store temp air-on	-18	-18
Coolers air off	-19.2	-18.3
Cooling on/off	On	On

E — E chamber front-centre temp

Item	°C
Front-centre temperature	-17.2

E — Condensing units

Item	E1 Compr1	E1 Compr2	E2 Compr1	E2 Compr2
Compr abnormal noise / vibration	OK	OK	OK	OK
Compressor abnormal frosting	OK	OK	OK	OK
Oil recovery / separator level		/		/
Condenser fin face free of debris	OK	OK	OK	OK
Condenser fans abnormal noise	OK	OK	OK	OK
Liquid line sight glass	OK	OK	OK	OK

E — Energy readings

Item	E1	E2
Previous kWhr meter reading	012443	012290