Battery string impedance test

FICTIONAL TRAINING DOCUMENT - NOT AN OPERATING INSTRUCTION

Document status: Reviewed seed revision Site: Hall 2 Permit: DEMO-026

Prerequisites / sign-off

Qualified technician, current work permit, local indications and chief engineer approval.

Read-back required before each step. Guardian advice never operates plant equipment.

One-line context (simplified; verify actual field labels)

Margin note: normal string voltage does not rule out cell impedance degradation.

STEP	ACTION / VERIFICATION
1	Verify PPE and approved battery test permit Verify: Verify local indication and record read-back.
2	Measure each cell; compare against its own baseline Verify: Verify local indication and record read-back.
3	Escalate impedance drift even if voltage is normal Verify: Verify local indication and record read-back.