CDU filter change

FICTIONAL TRAINING DOCUMENT - NOT AN OPERATING INSTRUCTION

Document status: Reviewed seed revision Site: Hall 2 Permit: DEMO-026

Prerequisites / sign-off

Qualified technician, current work permit, local indications and chief engineer approval.

Read-back required before each step. Guardian advice never operates plant equipment.

One-line context (simplified; verify actual field labels)

Margin note: verify an independent coolant path before any flow interruption.

STEP	ACTION / VERIFICATION
1	Verify standby coolant path and leak detection Verify: Verify local indication and record read-back.
2	Inspect filter differential pressure without isolating flow Verify: Verify local indication and record read-back.