CHW pump swap

FICTIONAL TRAINING DOCUMENT - NOT AN OPERATING INSTRUCTION

Document status: Reviewed seed revision Site: Hall 2 Permit: DEMO-026

Prerequisites / sign-off

Qualified technician, current work permit, local indications and chief engineer approval.

Read-back required before each step. Guardian advice never operates plant equipment.

One-line context (simplified; verify actual field labels)



Margin note: confirm flow and restart temperature limits before requesting a restart.

STEP	ACTION / VERIFICATION
1	Verify standby pump pressure and flow Verify: Verify local indication and record read-back.
2	Confirm pump B bearing inspection with mechanical lead Verify: Verify local indication and record read-back.
3	Stop pump only after independent cooling path is verified Verify: Verify local indication and record read-back. **Gate: retain_last_source**