PISSAR CHECKLIST

Created by People In Search of Safe and Accessible Restrooms, pissar_ucsb@yahoo.com

Type of bathroom (circle one):	Men's	Women's	All Gender	Family
Location of Bathroom: Bldg	Floor	Wing (east	, west) Re	oom #
Does the bathroom open directly to	the outside, or	r is the entry ins	side the building	ng?
				ng, please give the closest
DISABILITY ACCESSIBILITY				
1] Is the door into the bathroom wid	de enough? Gi	ve width. (ADA	A = 32 in)	
2] What kind of knob does the door Automatic push-button Other (s				
3] Are there double doors into the boopen another door to enter the bathr			o open one doo	or and then
4] Is the stall door wide enough? Gi	ive width. (AD	OA = 32 in)		
5] What kind of latch is on the stall Large turn knob with lip Other		ding Latch		
6] Does the stall door close by itself door to help pull it closed? Yes		Is there a ha	andle on the in	side of the
7] Measure the space between the firstall is wide, with open space next to to ilet and the farthest side wall the width of the stall in front of the	o the toilet, m		e between the	side of the
8] Are there grab bars? Yes begins from rear wall, and ex long, high, begins toilet. Back bar is long and	tends i from rear v	n front of the to	oilet. Second s	ide bar is

10] How accessible is the toilet paper holder? Height Is it too far from the toilet to reach without losing one's balance? Yes No
11] Describe the flush knob. (Is it a lever? If yes, is it next to the wall or on the open side of the toilet? Is it a center button?)
12] How high is the toilet seat? (e.g., is it raised or standard?) (ADA = 17-19in.)
13] Is the path to the toilet seat cover dispenser blocked by the toilet? Yes No How high is the dispenser?
14] How high is the urinal?How high is the handle?
15] If a multi-stall bathroom, how many stalls are accessible?
16] Is there a roll-under sink? If so, are the hot water pipes wrapped to prevent burns? (ADA = counter top no higher than 34 in)
17] What kind of faucet handles does the sink have? Lever Automatic Separate turn knobs Other (specify)
18] Is there a soap-dispenser at chair height (ADA = you have to reach no higher than 48 in)? A dryer / paper towel dispenser?
19] Is the tampon / pad dispenser at chair height? (ADA = you have to reach no higher than 48 in)
20] Is there a mirror at chair height? (ADA = bottom of mirror no higher than 40 in)
21] Is there an audible alarm system? Yes No A visual alarm system (lights)? Yes No
22] Is the accessible stall marked as accessible?
23] Is the outer bathroom door marked as accessible?
24] Are there any obstructions in front of the sink, the various dispensers, the accessible stall, the toilet, etc.? Please specify.
GENDER SAFETY
25] Is the bathroom marked as all-gender? Specify.

26] Is it in a safe location? (i.e., not in an isolated spot)
27] Is it next to a gender-specific restroom so that it serves as a de facto "men's" or "women's" restroom?
28] Does the door lock from the inside? Does the lock work securely?
MENSTRUAL PRODUCTS
29] Type of machine in the bathroom (circle one): Tampon Pad Tampon & Pad
30] Does it have a "this machine is broken" sticker? Sticker No Sticker
31] Does it look so rusty and disgusting that even if it works, you doubt anyone would use it? Yes No
32] Is the machine empty? (look for a little plastic "empty" sign) Yes No
CHILD-CARE
34] Does the bathroom have a changing table? (Specify location)
Use this space to answer questions you may have run out of space for: