



Inspection Register for fire fighting equipment

Regulation 9 of the Environmental Regulations for workplaces, Occupational Health and Safety Act, No. 85 of 1993 ("OHS Act")

Department SELF SERVICE BANKING SBC MOBILE

Instructions must be adhered to at all times

If the equipment is safe for use, the appropriate column must be ticked [✓ (yes)] and initialled. If the equipment is unsafe for use, the job number must be entered in the appropriate square [X (no) and no.]. After a re-inspection has been done, the job number and signature must be entered in the re-inspection section. Draw a line through sections not applicable.

Type of fire equipment to be inspected	Fire equipment number											
	January	February	March	April	May	June	July	August	September	October	November	December
A Portable fire extinguisher												
1 Are all signs visible and in good condition?	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
2 Is equipment correctly located?	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
3 Are hoses in optimal working condition?	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
4 Is breather clean and unobstructed?	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
5 Is there any corrosion?	✗	✗	✗	✗	✗	✗	✗	✗	✗	✗	✗	✗
6 Are there any leaks?	✗	✗	✗	✗	✗	✗	✗	✗	✗	✗	✗	✗
7 Are all the seals, including security seal, in order?	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
8 Is the correct pressure maintained?	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
9 Is the colour coding background correct?	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
10 Is demarcation according to standards?	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
11 Is equipment in any way obstructed?	✗	✗	✗	✗	✗	✗	✗	✗	✗	✗	✗	✗
12 Is nozzle clean and clear?	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
13 Is equipment numbered correctly?	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
14 Is equipment serviced annually/bi-annually?	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
15 Is the mounting hook in place and secured to the wall?	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
16 Are employees fully familiarised with the use of extinguishers?	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
B Fire hose reel												
1 Is there any symbolic sign displayed?	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
2 Is the correct number assigned?	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
3 Is the general paintwork in good condition?	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
4 Is the paintwork in any way damaged?	✗	✗	✗	✗	✗	✗	✗	✗	✗	✗	✗	✗
5 Is there any corrosion?	✗	✗	✗	✗	✗	✗	✗	✗	✗	✗	✗	✗

	B Fire hose reel	January	February	March	April	May	June	July	August	September	October	November	December
6	Are there any leaks?		x	x	x	x	x	x	x	x	x	x	x
7	Is the colour coding background correct?		v	v	v	v	v	v	v	v	v	v	v
8	Is demarcation according to standards?		v	v	v	v	v	v	v	v	v	v	v
9	Is the O-ring rubber in good condition?		v	v	v	v	v	v	v	v	v	v	v
10	Is the valve in good working condition?		v	v	v	v	v	v	v	v	v	v	v
11	Is the spray nozzle in good working order?		v	v	v	v	v	v	v	v	v	v	v
12	Is there water in the hose?		v	v	v	v	v	v	v	v	v	v	v
13	Is there a clearly displayed sign stating "Not to be used on electrical equipment"?		v	v	v	v	v	v	v	v	v	v	v
	C Fire hydrant												
1	Is there any symbolic sign displayed?		v	v	v	v	v	v	v	v	v	v	v
2	Is the correct number assigned?		v	v	v	v	v	v	v	v	v	v	v
3	Is the general paintwork in good condition?		v	v	v	v	v	v	v	v	v	v	v
4	Is the paintwork in any way damaged?		x	x	x	x	x	x	x	x	x	x	x
5	Is there any corrosion?		x	x	x	x	x	x	x	x	x	x	x
6	Are there any leaks?		x	x	x	x	x	x	x	x	x	x	x
7	Is colour coding background correct?		v	v	v	v	v	v	v	v	v	v	v
8	Is demarcation according to standards?		v	v	v	v	v	v	v	v	v	v	v
9	Is the O-ring rubber in good condition?		v	v	v	v	v	v	v	v	v	v	v
10	Is the valve in good working condition?		v	v	v	v	v	v	v	v	v	v	v
11	Is the plug fitted to mouth?		v	v	v	v	v	v	v	v	v	v	v
12	Is the coupling connector in good working condition?		v	v	v	v	v	v	v	v	v	v	v
13	Is the fire hydrant accessible?		v	v	v	v	v	v	v	v	v	v	v

I, the inspection officer and signatory declare that I am familiar with Environmental Regulations for Workplaces 9 and Vessels Under Pressure Regulations 11 of the Occupational Health and Safety Act. By the above signatures, the person responsible certifies that the equipment involved has been checked and is safe and fit for use.