

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 1 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
1	BDHS -018 CTF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-BQDA-0025	BDV-018CTF	Ex"d" / NIS				0	100			-	TBD	TYPE-4	2			
		BDV-018CTF RESET PB	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
2	BDHS -8001 TF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-BQDA-0023	BDV-8001TF	Ex"d" / NIS				0	100			-	TBD	TYPE-4	2			
		BDV-8001TF RESET PB	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
3	BDV -018 CTF	BLOW DOWN VALVE	PJ6-EXD-MRI-BQDA-0025	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0001-051	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-4	2			
		RGC DISCHARGE SCRIB INLET TO FLARE BDV	6"-SG-AC3N-8709	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
4	BDV -8001 TF	BLOW DOWN VALVE	PJ6-EXD-MRI-BQDA-0023	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0001-053	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-4	2			
		OIL SLUG CATC TO FLARE BDV	4"-SG-AC3N-8109	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
5	BDY -018 CTF	SOLENOID VALVE	PJ6-EXD-MRI-BQDA-0025	BDV-018CTF	Ex"d" / NIS								-	TBD	TYPE-4	2			
		BDV-018CTF SOV	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
6	BDY -8001 TF	SOLENOID VALVE	PJ6-EXD-MRI-BQDA-0023	BDV-8001TF	Ex"d" / NIS								-	TBD	TYPE-4	2			
		BDV-8001TF SOV	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
7	BPG -018 CTF	PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0025	BDV-018CTF	-								-	TBD	TYPE-4 (BY PACKAGE VENDOR) (Note-5)	2			
		BDV-018CTF VOLUME TANK PRESSURE	-	MRI	-							-	-	TBD					
8	BPG -8001 TF	PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0023	BDV-8001TF	-								-	TBD	TYPE-4 (BY PACKAGE VENDOR) (Note-5)	2			
		BDV-8001TF VOLUME TANK PRESSURE	-	MRI	-							-	-	TBD					
9	BPSV -018 CTF	PRESSURE SAFETY VALVE	PJ6-EXD-MRI-BQDA-0025	BDV-018CTF	-								-	TBD	TYPE-4 (BY PACKAGE VENDOR) (Note-5)	2			
		BDV-018CTF VOLUME TANK PSV	-	MRI	-							-	-	TBD					
10	BPSV -8001 TF	PRESSURE SAFETY VALVE	PJ6-EXD-MRI-BQDA-0023	BDV-8001TF	-								-	TBD	TYPE-4 (BY PACKAGE VENDOR) (Note-5)	2			
		BDV-8001TF VOLUME TANK PSV	-	MRI	-							-	-	TBD					
11	BZSC -018 CTF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0025	BDV-018CTF	Ex"d" / NIS								-	TBD	TYPE-4	2			
		BDV-018CTF CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 2 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
12	BZSC -8001 TF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0023	BDV-8001TF	Ex"d" / NIS								-	TBD	TYPE-4	2			
		BDV-8001TF CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
13	BZSO -018 CTF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0025	BDV-018CTF	Ex"d" / NIS								-	TBD	TYPE-4	2			
		BDV-018CTF OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
14	BZSO -8001 TF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0023	BDV-8001TF	Ex"d" / NIS								-	TBD	TYPE-4	2			
		BDV-8001TF OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
15	DPG -8001 TF	DIFFERENTIAL PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0022	-	-	0	25	psi	0	15	psi	PJ6-EXD-GEN-YZ0H-0006-094	PJ6-EXD-MRF-YZ0A-0002	TBD		2			
		PIG RECEIVER V-805-TF OUTLET LINE PRESSURE	20"-PL-DC3N-8106	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
16	DPT -8001 TF	DIFFERENTIAL PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0022	-	Ex"d" / NIS				0	150	psi G	PJ6-EXD-GEN-YZ0H-0005-122	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		DP ACROSS BYPASS SDV-8002TF	2"-PL-DC3N-8101	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
17	DPT -8002 TF	DIFFERENTIAL PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0021	V-806-TF	Ex"d" / NIS				0	150	psi G	PJ6-EXD-GEN-YZ0H-0005-123	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		MEA INLET SCRB DIFFERENTIAL PRESSURE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
18	DPT -8210 TF	DIFFERENTIAL PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS				0	50	psi G	PJ6-EXD-GEN-YZ0H-0005-124	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		DP AT PWDP PUMP P-851A-TF INLET	12"-PW-DL0N-8704	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
19	DPT -8211 TF	DIFFERENTIAL PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS				0	50	psi G	PJ6-EXD-GEN-YZ0H-0005-125	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		DP AT PWDP PUMP P-851B-TF INLET	12"-PW-DL0N-8715	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
20	DPT -8212 TF	DIFFERENTIAL PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS				0	50	psi G	PJ6-EXD-GEN-YZ0H-0005-126	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		DP AT PWDP PUMP P-851C-TF INLET	12"-PW-DL0N-8716	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
21	DV -8010 TF	HYDRAULIC TYPE DELUGE VALVE	PJ6-EXD-MRI-FZIS-0006	-	Ex'd' / NIS								-	TBD	BY PACKAGE VENDOR (Note-5)	2			
		SWEET GAS CMPSR DELUGE VALVE	10"-FW-A5-505	MRI	-							-	-	TBD					
22	DV -8020 TF	HYDRAULIC TYPE DELUGE VALVE	PJ6-EXD-MRI-FZIS-0006	-	Ex'd' / NIS								-	TBD	BY PACKAGE VENDOR (Note-5)	2			
		SOUR GAS CMPSR DELUGE VALVE	10"-FW-A5-505	MRI	-							-	-	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 3 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
23	DV -8030 TF	HYDRAULIC TYPE DELUGE VALVE	PJ6-EXD-MRI-FZIS-0006	-	Ex'd' / NIS								-	TBD	BY PACKAGE VENDOR (Note-5)	2			
		NEW SLUG CATC DELUGE VALVE	10"-FW-A21V-5101	MRI	-							-	-	TBD					
24	DV -8040 TF	HYDRAULIC TYPE DELUGE VALVE	PJ6-EXD-MRI-FZIS-0006	-	Ex'd' / NIS								-	TBD	BY PACKAGE VENDOR (Note-5)	2			
		SUBST TRANSFORMER DELUGE VALVE	XX"-FW-A21V-XXXX	SUB	-							-	-	TBD					
25	DVHS -8010ATF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-FZIS-0006	DV-8010TF	Ex'd' / NIS								-	-	-	2			
		DV-8010TF RESET PB	-	MRI	2 WIRE							-	-						
26	DVHS -8020ATF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-FZIS-0006	DV-8020TF	Ex'd' / NIS								-	TBD	*	2			
		DV-8020TF RESET PB	-	MRI	2 WIRE							-	-	TBD					
27	DVHS -8030ATF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-FZIS-0006	DV-8030TF	Ex'd' / NIS								-	-	*	2			
		DV-8030TF RESET PB	-	MRI	2 WIRE							-	-						
28	DVHS -8040ATF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-FZIS-0006	DV-8040TF	Ex'd' / NIS								-	-	*	2			
		DV-8040TF DV5040 RESET PB	-	MRI	2 WIRE							-	-						
29	DVPG -8010	PRESSURE GAUGE	PJ6-EXD-MRI-FZIS-0006	-	-								-	TBD	BY PACKAGE VENDOR (Note-5)	2			
		DV-8010TF INLET PRESSURE	10"-FW-A5-505	MRI	-							-	-	TBD					
30	DVPG -8020	PRESSURE GAUGE	PJ6-EXD-MRI-FZIS-0006	-	-								-	TBD	BY PACKAGE VENDOR (Note-5)	2			
		DV-8020TF INLET PRESSURE	10"-FW-A5-505	MRI	-							-	-	TBD					
31	DVPG -8030	PRESSURE GAUGE	PJ6-EXD-MRI-FZIS-0006	-	-								-	TBD	BY PACKAGE VENDOR (Note-5)	2			
		DV-8030TF INLET PRESSURE	10"-FW-A21V-5101	MRI	-							-	-	TBD					
32	DVPG -8040	PRESSURE GAUGE	PJ6-EXD-MRI-FZIS-0006	-	-								-	TBD	BY PACKAGE VENDOR (Note-5)	2			
		DV-8040TF INLET PRESSURE	XX"-FW-A21V-XXXX	MRI	-							-	-	TBD					
33	DVPRV-X8010	SELF REGULATING VALVE	PJ6-EXD-MRI-FZIS-0006	-	-								-	TBD	BY PACKAGE VENDOR (Note-5)	2			
		DV-8010TF SELF REGULATING VALVE	-	MRI	-							-	-	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS		
		Instrument and F&G Index - Mubarraz Island														
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001		
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model		
34	DVPRV-X8020	SELF REGULATING VALVE	PJ6-EXD-MRI-FZIS-0006	-	-								-	TBD	BY PACKAGE VENDOR (Note-5)	2
		DV-8020TF SELF REGULATING VALVE	-	MRI	-							-	-	TBD		
35	DVPRV-X8030	SELF REGULATING VALVE	PJ6-EXD-MRI-FZIS-0006	-	-								-	TBD	BY PACKAGE VENDOR (Note-5)	2
		DV-8030TF SELF REGULATING VALVE	-	MRI	-							-	-	TBD		
36	DVPRV-X8040	SELF REGULATING VALVE	PJ6-EXD-MRI-FZIS-0006	-	-								-	TBD	BY PACKAGE VENDOR (Note-5)	2
		DV-8040TF SELF REGULATING VALVE	-	MRI	-							-	-	TBD		
37	DVPT -8010	PRESSURE TRANSMITTER - DIAPHRAGM	PJ6-EXD-MRI-FZIS-0006	-	Ex'd' / NIS								-	TBD	BY PACKAGE VENDOR (Note-5)	2
		DV-8010TF OUTLET PRESSURE	10"-FW-A5-505	MRI	LOOP POWERED							-	-	TBD		
38	DVPT -8020	PRESSURE TRANSMITTER - DIAPHRAGM	PJ6-EXD-MRI-FZIS-0006	-	Ex'd' / NIS								-	TBD	BY PACKAGE VENDOR (Note-5)	2
		DV-8020TF OUTLET PRESSURE	10"-FW-A5-505	MRI	LOOP POWERED							-	-	TBD		
39	DVPT -8030	PRESSURE TRANSMITTER - DIAPHRAGM	PJ6-EXD-MRI-FZIS-0006	-	Ex'd' / NIS								-	TBD	BY PACKAGE VENDOR (Note-5)	2
		DV-8030TF OUTLET PRESSURE	10"-FW-A21V-5101	MRI	LOOP POWERED							-	-	TBD		
40	DVPT -8040	PRESSURE TRANSMITTER - DIAPHRAGM	PJ6-EXD-MRI-FZIS-0006	-	Ex'd' / NIS								-	TBD	BY PACKAGE VENDOR (Note-5)	2
		DV-8040TF OUTLET PRESSURE	XX"-FW-A21V-XXXX	MRI	LOOP POWERED							-	-	TBD		
41	DY -8010 TF	SOLENOID VALVE	PJ6-EXD-MRI-FZIS-0006	DV-8010TF	Ex'd' / NIS								-	TBD	BY PACKAGE VENDOR (Note-5)	2
		DV-8010TF SOV	-	MRI	2 WIRE							-	-	TBD		
42	DY -8020 TF	SOLENOID VALVE	PJ6-EXD-MRI-FZIS-0006	DV-8020TF	Ex'd' / NIS								-	TBD	BY PACKAGE VENDOR (Note-5)	2
		DV-8020TF SOV	-	MRI	2 WIRE							-	-	TBD		
43	DY -8030 TF	SOLENOID VALVE	PJ6-EXD-MRI-FZIS-0006	DV-8030TF	Ex'd' / NIS								-	TBD	BY PACKAGE VENDOR (Note-5)	2
		DV-8030TF SOV	-	MRI	2 WIRE							-	-	TBD		
44	DY -8040 TF	SOLENOID VALVE	PJ6-EXD-MRI-FZIS-0006	DV-8040TF	Ex'd' / NIS								-	TBD	BY PACKAGE VENDOR (Note-5)	2
		DV-8040TF DV5040 SOV	-	MRI	2 WIRE							-	-	TBD		

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 5 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
45	FCV -8007 TF	FLOW CONTROL VALVE	PJ6-EXD-MRI-BQDA-0007	-							D	FCV -8007 TF-SP	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		CRUDE OIL TO MRD OIL HEATER H-120-TF	10"-PL-AC3N-8352	MRI								PJ6-EXD-MRI-YZ0A-0002	PJ6-EXD-MRI-YCPA-0002	TBD					
46	FCV -8210 TF	FLOW CONTROL VALVE	PJ6-EXD-MRI-BQDA-0042	-	-							PJ6-EXD-GEN-YZ0H-0013-035	-	TBD	*	2			
		PROD. WATER FRM PMP P-851A-TF OUTLET BYPASS	6"-PW-DL0N-8700	MRI	-							-	-	TBD					
47	FCV -8211 TF	FLOW CONTROL VALVE	PJ6-EXD-MRI-BQDA-0042	-	-							PJ6-EXD-GEN-YZ0H-0013-038	-	TBD	*	2			
		PROD. WATER FRM PMP P-851B-TF OUTLET BYPASS	6"-PW-DL0N-8701	MRI	-							-	-	TBD					
48	FCV -8212 TF	FLOW CONTROL VALVE	PJ6-EXD-MRI-BQDA-0042	-	-							PJ6-EXD-GEN-YZ0H-0013-041	-	TBD	*	2			
		PROD. WATER FRM PMP P-851C-TF OUTLET BYPASS	6"-PW-DL0N-8702	MRI	-							-	-	TBD					
49	FD -3010 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SCRUBBER AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
50	FD -3011 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SCRUBBER AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
51	FD -3012 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SCRUBBER AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
52	FD -6012 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		3 PHASE SPTR AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
53	FD -6013 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SLUG CATCHER AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
54	FD -6014 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SLUG CATCHER AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
55	FD -6015 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SLUG CATCHER AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (اليابان) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 6 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
56	FD -6016 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		3 PHASE SPTR AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
57	FD -6017 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		3 PHASE SPTR AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
58	FD -6018 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		PIG RCVR AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
59	FD -6019 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		PIG RCVR AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
60	FD -6020 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		PIG RCVR AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
61	FD -6021 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SOUR GAS CMPSR AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
62	FD -6022 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SOUR GAS CMPSR AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
63	FD -6023 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SOUR GAS CMPSR AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
64	FD -6024 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SOUR GAS CMPSR AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
65	FD -7007 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		NEW OIL HEATER H-801-TF AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
66	FD -7008 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		NEW OIL HEATER H-801-TF AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 7 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
67	FD -7009 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SWEET GAS CMPSR K-101E-TF AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
68	FD -7011 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SWEET GAS CMPSR K-101E-TF AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
69	FD -7012 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SWEET GAS CMPSR K-101E-TF AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
70	FD -7013 -M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SWEET GAS CMPSR K-101E-TF AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
71	FD -7015-M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SWEET GAS CMPSR K-101E-TF AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
72	FD -7016-M	FLAME DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SWEET GAS CMPSR K-101E-TF AREA FLAME DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
73	FE -102 BK	FLOW ELEMENT - ORIFICE	MRI-091-081	-	-				0	10	mft³/d	PJ6-EXD-GEN-YZ0H-0009-012	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		SWEET GAS COMPRESSOR COMMON DISCHARGE	6/6"-FG-C1-329	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
74	FE -160 TF	FLOW ELEMENT - ORIFICE	MRI-091-021	-	-				0	2.5	mft³/d	PJ6-EXD-GEN-YZ0H-0009-010	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		DEGASSING BOOT V-180-TF GAS OUTLET FLOW	10/10"-FG-B1-327	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
75	FE -180 TF	FLOW ELEMENT - ORIFICE	MRI-091-021	-	-				0	2.5	mft³/d	PJ6-EXD-GEN-YZ0H-0009-011	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		DEGASSING BOOT V-180-TF GAS OUTLET FLOW	10/10"-FG-B1-328	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
76	FE -8001 TF	V-CONE FLOWMETER	PJ6-EXD-MRI-BQDA-0023	-	-				0	17500	lb/h	PJ6-EXD-GEN-YZ0H-0011-015	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		OIL SLUG CATC TO MEA INLET SCRB FLOW	6"-SG-AC3N-8112	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
77	FE -8003 TF	FLOW ELEMENT - ORIFICE	PJ6-EXD-MRI-BQDA-0024	-	-				0	1300	lb/h	PJ6-EXD-GEN-YZ0H-0009-005	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		3 PHASE SEPT GAS TO NEW MEA INLET SCRB FLOW	3"-SG-AC3N-8116	MRI	-							-	-	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 8 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
78	FE -8210 TF	FLOW ELEMENT - ORIFICE	PJ6-EXD-MRI-BQDA-0042	-	-				0	135000	lb/h	PJ6-EXD-GEN-YZ0H-0009-006	-	TBD	*	2			
		PROD WATER FROM PROD WATER DISPOSAL PUMP P-851A-TF	10"-PW-DL0N-8703	MRI	-							-	-	TBD					
79	FE -8211 TF	FLOW ELEMENT - ORIFICE	PJ6-EXD-MRI-BQDA-0042	-	-				0	135000	lb/h	PJ6-EXD-GEN-YZ0H-0009-007	-	TBD	*	2			
		PROD WATER FROM PROD WATER DISPOSAL PUMP P-851B-TF	10"-PW-DL0N-8704	MRI	-							-	-	TBD					
80	FE -8212 TF	FLOW ELEMENT - ORIFICE	PJ6-EXD-MRI-BQDA-0042	-	-				0	135000	lb/h	PJ6-EXD-GEN-YZ0H-0009-008	-	TBD	*	2			
		PROD WATER FROM PROD WATER DISPOSAL PUMP P-851C-TF	10"-PW-DL0N-8705	MRI	-							-	-	TBD					
81	FE -8213 TF	FLOW ELEMENT - ORIFICE	PJ6-EXD-MRI-BQDA-0042	-	-				0	270000	lb/h	PJ6-EXD-GEN-YZ0H-0009-009	-	TBD	*	2			
		PROD WATER FRM PROD WATER DISPOSAL PMP P-851A/B/C-TF	12"-PW-DL0N-8110	MRI	-							-	-	TBD					
82	FGD -3013 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		MEA INLET SCRB V-806-TF AREA FLAMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
83	FGD -3014 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		MEA INLET SCRB V-806-TF AREA FLAMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
84	FGD -6016 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SLUG CATCHER AREA FLAMMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
85	FGD -6017 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SLUG CATCHER AREA FLAMMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
86	FGD -6021 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		3 PHASE SPTR AREA FLAMMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
87	FGD -6022 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		PIG RCVR FLAMMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
88	FGD -6023 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		PIG RCVR AREA FLAMMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (اليابان) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 9 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
89	FGD -6024 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		PIG RCVR AREA FLAMMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
90	FGD -6025 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SOUR GAS CMPSR AREA FLAMMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
91	FGD -6026 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SOUR GAS CMPSR AREA FLAMMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
92	FGD -6027 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SOUR GAS CMPSR AREA FLAMMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
93	FGD -6028 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		3 PHASE SPTR AREA FLAMMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
94	FGD -6029 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SLUG CATCHER AREA FLAMMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
95	FGD -6030 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		3 PHASE SPTR AREA FLAMMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
96	FGD -6031 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		3 PHASE SPTR AREA FLAMMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
97	FGD -7011 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		NEW OIL HEATER H-801-TF AREA FLAMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
98	FGD -7012 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		NEW OIL HEATER H-801-TF AREA FLAMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
99	FGD -7013 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		NEW OIL HEATER H-801-TF AREA FLAMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البيان) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 10 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
100	FGD -7014 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SWEET GAS CMPSR K-101E-TF AREA FLAMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
101	FGD -7015 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SWEET GAS CMPSR K-101E-TF AREA FLAMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
102	FGD -7016 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SWEET GAS CMPSR K-101E-TF AREA FLAMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
103	FGD -7017 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SWEET GAS CMPSR K-101E-TF AREA FLAMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
104	FGD -7018 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SWEET GAS CMPSR K-101E-TF AREA FLAMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
105	FGD -7023-M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		NEW OIL HEATER H-801TF AREA FLAMMABLE GASDETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
106	FGD -7024-M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		NEW OIL HEATER H-801TF AREA FLAMMABLE GASDETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
107	FGD -7025-M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		NEW OIL HEATER H-801TF AREA FLAMMABLE GASDETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
108	FGD -9001 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION HVAC AREA FLAMMABLE GAS DETECTOR	-	SUB	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
109	FGD -9002 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION HVAC AREA FLAMMABLE GAS DETECTOR	-	SUB	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
110	FGD -9004 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION AIR LOCK ROOM FLAMMABLE GAS DETECTOR	-	SUB	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 11 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
111	FGD -9005 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION AIR LOCK ROOM FLAMMABLE GAS DETECTOR	-	SUB	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
112	FGD -9007 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD		2			
		ICSS ROOM-3 AIR LOCK ROOM FLAMMABLE GAS DETECTOR	-	SUB	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
113	FGD -9008 -M	FLAMMABLE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD		2			
		ICSS ROOM-3 AIR LOCK ROOM FLAMMABLE GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
114	FIT -010 CTF	FLOW INDICATING TRANSMITTER	PJ6-EXD-MRI-BQDA-0025	-	-								-	TBD	*	2			
		SIGNAL TO FQ 010DT	6"-SG-AC3N-8103	MRI	-							-	-	TBD					
115	FMDV -8000-M	DELUGE SOLENIOD VALVE	PJ6-EXD-MRI-FZIS-0011	-	Ex"d" / NIS								-	TBD		2			
		FIRE MONITOR AT HEATER AREA	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-						
116	FMDV -8001-M	DELUGE SOLENIOD VALVE	PJ6-EXD-MRI-FZIS-0011	-	Ex"d" / NIS								-	TBD		2			
		FIRE MONITOR AT HEATER AREA	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-						
117	FMDV -8002-M	DELUGE SOLENIOD VALVE	PJ6-EXD-MRI-FZIS-0011	-	Ex"d" / NIS								-	TBD		2			
		FIRE MONITOR AT HEATER AREA	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-						
118	FMDV -8003-M	DELUGE SOLENIOD VALVE	PJ6-EXD-MRI-FZIS-0011	-	Ex"d" / NIS								-	TBD		2			
		FIRE MONITOR AT HEATER AREA	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-						
119	FMDV -8004-M	DELUGE SOLENIOD VALVE	PJ6-EXD-MRI-FZIS-0011	-	Ex"d" / NIS								-	TBD		2			
		FIRE MONITOR AT HEATER AREA	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-						
120	FT -010 CTF	FLOW TRANSMITTER- VORTEX	PJ6-EXD-MRI-BQDA-0025	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0011-014	PJ6-EXD-MRF-YZ0A-0002	TBD	BY PACKAGE VENDOR (Note-5)	2			
		SOUR GAS TO RGC DISCHARGE SCRB INLET FLOW	6"-SG-AC3N-8103	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
121	FT -8001 TF	FLOW TRANSMITTER- V CONE	PJ6-EXD-MRI-BQDA-0023	-	Ex"d" / NIS				0	16000	lb/h	PJ6-EXD-GEN-YZ0H-0011-016	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		3 PHASE SEPT GAS TO NEW MEA INLET SCRB FLOW	6"-SG-AC3N-8112	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 12 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
122	FT -8002 TF	FLOW TRANSMITTER- ULTRASONIC	PJ6-EXD-MRI-BQDA-0023	-	Ex"d" / NIS				0	3000000	lb/h	PJ6-EXD-GEN-YZ0H-0011-004	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		OIL SLUG CATC V803TF OUTLET TO 3 PHASE SEPT FLOW	12"-PL-AC3N-8114	MRI	4 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
123	FT -8003 TF	FLOW TRANSMITTER- DP TYPE	PJ6-EXD-MRI-BQDA-0024	-	Ex"d" / NIS				0	1000	lb/h	PJ6-EXD-GEN-YZ0H-0005-127	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		3 PHASE SEPT GAS TO NEW MEA INLET SCRB FLOW	3"-SG-AC3N-8116	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
124	FT -8004 TF	FLOW TRANSMITTER- MAGNETIC	PJ6-EXD-MRI-BQDA-0024	-	Ex"d" / NIS				0	1800000	lb/h	PJ6-EXD-GEN-YZ0H-0011-008	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		3 PHASE SEPT WATER OUTLET FLOW	12"-PW-AL0N-8104	MRI	4 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
125	FT -8007 TF	FLOW TRANSMITTER- ULTRASONIC	PJ6-EXD-MRI-BQDA-0007	-	Ex'd' / NIS				0	750000	lb/h	PJ6-EXD-GEN-YZ0H-0011-006	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		CRUDE OIL TO MRD OIL HEATER H-120-TF	-	MRI	4 WIRE							PJ6-EXD-MRI-YZ0A-0002	PJ6-EXD-MRI-YCPA-0002	TBD					
126	FT -8008 TF	FLOW TRANSMITTER- ULTRASONIC	PJ6-EXD-MRI-BQDA-0024	-	Ex"d" / NIS				0	750000	lb/h	PJ6-EXD-GEN-YZ0H-0011-006	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		3 PHASE SEPT OIL TO NEW HEATER OUTLET FLOW	10"-PL-AC3N-8116	MRI	4 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
127	FT -8009 TF	FLOW TRANSMITTER- MAGNETIC	PJ6-EXD-MRI-BQDA-0024	-	Ex"d" / NIS				0	1800000	lb/h	PJ6-EXD-GEN-YZ0H-0011-010	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		PROD WATER FROM MRD 3 PHASE SEPT V-804-TF	12"-PW-AL0N-8104	MRI	4 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
128	FT -8010 TF	FLOW Tx - VARIABLE AREA (ROTAMETER)	PJ6-EXD-MRI-BQDA-0010	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0011-012	PJ6-EXD-MRF-YZ0A-0002	TBD		2			
		PURGE GAS FROM RECOVERY GAS HDR TO FLARE HDR	2"-FG-AC3-8105	MRI	LOOP POWERED							-	PJ6-EXD-MRI-YCPA-0002	TBD					
129	FT -8050 TF	FLOW Tx - VARIABLE AREA (ROTAMETER)	PJ6-EXD-MRI-BQDA-0058	-	Ex"d" / NIS								-	TBD		2			
		CHEMICAL INJECTION TO MIXER VALVE	-	MRI	LOOP POWERED							-	-						
130	FT -8200 TF	FLOW TRANSMITTER- MAGNETIC	P250001-PLK00C01001	-	Ex"d" / NIS								-	TBD		2			
		INLET HEADER V-851A-TF	-	MRI	-							-	-						
131	FT -8201 TF	FLOW TRANSMITTER- MAGNETIC	P250001-PLK00C01001	-	Ex"d" / NIS								-	TBD		2			
		INLET HEADER V-851B-TF	-	MRI	-							-	-						
132	FT -8202 TF	FLOW TRANSMITTER- MAGNETIC	P250001-PLK00C01001	-	Ex"d" / NIS								-	TBD		2			
		INLET HEADER V-851C-TF	-	MRI	-							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 13 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
133	FT -8210 TF	FLOW TRANSMITTER- DP TYPE	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS				0	760000	lb/h	PJ6-EXD-GEN-YZ0H-0005-129	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		PRODUCED WATER FROM PRODUCED WATER DISPOSAL PUMP P-8	10"-PW-DL0N-8703	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
134	FT -8211 TF	FLOW TRANSMITTER- DP TYPE	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS				0	760000	lb/h	PJ6-EXD-GEN-YZ0H-0005-131	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		PRODUCED WATER FROM PRODUCED WATER DISPOSAL PUMP P-8	10"-PW-DL0N-8704	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
135	FT -8212 TF	FLOW TRANSMITTER- DP TYPE	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS				0	760000	lb/h	PJ6-EXD-GEN-YZ0H-0005-133	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		PRODUCED WATER FROM PRODUCED WATER DISPOSAL PUMP P-8	10"-PW-DL0N-8705	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
136	FT -8213 TF	FLOW TRANSMITTER- DP TYPE	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS				0	760000	lb/h	PJ6-EXD-GEN-YZ0H-0005-135	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		PRODUCED WATER FROM PRODUCED WATER DISPOSAL PUMP P-8	12"-PW-DL0N-8110	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
137	FY -8007 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0007	FCV-8007TF	Ex"d" / NIS								-	TBD	TYPE-5	2			
		FCV-8007TF POSITIONER	-	MRI	2 WIRE							-	-	TBD					
138	FY -8200 TF	CONTROL VALVE POSITIONER	P250001-PLK00C01001	FCV-8200TF	Ex"d" / NIS								-	TBD		2			
		CONTROL SIGNAL FCV-8200, V-851A-TF	-	MRI	2 WIRE							-	-						
139	FY -8201 TF	CONTROL VALVE POSITIONER	P250001-PLK00C01001	FCV-8201TF	Ex"d" / NIS								-	TBD		2			
		CONTROL SIGNAL FCV-8201, V-851B-TF	-	MRI	2 WIRE							-	-						
140	FY -8202 TF	CONTROL VALVE POSITIONER	P250001-PLK00C01001	FCV-8202TF	Ex"d" / NIS								-	TBD		2			
		CONTROL SIGNAL FCV-8202, V-851C-TF	-	MRI	2 WIRE							-	-						
141	FY -8210 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0042	FCV-8210TF	Ex"d" / NIS								-	TBD		2			
		FCV-8210TF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
142	FY -8211 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0042	FCV-8211TF	Ex"d" / NIS								-	TBD		2			
		FCV-8211TF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
143	FY -8212 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0042	FCV-8212TF	Ex"d" / NIS								-	TBD		2			
		FCV-8212TF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						

FD شركة نفط أبوظبي المحدودة (اليابان) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 14 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
144	FZT -8007 TF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0007	FCV-8007TF	Ex"d" / NIS								-	TBD	TYPE-5	2			
		FCV-8007TF POSITION TRANSMITTER	-	MRI	LOOP POWERED							-	-						
145	FZT -8200 TF	FEEDBACK	P250001-PLK00C01001	FCV-8200TF	NIS								-	TBD		2			
		POSITION FEEDBACK FCV-8200, V-851A-TF	-	MRI	2 WIRE							-	-						
146	FZT -8201 TF	FEEDBACK	P250001-PLK00C01001	FCV-8201TF	NIS								-	TBD		2			
		POSITION FEEDBACK FCV-8201, V-851B-TF	-	MRI	2 WIRE							-	-						
147	FZT -8202 TF	FEEDBACK	P250001-PLK00C01001	FCV-8202TF	NIS								-	TBD		2			
		POSITION FEEDBACK FCV-8202, V-851C-TF	-	MRI	2 WIRE							-	-						
148	FZT -8210 TF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	FCV-8210TF	Ex"d" / NIS								-	TBD	TYPE-5	2			
		FCV-8210TF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
149	FZT -8211 TF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	FCV-8211TF	Ex"d" / NIS								-	TBD	TYPE-5	2			
		FCV-8211TF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
150	FZT -8212 TF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	FCV-8212TF	Ex"d" / NIS								-	TBD	TYPE-5	2			
		FCV-8212TF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
151	HCV -8002 TF	HAND CONTROL VALVE	PJ6-EXD-MRI-BQDA-0023	-	-							PJ6-EXD-GEN-YZ0H-0013-053	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-5	2			
		MRD OIL SLUG CATCHER V-803TF OUTLET TO 3 PHASE SEPT	8"-PL-AC3N-8113	MRI	-							-	-	TBD					
152	HCV -8003 TF	HAND CONTROL VALVE	PJ6-EXD-MRI-BQDA-0024	-	-							PJ6-EXD-GEN-YZ0H-0013-056	-	TBD	-	2			
		CRUDE OIL FRM MRD 3 PH SEPT TO NEW OIL HEATER HDR	10"-PL-AC3N-8116	MRI	-							-	-	TBD					
153	HCV -8004 TF	HAND CONTROL VALVE	PJ6-EXD-MRI-BQDA-0024	-	-							PJ6-EXD-GEN-YZ0H-0013-059	-	TBD	-	2			
		CRUDE OIL FRM MRD 3 PH SEPT TO NEW OIL HEATER HDR	8"-PL-AC3N-8116	MRI	-							-	-	TBD					
154	HCV -8005 TF	HAND CONTROL VALVE	PJ6-EXD-MRI-BQDA-0024	-	-							PJ6-EXD-GEN-YZ0H-0013-062	-	TBD	-	2			
		PROD. WATER FRM MRD 3 PH SEPT TO WATER TREATMENT PKG	12"-PW-AL0N-8104	MRI	-							-	-	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 15 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
155	HCV -8006 TF	HAND CONTROL VALVE	PJ6-EXD-MRI-BQDA-0024	-	-							PJ6-EXD-GEN-YZ0H-0013-065	-	TBD	-	2			
		PROD. WATER FRM MRD 3 PH SEPT TO WATER TREATMENT PKG	10"-PW-AL0N-8104	MRI	-							-	-	TBD					
156	HCV -8220 TF	HAND CONTROL VALVE	PJ6-EXD-MRI-BQDA-0042	-	-							PJ6-EXD-GEN-YZ0H-0013-044	-	TBD	*	2			
		PROD. WATER FRM PMP P-851A-TF DISCHARGE	10"-PW-DL0N-8703	MRI	-							-	-	TBD					
157	HCV -8221 TF	HAND CONTROL VALVE	PJ6-EXD-MRI-BQDA-0042	-	-							PJ6-EXD-GEN-YZ0H-0013-047	-	TBD	*	2			
		PROD. WATER FRM PMP P-851B-TF DISCHARGE	10"-PW-DL0N-8704	MRI	-							-	-	TBD					
158	HCV -8222 TF	HAND CONTROL VALVE	PJ6-EXD-MRI-BQDA-0042	-	-							PJ6-EXD-GEN-YZ0H-0013-050	-	TBD	*	2			
		PROD. WATER FRM PMP P-851C-TF DISCHARGE	10"-PW-DL0N-8705	MRI	-							-	-	TBD					
159	HGD -9001 -M	HYDROGEN GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION TOXIC GAS DETECTOR	-	SUB	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
160	HGD -9002 -M	HYDROGEN GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS				0	100	% LEL	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION TOXIC GAS DETECTOR	-	SUB	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
161	HS -017 CTF	PST SOFT HAND SWITCH	PJ6-EXD-MRI-BQDA-0025	-	-								-			2			
		SDV-017CTF SOFT HAND SWITCH	-	MRI	-							-	-						
162	HS -8001 TF	PST SOFT HAND SWITCH	PJ6-EXD-MRI-BQDA-0022	-	-								-			2			
		SDV-8001T PST SOFT HAND SWITCH	-	MRI	-							-	-						
163	HS -8003 TF	PST SOFT HAND SWITCH	PJ6-EXD-MRI-BQDA-0023	-	-								-			2			
		SDV-8003 PST SOFT HAND SWITCH	-	MRI	-							-	-						
164	HS -8004 TF	PST SOFT HAND SWITCH	PJ6-EXD-MRI-BQDA-0023	-	-								-			2			
		SDV-8004TF PST SOFT HAND SWITCH	-	MRI	-							-	-						
165	HS -8005 TF	PST SOFT HAND SWITCH	PJ6-EXD-MRI-BQDA-0023	-	-								-			2			
		SDV-8005TF PST SOFT HAND SWITCH	-	MRI	-							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 16 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
166	HS -8006 TF	PST SOFT HAND SWITCH	PJ6-EXD-MRI-BQDA-0024	-	-								-			2			
		SDV-8006TF PST SOFT HAND SWITCH	-	MRI	-							-	-						
167	HS -8007 TF	PST SOFT HAND SWITCH	PJ6-EXD-MRI-BQDA-0024	-	-								-			2			
		SDV-8007TF PST SOFT HAND SWITCH	-	MRI	-							-	-						
168	HS -8009 TF	PST SOFT HAND SWITCH	PJ6-EXD-MRI-BQDA-0024	-	-								-			2			
		SDV-8009TF PST SOFT HAND SWITCH	-	MRI	-							-	-						
169	HS -8014BTF	PST SOFT HAND SWITCH	PJ6-EXD-MRI-BQDA-0025	-	-								-			2			
		SDV-8014TF PST SOFT HAND SWITCH	-	MRI	-							-	-						
170	HS -8016 TF	PST SOFT HAND SWITCH	PJ6-EXD-MRI-BQDA-0021	-	-								-			2			
		SDV-8016 SOFT HAND SWITCH	-	MRI	-							-	-						
171	HS -8017 TF	PST SOFT HAND SWITCH	PJ6-EXD-MRI-BQDA-0021	-	-								-			2			
		SDV-8017TF SOFT HAND SWITCH	-	MRI	-							-	-						
172	HS -8018 TF	PST SOFT HAND SWITCH	PJ6-EXD-MRI-BQDA-0023	-	-								-			2			
		SDV-8018TF PST SOFT HAND SWITCH	-	MRI	-							-	-						
173	HS -8020 TF	EMERGENCY SHUTDOWN PUSH BUTTON	-	-	-								-			2			
		TOTAL PRODTN STDWN OF MRI FLD ESD PB IN ESD PB CNSL	-	MRI	-							-	-						
174	HS -8021 TF	RESET PUSH BUTTON	-	-	-								-			2			
		TOTAL PRODN SDWN OF MRI FLD RESET PB IN ESD PB CNSL	-	MRI	-							-	-						
175	HSSD -9001 -M	HIGH SENSITIVITY SMOKE DETECTOR	PJ6-EXD-MRI-FZ0A-0002	-	-								-	TBD	*	2			
		ICSS CONTROL-3 EQUIP ROOM CEILING HIGH SENSITIVITY S	-	ICSS CAB ROOM-3	-							-	-	TBD					
176	HSSD -90XX -M	HIGH SENSITIVITY SMOKE DETECTOR	PJ6-EXD-MRI-FZ0A-0002	-	-								-	TBD	*	2			
		SUBST BLDG HIGH SENSITIVITY SMOKE DETECTION	-	SUB	-							-	-	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 17 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
177	HY -8002 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0023	-	Ex"d" / NIS								-			2			
		HCV-8002TF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
178	HY -8003 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0024	-	Ex"d" / NIS								-	TBD	TYPE-5	2			
		HCV-8003TF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
179	HY -8004 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0024	-	Ex"d" / NIS								-	TBD	TYPE-5	2			
		HCV-8004TF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
180	HY -8005 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0024	-	Ex"d" / NIS								-	TBD	TYPE-5	2			
		HCV-8005TF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
181	HY -8006 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0024	-	Ex"d" / NIS								-	TBD	TYPE-5	2			
		HCV-8006TF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
182	HY -8220 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS								-			2			
		HCV-8220TF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
183	HY -8221 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS								-			2			
		HCV-8221TF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
184	HY -8222 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS								-			2			
		HCV-8222TF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
185	HZT -8002 TF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0023	-	Ex"d" / NIS								-			2			
		HCV-8002TF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
186	HZT -8003 TF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0024	-	Ex"d" / NIS								-			2			
		HCV-8003TF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
187	HZT -8004 TF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0024	-	Ex"d" / NIS								-			2			
		HCV-8004TF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 18 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
188	HZZ -8005 TF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0024	-	Ex"d" / NIS								-			2			
		HCV-8005TF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
189	HZZ -8006 TF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0024	-	Ex"d" / NIS								-			2			
		HCV-8006TF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
190	HZZ -8220 TF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS								-	TBD	TYPE-5	2			
		HCV-8220TF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
191	HZZ -8221 TF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS								-	TBD	TYPE-5	2			
		HCV-8221TF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
192	HZZ -8222 TF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS								-	TBD	TYPE-5	2			
		HCV-8222TF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
193	KT -8250ATF	KEY PHASER	P250001-PLK00C01001	-	Ex'd' / NIS				0	9999	rpm		-			2			
		PUMP P-851A KEY PHASER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
194	KT -8250BTF	KEY PHASER	P250001-PLK00C01001	-	Ex'd' / NIS				0	9999	rpm		-			2			
		PUMP P-851B KEY PHASER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
195	KT -8250CTF	KEY PHASER	P250001-PLK00C01001	-	Ex'd' / NIS				0	9999	rpm		-			2			
		PUMP P-851C KEY PHASER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
196	LCV -8002 TF	LEVEL CONTROL VALVE	PJ6-EXD-MRI-BQDA-0023	-	-							PJ6-EXD-GEN-YZ0H-0013-020	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-5B	2			
		MRD OIL SLUG CATCHER V-803TF OUTLET TO 3 PHASE SEPT	12"-PL-AC3N-8113	MRI	-							-	-	TBD					
197	LCV -8005 TF	LEVEL CONTROL VALVE	PJ6-EXD-MRI-BQDA-0024	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0013-023	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-5	2			
		3 PHASE SEPT TO PRODUCED WATER TREATMENT LCV	12"-PW-AL0N-8104	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
198	LCV -8008 TF	LEVEL CONTROL VALVE	PJ6-EXD-MRI-BQDA-0024	-	-							PJ6-EXD-GEN-YZ0H-0013-026	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-5	2			
		CRUDE OIL FRM MRD THREE PH. SEPARATOR TO NEW OIL HDR	10"-PL-AC3N-8116	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 19 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
199	LCV -8018 TF	LEVEL CONTROL VALVE	PJ6-EXD-MRI-BQDA-0021	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0013-029	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-5B	2			
		MRD MEA INLET SCRUBBER OUTLET	2"-CD-AC3N-8101	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
200	LCV -8209 TF	LEVEL CONTROL VALVE	PJ6-EXD-MRI-BQDA-0042	-	-							PJ6-EXD-GEN-YZ0H-0013-032	-	TBD	*	2			
		PROD. WATER OUTLET TO DISPOSAL WATER INJECTION WELL	12"-PW-DL0N-8110	MRI	-							-	-	TBD					
201	LG -8001 TF	LEVEL GAUGE - MAGNETIC	PJ6-EXD-MRI-BQDA-0023	V-803-TF	-							PJ6-EXD-GEN-YZ0H-0003-038	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		OIL SLUG CATC V803TF LEVEL	-	MRI	-							-	-	TBD					
202	LG -8002 TF	LEVEL GAUGE - MAGNETIC	PJ6-EXD-MRI-BQDA-0024	V-804-TF	-							PJ6-EXD-GEN-YZ0H-0003-039	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		3 PHASE SEPT LEVEL	-	MRI	-							-	-	TBD					
203	LG -8003 TF	LEVEL GAUGE - MAGNETIC	PJ6-EXD-MRI-BQDA-0024	V-804-TF	-							PJ6-EXD-GEN-YZ0H-0003-040	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		3 PHASE SEPT OIL LEVEL	-	MRI	-							-	-	TBD					
204	LG -8004 TF	LEVEL GAUGE - MAGNETIC	PJ6-EXD-MRI-BQDA-0021	V-806-TF	-							PJ6-EXD-GEN-YZ0H-0003-041	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		MEA INLET SCRB LEVEL	-	MRI	-							-	-	TBD					
205	LG -8050 TF	LEVEL GAUGE - MAGNETIC	PJ6-EXD-MRI-BQDA-0058	-	-						D	LG -8050 TF-SP	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		CHEMICAL INJECTION PACKAGE TANK T-8050TF LEVEL	-	MRI	-							-	-	TBD					
206	LG -8051 TF	LEVEL GAUGE - MAGNETIC	PJ6-EXD-MRI-BQDA-0058	-	-						D	LG -8051 TF-SP	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		CHEMICAL INJECTION PACKAGE TANK T-8051TF LEVEL	-	MRI	-							-	-	TBD					
207	LG -8200 TF	LEVEL GAUGE - MAGNETIC	PJ6-EXD-MRI-BQDA-0028	V-853-TF	-							PJ6-EXD-GEN-YZ0H-0003-042	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		DRAIN PIT V-853-TF LEVEL	-	MRI	-							-	-	TBD					
208	LG -8201 TF	LEVEL GAUGE - MAGNETIC	PJ6-EXD-MRI-BQDA-0028	V-854-TF	-							PJ6-EXD-GEN-YZ0H-0003-043	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		KNOCKOUT DRUM V-854-TF LEVEL	-	MRI	-							-	-	TBD					
209	LHD -9001 -M	LINEAR HEAT DETECTION CABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION DIST. TRF LINEAR HEAT DETECTION CABLE	-	SUB	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 20 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
210	LHD -9002 -M	LINEAR HEAT DETECTION CABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION DIST. TRF LINEAR HEAT DETECTION CABLE	-	SUB	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
211	LHD -9003 -M	LINEAR HEAT DETECTION CABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION DIST. TRF LINEAR HEAT DETECTION CABLE	-	SUB	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
212	LHD -9004 -M	LINEAR HEAT DETECTION CABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION DIST. TRF LINEAR HEAT DETECTION CABLE	-	SUB	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
213	LHD -9005 -M	LINEAR HEAT DETECTION CABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD		2			
		SUBSTATION DIST. TRF LINEAR HEAT DETECTION CABLE	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
214	LHD -9006 -M	LINEAR HEAT DETECTION CABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD		2			
		SUBSTATION DIST. TRF LINEAR HEAT DETECTION CABLE	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
215	LI -8002 TF	LOOP POWERED INDICATOR	PJ6-EXD-MRI-BQDA-0023	-	Ex"d" / NIS								-			2			
		OIL SLUG CATCHER V803TF LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
216	LI -8005 TF	LOOP POWERED INDICATOR	PJ6-EXD-MRI-BQDA-0024	V-804-TF	Ex"d" / NIS								-	TBD	*	2			
		3 PHASE SPTR LEVEL INTERFACE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
217	LI -8008 TF	LOOP POWERED INDICATOR	PJ6-EXD-MRI-BQDA-0024	V-804-TF	Ex"d" / NIS								-	TBD	-	2			
		3 PHASE SPTR OIL LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
218	LS -8200 TF	LEVEL SWITCH (VIBRATING FORK)	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		SLUDGE H V-851A-TF	-	MRI	-							-	-						
219	LS -8201 TF	LEVEL SWITCH (VIBRATING FORK)	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		SLUDGE L V-851A-TF	-	MRI	-							-	-						
220	LS -8202 TF	LEVEL SWITCH (VIBRATING FORK)	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		SLUDGE H V-851A-TF	-	MRI	-							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS		
		Instrument and F&G Index - Mubarraz Island														
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001		
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model		
221	LS -8203 TF	LEVEL SWITCH (VIBRATING FORK)	P250001-PLK00C01001	-	Ex"d" / NIS								-			2
		SLUDGE L V-851A-TF	-	MRI	-							-	-			
222	LS -8204 TF	LEVEL SWITCH (VIBRATING FORK)	P250001-PLK00C01001	-	Ex"d" / NIS								-			2
		SLUDGE H V-851B-TF	-	MRI	-							-	-			
223	LS -8205 TF	LEVEL SWITCH (VIBRATING FORK)	P250001-PLK00C01001	-	Ex"d" / NIS								-			2
		SLUDGE L V-851B-TF	-	MRI	-							-	-			
224	LS -8206 TF	LEVEL SWITCH (VIBRATING FORK)	P250001-PLK00C01001	-	Ex"d" / NIS								-			2
		SLUDGE H V-851B-TF	-	MRI	-							-	-			
225	LS -8207 TF	LEVEL SWITCH (VIBRATING FORK)	P250001-PLK00C01001	-	Ex"d" / NIS								-			2
		SLUDGE L V-851B-TF	-	MRI	-							-	-			
226	LS -8208 TF	LEVEL SWITCH (VIBRATING FORK)	P250001-PLK00C01001	-	Ex"d" / NIS								-			2
		SLUDGE H V-851C-TF	-	MRI	-							-	-			
227	LS -8209 TF	LEVEL SWITCH (VIBRATING FORK)	P250001-PLK00C01001	-	Ex"d" / NIS								-			2
		SLUDGE L V-851C-TF	-	MRI	-							-	-			
228	LS -8210 TF	LEVEL SWITCH (VIBRATING FORK)	P250001-PLK00C01001	-	Ex"d" / NIS								-			2
		SLUDGE H V-851C-TF	-	MRI	-							-	-			
229	LS -8211 TF	LEVEL SWITCH (VIBRATING FORK)	P250001-PLK00C01001	-	Ex"d" / NIS								-			2
		SLUDGE L V-851C-TF	-	MRI	-							-	-			
230	LT -8001ATF	LEVEL TRANSMITTER- GWR	PJ6-EXD-MRI-BQDA-0023	V-803-TF	Ex"d" / NIS				0	100	%	PJ6-EXD-GEN-YZ0H-0003-004	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2
		OIL SLUG CATC V803TF LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
231	LT -8001BTF	LEVEL TRANSMITTER- GWR	PJ6-EXD-MRI-BQDA-0023	V-803-TF	Ex"d" / NIS				0	100	%	PJ6-EXD-GEN-YZ0H-0003-006	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2
		OIL SLUG CATC V803TF LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS		
		Instrument and F&G Index - Mubarraz Island														
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001		
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model		
232	LT -8002 TF	LEVEL TRANSMITTER- GWR	PJ6-EXD-MRI-BQDA-0023	V-803-TF	Ex"d" / NIS				0	100	%	PJ6-EXD-GEN-YZ0H-0003-008	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2
		OIL SLUG CATC V803TF LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
233	LT -8003ATF	LEVEL TRANSMITTER- GWR	PJ6-EXD-MRI-BQDA-0023	V-803-TF	Ex"d" / NIS				0	100	%	PJ6-EXD-GEN-YZ0H-0003-010	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2
		OIL SLUG CATC V803TF LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
234	LT -8003BTF	LEVEL TRANSMITTER- GWR	PJ6-EXD-MRI-BQDA-0023	V-803-TF	Ex"d" / NIS				0	100	%	PJ6-EXD-GEN-YZ0H-0003-012	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2
		OIL SLUG CATC V803TF LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
235	LT -8004ATF	LEVEL TRANSMITTER- GWR	PJ6-EXD-MRI-BQDA-0024	V-804-TF	Ex"d" / NIS				0	100	%	PJ6-EXD-GEN-YZ0H-0003-014	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2
		3 PHASE SEPT LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
236	LT -8004BTF	LEVEL TRANSMITTER- GWR	PJ6-EXD-MRI-BQDA-0024	V-804-TF	Ex"d" / NIS				0	100	%	PJ6-EXD-GEN-YZ0H-0003-016	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2
		3 PHASE SEPT LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
237	LT -8005 TF	LEVEL TRANSMITTER- GWR	PJ6-EXD-MRI-BQDA-0024	V-804-TF	Ex"d" / NIS				0	100	%	PJ6-EXD-GEN-YZ0H-0003-018	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2
		3 PHASE SEPT LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
238	LT -8006ATF	LEVEL TRANSMITTER- GWR	PJ6-EXD-MRI-BQDA-0024	V-804-TF	Ex"d" / NIS				0	100	%	PJ6-EXD-GEN-YZ0H-0003-020	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2
		3 PHASE SEPT OIL LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
239	LT -8006BTF	LEVEL TRANSMITTER- GWR	PJ6-EXD-MRI-BQDA-0024	V-804-TF	Ex"d" / NIS				0	100	%	PJ6-EXD-GEN-YZ0H-0003-022	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2
		3 PHASE SEPT OIL LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
240	LT -8007ATF	LEVEL TRANSMITTER- GWR	PJ6-EXD-MRI-BQDA-0024	V-804-TF	Ex"d" / NIS				0	100	%	PJ6-EXD-GEN-YZ0H-0003-024	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2
		3 PHASE SEPT OIL LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
241	LT -8007BTF	LEVEL TRANSMITTER- GWR	PJ6-EXD-MRI-BQDA-0024	V-804-TF	Ex"d" / NIS				0	100	%	PJ6-EXD-GEN-YZ0H-0003-026	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2
		3 PHASE SEPT OIL LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
242	LT -8008 TF	LEVEL TRANSMITTER- GWR	PJ6-EXD-MRI-BQDA-0024	V-804-TF	Ex"d" / NIS				0	100	%	PJ6-EXD-GEN-YZ0H-0003-028	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2
		3 PHASE SEPT OIL LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 23 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
243	LT -8015 TF	LEVEL TRANSMITTER- GWR	PJ6-EXD-MRI-BQDA-0021	V-806-TF	Ex"d" / NIS				0	100	%	PJ6-EXD-GEN-YZ0H-0003-030	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		MEA INLET SCRB LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
244	LT -8017 TF	LEVEL TRANSMITTER- GWR	PJ6-EXD-MRI-BQDA-0021	V-806-TF	Ex"d" / NIS				0	100	%	PJ6-EXD-GEN-YZ0H-0003-032	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		MEA INLET SCRB LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
245	LT -8018 TF	LEVEL TRANSMITTER- GWR	PJ6-EXD-MRI-BQDA-0021	V-806-TF	Ex"d" / NIS				0	100	%	PJ6-EXD-GEN-YZ0H-0003-034	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		MEA INLET SCRB LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
246	LT -8019 TF	LEVEL TRANSMITTER- GWR	PJ6-EXD-MRI-BQDA-0023	V-803-TF	Ex"d" / NIS				0	100	%	PJ6-EXD-GEN-YZ0H-0003-036	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		OIL SLUG CATC V803TF LEVEL	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
247	LT -8050 TF	DP LEVEL TRANSMITTER - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0058	T-8050TF	Ex"d" / NIS				0	100	%		-			2			
		CHEMICAL INJECTION PACKAGE TANK T-8050TF LEVEL	-	MRI	LOOP POWERED							-	-						
248	LT -8051 TF	DP LEVEL TRANSMITTER - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0058	T-8051TF	Ex"d" / NIS				0	100	%		-			2			
		CHEMICAL INJECTION PACKAGE TANK T-8051TF LEVEL	-	MRI	LOOP POWERED							-	-						
249	LT -8200 TF	LEVEL TRANSMITTER- GWR	P250001-PLK00C01001	-	Ex"d" / NIS				0	100	%		-			2			
		OIL/WATER INTERFACE V-851A-TF	-	MRI	-							-	-						
250	LT -8201 TF	LEVEL TRANSMITTER- GWR	P250001-PLK00C01001	-	Ex"d" / NIS				0	100	%		-			2			
		OIL/WATER INTERFACE V-851A-TF (SAFETY)	-	MRI	-							-	-						
251	LT -8202 TF	LEVEL TRANSMITTER- GWR	P250001-PLK00C01001	-	Ex"d" / NIS				0	100	%		-			2			
		GAS/OIL INTERFACE V-851A-TF	-	MRI	-							-	-						
252	LT -8203 TF	LEVEL TRANSMITTER- GWR	P250001-PLK00C01001	-	Ex"d" / NIS				0	100	%		-			2			
		OIL/WATER INTERFACE V-851B-TF	-	MRI	-							-	-						
253	LT -8204 TF	LEVEL TRANSMITTER- GWR	P250001-PLK00C01001	-	Ex"d" / NIS				0	100	%		-			2			
		OIL/WATER INTERFACE V-851B-TF (SAFETY)	-	MRI	-							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 24 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
254	LT -8205 TF	LEVEL TRANSMITTER- GWR	P250001-PLK00C01001	-	Ex"d" / NIS				0	100	%		-			2			
		GAS/OIL INTERFACE V-851B-TF	-	MRI	-							-	-						
255	LT -8206 TF	LEVEL TRANSMITTER- GWR	P250001-PLK00C01001	-	Ex"d" / NIS				0	100	%		-			2			
		OIL/WATER INTERFACE V-851C-TF	-	MRI	-							-	-						
256	LT -8207 TF	LEVEL TRANSMITTER- GWR	P250001-PLK00C01001	-	Ex"d" / NIS				0	100	%		-			2			
		OIL/WATER INTERFACE V-851C-TF (SAFETY)	-	MRI	-							-	-						
257	LT -8208 TF	LEVEL TRANSMITTER- GWR	P250001-PLK00C01001	-	Ex"d" / NIS				0	100	%		-			2			
		GAS/OIL INTERFACE V-851C-TF	-	MRI	-							-	-						
258	LT -8209 TF	LEVEL TRANSMITTER- GWR	P250001-PLK00C01001	-	Ex"d" / NIS				0	100	%		-			2			
		WATER LEVEL V-852-TF	-	MRI	-							-	-						
259	LT -8210 TF	LEVEL TRANSMITTER- GWR	P250001-PLK00C01001	-	Ex"d" / NIS				0	100	%		-			2			
		WATER LEVEL V-852-TF (SAFETY)	-	MRI	-							-	-						
260	LT -8211 TF	LEVEL TRANSMITTER- GWR	P250001-PLK00C01001	-	Ex"d" / NIS				0	100	%		-			2			
		WATER LEVEL V-852-TF (SAFETY)	-	MRI	-							-	-						
261	LT -8212 TF	DP LEVEL TRANSMITTER - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0028	V-853-TF	Ex'd' / NIS			mm	0	100	%	PJ6-EXD-GEN-YZ0H-0005-137	-	TBD		2			
		DRAIN PIT V-853-TF LEVEL	-	MRI	LOOP POWERED							-	-	TBD					
262	LT -8213 TF	DP LEVEL TRANSMITTER - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0028	V-854-TF	Ex'd' / NIS			mm	0	100	%	PJ6-EXD-GEN-YZ0H-0005-138	-	TBD		2			
		KNOCKOUT DRUM V-854-TF LEVEL	-	MRI	LOOP POWERED							-	-	TBD					
263	LY -8002 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0023	-	Ex"d" / NIS								-			2			
		OIL SLUG CATCHER V803TF OUTLET LCV POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
264	LY -8005 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0024	LCV-8005TF	Ex"d" / NIS								-	TBD	TYPE-5	2			
		LCV-8005TF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 25 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
265	LY -8008 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0024	-	Ex"d" / NIS								-	TBD	TYPE-5	2			
		LCV-8008TF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
266	LY -8018 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0021	LCV-8057TF	Ex"d" / NIS								-	TBD	TYPE-5B	2			
		LCV-8018TF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
267	LY -8209 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS								-			2			
		LCV-8209TF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
268	LZT -8005 TF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0024	LCV-8005TF	Ex"d" / NIS								-	TBD	TYPE-5	2			
		LCV-8005TF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
269	LZT -8008 TF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0024	-	Ex"d" / NIS								-	TBD	TYPE-5	2			
		LCV-8008TF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
270	MCP -6006 -M	MANUAL CALL POINT	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SLUG CATCHER AREA MANUAL CALL POINT	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
271	MCP -6008 -M	MANUAL CALL POINT	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SOUR GAS COMPRESSOR AREA MANUAL CALL POINT	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
272	MCP -9004 -M	MANUAL CALL POINT	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG MANUAL CALL POINT	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
273	MCP -9006 -M	MANUAL CALL POINT	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG BATTERY ROOM MANUAL CALL POINT	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
274	MCP -9501-M	MANUAL CALL POINT	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		PWT AREA MANUAL CALL POINT	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
275	MHKH -8050 TF	MOTOR - REMOTE START	PJ6-EXD-MRI-BQDA-0058	-	NIS								-			2			
		CHEMICAL INJECTION PACKAGE PMP P-8050TF START CMD	-	MRI	2 WIRE							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 26 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
276	MHKH -8051 TF	MOTOR - REMOTE START	PJ6-EXD-MRI-BQDA-0058	-	NIS								-			2			
		CHEMICAL INJECTION PACKAGE PMP P-8051TF START CMD	-	MRI	2 WIRE							-	-						
277	MHKH -851 ATF	MOTOR - REMOTE START	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851A-TF START CMD	-	MRI	2 WIRE							-	-						
278	MHKH -851 BTF	MOTOR - REMOTE START	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851B-TF START CMD	-	MRI	2 WIRE							-	-						
279	MHKH -851 CTF	MOTOR - REMOTE START	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851C-TF START CMD	-	MRI	2 WIRE							-	-						
280	MHKL -8050 TF	MOTOR - REMOTE STOP	PJ6-EXD-MRI-BQDA-0058	-	NIS								-			2			
		CHEMICAL INJECTION PACKAGE PMP P-8050TF STOP CMD	-	MRI	2 WIRE							-	-						
281	MHKL -8051 TF	MOTOR - REMOTE STOP	PJ6-EXD-MRI-BQDA-0058	-	NIS								-			2			
		CHEMICAL INJECTION PACKAGE PMP P-8051TF STOP CMD	-	MRI	2 WIRE							-	-						
282	MHKL -851 ATF	MOTOR - REMOTE STOP	PJ6-EXD-MRI-BQDA-0042	-	NIS								-	TBD		2			
		PWDP PUMP P-851A-TF STOP CMD	-	MRI	2 WIRE							-	-						
283	MHKL -851 BTF	MOTOR - REMOTE STOP	PJ6-EXD-MRI-BQDA-0042	-	NIS								-	TBD		2			
		PWDP PUMP P-851B-TF STOP CMD	-	MRI	2 WIRE							-	-						
284	MHKL -851 CTF	MOTOR - REMOTE STOP	PJ6-EXD-MRI-BQDA-0042	-	NIS								-	TBD		2			
		PWDP PUMP P-851C-TF STOP CMD	-	MRI	2 WIRE							-	-						
285	MHKM -851 ATF	AUTO/MANUAL SELECTION	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851A-TF AUTO MANUAL SELECTION	-	MRI	2 WIRE							-	-						
286	MHKM -851 BTF	AUTO/MANUAL SELECTION	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851A-TF AUTO MANUAL SELECTION	-	MRI	2 WIRE							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 27 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
287	MHKM -851 CTF	AUTO/MANUAL SELECTION	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851A-TF AUTO MANUAL SELECTION	-	MRI	2 WIRE							-	-						
288	MHKR -8050 TF	MOTOR - LOCAL/REMOTE STATUS	PJ6-EXD-MRI-BQDA-0058	-	NIS								-			2			
		CHEM INJ PACKAGE PMP P-8050TF LOCAL REMOTE STATUS	-	MRI	2 WIRE							-	-						
289	MHKR -8051 TF	MOTOR - LOCAL/REMOTE STATUS	PJ6-EXD-MRI-BQDA-0058	-	NIS								-			2			
		CHEM INJ PACKAGE PMP P-8051TF LOCAL REMOTE STATUS	-	MRI	2 WIRE							-	-						
290	MHKR -851 ATF	MOTOR - LOCAL/REMOTE STATUS	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851A-TF LOCAL REMOTE STATUS	-	MRI	2 WIRE							-	-						
291	MHKR -851 BTF	MOTOR - LOCAL/REMOTE STATUS	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851B-TF LOCAL REMOTE STATUS	-	MRI	2 WIRE							-	-						
292	MHKR -851 CTF	MOTOR - LOCAL/REMOTE STATUS	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851C-TF LOCAL REMOTE STATUS	-	MRI	2 WIRE							-	-						
293	MHSC -8003 TF	CLOSE COMMAND	PJ6-EXD-MRI-BQDA-0022	-	Ex"d" / NIS								-			2			
		MOV-08003TF CLOSE CMD	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-						
294	MHSO -8003 TF	OPEN COMMAND	PJ6-EXD-MRI-BQDA-0022	-	Ex"d" / NIS								-			2			
		MOV-8003TF OPEN CMD	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-						
295	MOV -8001 TF	MOTORISED OPERATED VALVE	PJ6-EXD-MRI-BQDA-0022	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0012-059	-	TBD	TYPE-2B	2			
		PIG RCVR INLET LINE MOV	-	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
296	MOV -8002 TF	MOTORISED OPERATED VALVE	PJ6-EXD-MRI-BQDA-0022	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0012-061	-	TBD	TYPE-2B	2			
		PIG RCVR INLET LINE MOV	-	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
297	MOV -8003 TF	MOTORISED OPERATED VALVE	PJ6-EXD-MRI-BQDA-0022	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0012-063	-	TBD	TYPE-2	2			
		PIG RCVR OUTLET LINE MOV	20"-PL-DC3N-8106	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البيان) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 28 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
298	MOZT -8003 TF	POSITION TRANSMITTER - MOV	PJ6-EXD-MRI-BQDA-0022	MOV-8003TF	Ex"d" / NIS				0	100	%		-			2			
		MOV-8003TF POSITION INDICATION	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-						
299	MXA -8001 TF	FAULT STATUS	PJ6-EXD-MRI-BQDA-0022	-	NIS								-			2			
		MOV-8001TF FAULT	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-						
300	MXA -8002 TF	FAULT STATUS	PJ6-EXD-MRI-BQDA-0022	-	NIS								-			2			
		MOV-8002TF FAULT	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-						
301	MXA -8003 TF	FAULT STATUS	PJ6-EXD-MRI-BQDA-0022	-	NIS								-			2			
		MOV-8003TF FAULT	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-						
302	MXL -8003 TF	LOCAL / REMOTE STATUS	PJ6-EXD-MRI-BQDA-0022	-	Ex"d" / NIS								-			2			
		MOV-8003TF L/R STS	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-						
303	MXS -8050 TF	MOTOR - TRIP COMMAND	PJ6-EXD-MRI-BQDA-0058	-	NIS								-			2			
		CHEMICAL INJECTION PACKAGE PUMP P-8050TF TRIP CMD	-	MRI	2 WIRE							-	-						
304	MXS -8051 TF	MOTOR - TRIP COMMAND	PJ6-EXD-MRI-BQDA-0058	-	NIS								-			2			
		CHEMICAL INJECTION PACKAGE PUMP P-8051TF TRIP CMD	-	MRI	2 WIRE							-	-						
305	MXS -851 ATF	MOTOR - TRIP COMMAND	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851A-TF TRIP CMD	-	MRI	2 WIRE							-	-						
306	MXS -851 BTF	MOTOR - TRIP COMMAND	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851B-TF TRIP CMD	-	MRI	2 WIRE							-	-						
307	MXS -851 CTF	MOTOR - TRIP COMMAND	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851C-TF TRIP CMD	-	MRI	2 WIRE							-	-						
308	MXX -8003 TF	POSITION COMMAND	PJ6-EXD-MRI-BQDA-0022	-	Ex'd' / NIS								-			2			
		MOV-08003TF POSITION COMMAND	-	MRI	-							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 29 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
309	MYA -8050 TF	MOTOR FAULT ALARM	PJ6-EXD-MRI-BQDA-0058	-	NIS								-			2			
		CHEM INJ PACKAGE PMP P-8050TF FAULT ALARM	-	MRI	2 WIRE							-	-						
310	MYA -8051 TF	MOTOR FAULT ALARM	PJ6-EXD-MRI-BQDA-0058	-	NIS								-			2			
		CHEM INJ PACKAGE PMP P-8051TF FAULT ALARM	-	MRI	2 WIRE							-	-						
311	MYA -851 ATF	MOTOR FAULT ALARM	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851A-TF FAULT ALARM	-	MRI	2 WIRE							-	-						
312	MYA -851 BTF	MOTOR FAULT ALARM	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851B-TF FAULT ALARM	-	MRI	2 WIRE							-	-						
313	MYA -851 CTF	MOTOR FAULT ALARM	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851C-TF FAULT ALARM	-	MRI	2 WIRE							-	-						
314	MYL -8050 TF	MOTOR - RUNNING STATUS	PJ6-EXD-MRI-BQDA-0058	-	NIS								-			2			
		CHEM INJ PACKAGE PMP P-8050TF RUNNING STATUS	-	MRI	2 WIRE							-	-						
315	MYL -8051 TF	MOTOR - RUNNING STATUS	PJ6-EXD-MRI-BQDA-0058	-	NIS								-			2			
		CHEM INJ PACKAGE PMP P-8051TF RUNNING STATUS	-	MRI	2 WIRE							-	-						
316	MYL -851 ATF	MOTOR - ON/OFF STATUS	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851A-TF RUNNING STATUS	-	MRI	2 WIRE							-	-						
317	MYL -851 BTF	MOTOR - ON/OFF STATUS	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851B-TF RUNNING STATUS	-	MRI	2 WIRE							-	-						
318	MYL -851 CTF	MOTOR - ON/OFF STATUS	PJ6-EXD-MRI-BQDA-0042	-	NIS								-			2			
		PWDP PUMP P-851C-TF RUNNING STATUS	-	MRI	2 WIRE							-	-						
319	MZSC -8001 TF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0022	MOV-8001TF	Ex"d" / NIS								-	TBD	TYPE-2B	2			
		MOV-8001TF CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البيان) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 30 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
320	MZSC -8002 TF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0022	MOV-8002TF	Ex"d" / NIS								-	TBD	TYPE-2B	2			
		MOV-8002TF CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
321	MZSC -8003 TF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0022	MOV-8003TF	Ex"d" / NIS								-	TBD	TYPE-2	2			
		MOV-8003TF CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
322	MZSO -8001 TF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0022	MOV-8001TF	Ex"d" / NIS								-	TBD	TYPE-2B	2			
		MOV-8001TF OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
323	MZSO -8002 TF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0022	MOV-8002TF	Ex"d" / NIS								-	TBD	TYPE-2B	2			
		MOV-8002TF OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
324	MZSO -8003 TF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0022	MOV-8003TF	Ex"d" / NIS								-	TBD	TYPE-2	2			
		MOV-8003TF OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
325	PCV -8004ATF	PRESSURE CONTROL VALVE	PJ6-EXD-MRI-BQDA-0023	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0013-005	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-5	2			
		MRD OIL SLUG CATCHER V-803-TF TO HAIL FLARE HDR	6"-SG-AC3N-8113	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
326	PCV -8004BTF	PRESSURE CONTROL VALVE	PJ6-EXD-MRI-BQDA-0023	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0013-008	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-5	2			
		MRD OIL SLUG CATCHER V-803TF TO MEA INLET SCRUBBER	6"-SG-AC3N-8112	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
327	PCV -8006ATF	PRESSURE CONTROL VALVE	PJ6-EXD-MRI-BQDA-0024	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0013-011	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-5	2			
		MRD GAS THREE PH. SEPARATOR V-804-TF TO HAIL FLARE	3"-SG-AC3N-8117	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
328	PCV -8006BTF	PRESSURE CONTROL VALVE	PJ6-EXD-MRI-BQDA-0024	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0013-014	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-5	2			
		MRD GAS THREE PH. SEPARATOR V-804-TF TO MRD MEA SCRB	3"-SG-AC3N-8116	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
329	PCV -8009 TF	PRESSURE CONTROL VALVE	PJ6-EXD-MRI-BQDA-0026	-	Ex'd' / NIS								-	TBD	TYPE-5 (BY PACKAGE VENDOR) (Note-5)	2			
		SWEET GAS CMPSR INLET SCRB OUTLET PCV	3"	MRI	-							-	-	TBD					
330	PCV -8010 TF	PRESSURE CONTROL VALVE	PJ6-EXD-MRI-BQDA-0026	-	Ex'd' / NIS								-	TBD	TYPE-5 (BY PACKAGE VENDOR) (Note-5)	2			
		SWEET GAS CMPSR OUTLET SCRB OUTLET PCV	3"	MRI	-							-	-	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 31 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
331	PCV -8017 TF	PRESSURE CONTROL VALVE	PJ6-EXD-MRI-BQDA-0021	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0013-017	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-5	2			
		MEA INLET SCRB OUTLET TO FLARE PCV	10"-SG-AC3N-8173	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
332	PG -017 CTF	PRESSURE GAUGE - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0025	-	-				0	100	psi G	PJ6-EXD-GEN-YZ0H-0006-068	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		SOUR GAS COMPRESSOR OUTLET PRESSURE	6"-SG-AC3N-8103	MRI	-							-	-	TBD					
333	PG -121B TF	PRESSURE GAUGE	4RC31303 / 1RC20650	-	-				0	100	psi G	PJ6-EXD-GEN-YZ0H-0006-095	-	TBD	*	2			
		1ST STAGE SUCT. GAS PRESS.	-	MRI	-							-	-	TBD					
334	PG -122 TF	PRESSURE GAUGE	4RC31303 / 1RC20650	-	-				0	200	psi G	PJ6-EXD-GEN-YZ0H-0006-096	-	TBD	*	2			
		1ST STAGE DISCH. GAS PRESS.	-	MRI	-							-	-	TBD					
335	PG -123B TF	PRESSURE GAUGE	4RC31303 / 1RC20650	-	-				0	200	psi G	PJ6-EXD-GEN-YZ0H-0006-097	-	TBD	*	2			
		2ND STAGE SUCT. GAS PRESS.	-	MRI	-							-	-	TBD					
336	PG -124 TF	PRESSURE GAUGE	4RC31303 / 1RC20650	-	-				0	600	psi G	PJ6-EXD-GEN-YZ0H-0006-098	-	TBD	*	2			
		2ND STAGE DISCH. GAS PRESS.	-	MRI	-							-	-	TBD					
337	PG -8001 TF	PRESSURE GAUGE - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0022	V-805-TF	-				0	250	psi G	PJ6-EXD-GEN-YZ0H-0006-069	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		PIG RECEIVER V-805-TF PRESSURE	-	MRI	-							-	-	TBD					
338	PG -8002 TF	PRESSURE GAUGE - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0022	V-805-TF	-				0	250	psi G	PJ6-EXD-GEN-YZ0H-0006-070	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		PIG RECEIVER V-805-TF PRESSURE	-	MRI	-							-	-	TBD					
339	PG -8003 TF	PRESSURE GAUGE - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0022	-	-				0	250	psi G	PJ6-EXD-GEN-YZ0H-0006-071	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		PIG RECEIVER V-805-TF OUTLET LINE PRESSURE	20"-PL-DC3N-8106	MRI	-							-	-	TBD					
340	PG -8004 TF	PRESSURE GAUGE - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0023	V-803-TF	-				0	250	psi G	PJ6-EXD-GEN-YZ0H-0006-072	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		OIL SLUG CATCHER V-803-TF PRESSURE	-	MRI	-							-	-	TBD					
341	PG -8005 TF	PRESSURE GAUGE - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0024	V-804-TF	-				0	200	psi G	PJ6-EXD-GEN-YZ0H-0006-073	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		3 PHASE SEPT V-804-TF PRESSURE	-	MRI	-							-	-	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 32 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
342	PG -8006 TF	PRESSURE GAUGE - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0021	V-806-TF	-				0	100	psi G	PJ6-EXD-GEN-YZ0H-0006-074	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		MEA INLET SCRB V-806-TF PRESSURE	-	MRI	-							-	-	TBD					
343	PG -8050 TF	PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0058	-	-				0	1500	psi G	PG -8050 TF-SP	-	TBD	*	2			
		CHEM INJ PACKAGE PMP P-8050TF PRESSURE	-	MRI	-							-	-	TBD					
344	PG -8051 TF	PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0058	-	-				0	1500	psi G	PG -8051 TF-SP	-	TBD	*	2			
		CHEM INJ PACKAGE PMP P-8051TF PRESSURE	-	MRI	-							-	-	TBD					
345	PG -8210ATF	PRESSURE GAUGE - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0042	-	-				0	15	psi G	PJ6-EXD-GEN-YZ0H-0006-075	-	TBD	*	2			
		MRD PROD WATER DISPOSAL PMP (P-851A-TF) SUCTION LINE	12"-PW-DL0N-8714	MRI	-							-	-	TBD					
346	PG -8210BTF	PRESSURE GAUGE - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0042	-	-				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0006-076	-	TBD	*	2			
		MRD PROD WATER DISPOSAL PMP (P-851A-TF) DISCHRG LINE	10"-PW-DL0N-8703	MRI	-							-	-	TBD					
347	PG -8211ATF	PRESSURE GAUGE - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0042	-	-				0	15	psi G	PJ6-EXD-GEN-YZ0H-0006-077	-	TBD	*	2			
		MRD PROD WATER DISPOSAL PMP (P-851B-TF) SUCTION LINE	12"-PW-DL0N-8715	MRI	-							-	-	TBD					
348	PG -8211BTF	PRESSURE GAUGE - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0042	-	-				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0006-078	-	TBD	*	2			
		MRD PROD WATER DISPOSAL PMP (P-851B-TF) DISCHRG LINE	10"-PW-DL0N-8704	MRI	-							-	-	TBD					
349	PG -8212ATF	PRESSURE GAUGE - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0042	-	-				0	15	psi G	PJ6-EXD-GEN-YZ0H-0006-079	-	TBD	*	2			
		MRD PROD WATER DISPOSAL PMP (P-851C-TF) SUCTION LINE	12"-PW-DL0N-8716	MRI	-							-	-	TBD					
350	PG -8212BTF	PRESSURE GAUGE - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0042	-	-				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0006-080	-	TBD	*	2			
		MRD PROD WATER DISPOSAL PMP (P-851C-TF) DISCHRG LINE	10"-PW-DL0N-8705	MRI	-							-	-	TBD					
351	PG -8213 TF	PRESSURE GAUGE - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0028	V-853-TF	-				0	15	psi G	PJ6-EXD-GEN-YZ0H-0006-081	-	TBD	*	2			
		KNOCKOUT DRUM V-853-TF	-	MRI	-							-	-	TBD					
352	PG -8214 TF	PRESSURE GAUGE - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0028	V-853-TF	-				0	15	psi G	PJ6-EXD-GEN-YZ0H-0006-082	-	TBD	*	2			
		KNOCKOUT DRUM V-853-TF	-	MRI	-							-	-	TBD					

FD شركة نفط أبوظبي المحدودة (اليابان) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 33 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
353	PG -8215 TF	PRESSURE GAUGE - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0028	V-854-TF	-				0	160	psi G	PJ6-EXD-GEN-YZ0H-0006-083	-	TBD	*	2			
		KNOCKOUT DRUM V-854-TF	-	MRI	-							-	-	TBD					
354	PG -8216 TF	PRESSURE GAUGE - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0028	V-854-TF	-				0	160	psi G	PJ6-EXD-GEN-YZ0H-0006-084	-	TBD	*	2			
		KNOCKOUT DRUM V-854-TF	-	MRI	-							-	-	TBD					
355	PG -8220 TF	PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0042	WD-10	-				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0006-085	-	TBD	*	2			
		WATER DISPOSAL WELL 10	-	MRI	-							-	-	TBD					
356	PG -8221 TF	PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0042	WD-10	-				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0006-086	-	TBD	*	2			
		WATER DISPOSAL WELL 10	-	MRI	-							-	-	TBD					
357	PG -8222 TF	PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0042	WD-10	-				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0006-087	-	TBD	*	2			
		WATER DISPOSAL WELL 10	-	MRI	-							-	-	TBD					
358	PG -8230 TF	PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0042	WD-11	-				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0006-088	-	TBD	*	2			
		WATER DISPOSAL WELL 11	-	MRI	-							-	-	TBD					
359	PG -8231 TF	PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0042	WD-11	-				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0006-089	-	TBD	*	2			
		WATER DISPOSAL WELL 11	-	MRI	-							-	-	TBD					
360	PG -8232 TF	PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0042	WD-11	-				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0006-090	-	TBD	*	2			
		WATER DISPOSAL WELL 11	-	MRI	-							-	-	TBD					
361	PG -8240 TF	PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0042	WD-12	-				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0006-091	-	TBD	*	2			
		WATER DISPOSAL WELL 12	-	MRI	-							-	-	TBD					
362	PG -8241 TF	PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0042	WD-12	-				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0006-092	-	TBD	*	2			
		WATER DISPOSAL WELL 12	-	MRI	-							-	-	TBD					
363	PG -8242 TF	PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0042	WD-12	-				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0006-093	-	TBD	*	2			
		WATER DISPOSAL WELL 12	-	MRI	-							-	-	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 34 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
364	PRV -8001	PRESSURE REGULATOR	PJ6-EXD-MRI-BQDA-0028	-	-							PJ6-EXD-GEN-YZ0H-0013-065	-	BY VDR		2			
		UTILITY WATER	2"-UW-AG1-8101	MRI	-							-	-	BY VDR					
365	PSV -8001 TF	PRESSURE SAFETY VALVE	PJ6-EXD-MRI-BQDA-0022	-	-							PJ6-EXD-GEN-YZ0H-0002-010	-	TBD	*	2			
		PIG RCVR TO FLARE PSV	3"-PL-DC3N-8104	MRI	-							-	-	TBD					
366	PSV -8002 TF	PRESSURE SAFETY VALVE	PJ6-EXD-MRI-BQDA-0023	-	-							PJ6-EXD-GEN-YZ0H-0002-012	-	TBD	*	2			
		OIL SLUG CATC TO FLARE PSV	4"-SG-AC3N-8111	MRI	-							-	-	TBD					
367	PSV -8003 TF	PRESSURE SAFETY VALVE	PJ6-EXD-MRI-BQDA-0023	-	-							PJ6-EXD-GEN-YZ0H-0002-013	-	TBD	*	2			
		OIL SLUG CATC TO FLARE PSV	4"-SG-AC3N-8111	MRI	-							-	-	TBD					
368	PSV -8004 TF	PRESSURE SAFETY VALVE	PJ6-EXD-MRI-BQDA-0024	-	-							PJ6-EXD-GEN-YZ0H-0002-014	-	TBD	*	2			
		3 PHASE SEPT TO FLARE PSV	2"-SG-AC3N-8115	MRI	-							-	-	TBD					
369	PSV -8005 TF	PRESSURE SAFETY VALVE	PJ6-EXD-MRI-BQDA-0024	-	-							PJ6-EXD-GEN-YZ0H-0002-015	-	TBD	*	2			
		3 PHASE SEPT TO FLARE PSV	2"-SG-AC3N-8115	MRI	-							-	-	TBD					
370	PSV -8006 TF	PRESSURE SAFETY VALVE	PJ6-EXD-MRI-BQDA-0021	-	-							PJ6-EXD-GEN-YZ0H-0002-016	-	TBD	*	2			
		NEW MEA INLET SCRB TO FLARE PSV	12"-SG-AC3N-8128	MRI	-							-	-	TBD					
371	PSV -8007 TF	PRESSURE SAFETY VALVE	PJ6-EXD-MRI-BQDA-0021	-	-							PJ6-EXD-GEN-YZ0H-0002-017	-	TBD	*	2			
		NEW MEA INLET SCRB TO FLARE PSV	12"-SG-AC3N-8128	MRI	-							-	-	TBD					
372	PSV -8008 TF	PRESSURE SAFETY VALVE	PJ6-EXD-MRI-BQDA-0022	-	-							PJ6-EXD-GEN-YZ0H-0002-011	-	TBD		2			
		PIG RCVR TO FLARE PSV	3"-PL-DC3N-8104	MRI	-							-	-	TBD					
373	PSV -8050 TF	PRESSURE SAFETY VALVE	PJ6-EXD-MRI-BQDA-0058	-	-						D	PSV -8050 TF-SP	-	TBD	*	2			
		CHEMICAL INJ PACKAGE PUMP TO STORAGE TANK	-	MRI	-							-	-	TBD					
374	PSV -8051 TF	PRESSURE SAFETY VALVE	PJ6-EXD-MRI-BQDA-0058	-	-						D	PSV -8051 TF-SP	-	TBD	*	2			
		CHEMICAL INJ PACKAGE PUMP TO STORAGE TANK	-	MRI	-							-	-	TBD					

 شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)																	
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 35 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
375	PT -8001ATF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0022	-	Ex"d" / NIS				0	300	psi G	PJ6-EXD-GEN-YZ0H-0005-090	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		FRM PIG LNCR CFP-MRI LINE PRESSURE	30" MULTIPHASE PIPELINE APL 5L GR X65	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
376	PT -8001BTF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0022	-	Ex"d" / NIS				0	300	psi G	PJ6-EXD-GEN-YZ0H-0005-091	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		FRM PIG LNCR CFP-MRI LINE PRESSURE	30" MULTIPHASE PIPELINE APL 5L GR X65	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
377	PT -8001CTF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0022	-	Ex"d" / NIS				0	300	psi G	PJ6-EXD-GEN-YZ0H-0005-092	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		FRM PIG LNCR CFP-MRI LINE PRESSURE	30" MULTIPHASE PIPELINE APL 5L GR X65	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
378	PT -8002 TF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0022	-	Ex"d" / NIS				0	300	psi G	PJ6-EXD-GEN-YZ0H-0005-093	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		FRM PIG LNCR CFP-MRI LINE PRESSURE	30" MULTIPHASE PIPELINE APL 5L GR X65	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
379	PT -8003ATF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0023	V-803-TF	Ex"d" / NIS				0	300	psi G	PJ6-EXD-GEN-YZ0H-0005-094	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		OIL SLUG CATC V803TF PRESSURE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
380	PT -8003BTF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0023	V-803-TF	Ex"d" / NIS				0	300	psi G	PJ6-EXD-GEN-YZ0H-0005-095	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		OIL SLUG CATC V803TF PRESSURE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
381	PT -8004 TF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0023	V-803-TF	Ex"d" / NIS				0	300	psi G	PJ6-EXD-GEN-YZ0H-0005-096	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		OIL SLUG CATC V803TF PRESSURE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
382	PT -8005 TF	PRESSURE TRANSMITTER - WIRELESS	PJ6-EXD-MRI-BQDA-0023	-	Ex"d" / NIS				0	300	psi G	PJ6-EXD-GEN-YZ0H-0005-115	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		OIL SLUG CATC TO MEA INLET SCRB PRESSURE	6"-SG-AC3N-8112	MRI	-							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
383	PT -8006 TF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0024	V-804-TF	Ex"d" / NIS				0	200	psi G	PJ6-EXD-GEN-YZ0H-0005-097	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		3 PHASE SEPT PRESSURE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
384	PT -8007ATF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0024	V-804-TF	Ex"d" / NIS				0	200	psi G	PJ6-EXD-GEN-YZ0H-0005-098	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		3 PHASE SEPT PRESSURE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
385	PT -8007BTF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0024	V-804-TF	Ex"d" / NIS				0	200	psi G	PJ6-EXD-GEN-YZ0H-0005-099	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		3 PHASE SEPT PRESSURE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 36 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
386	PT -8008 TF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0024	V-804-TF	Ex"d" / NIS				0	200	psi G	PJ6-EXD-GEN-YZ0H-0005-117	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		3 PHASE SEPT V804TF TO NEW MEA SCRB PRESSURE	-	MRI	-							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
387	PT -8016ATF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0021	V-806-TF	Ex"d" / NIS				0	100	psi G	PJ6-EXD-GEN-YZ0H-0005-100	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		MEA INLET SCRB PRESSURE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
388	PT -8016BTF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0021	V-806-TF	Ex"d" / NIS				0	100	psi G	PJ6-EXD-GEN-YZ0H-0005-101	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		MEA INLET SCRB PRESSURE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
389	PT -8017 TF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0021	V-806-TF	Ex"d" / NIS				0	100	psi G	PJ6-EXD-GEN-YZ0H-0005-102	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		MEA INLET SCRB PRESSURE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
390	PT -8050 TF	PRESSURE TRANSMITTER - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0058	-	Ex"d" / NIS				0	100	psi G		-	TBD		2			
		CHEM INJ PACKAGE PMP P-8050TF DIAPHRAGM FAUILURE	-	MRI	LOOP POWERED							-	-						
391	PT -8051 TF	PRESSURE TRANSMITTER - DIAPHRAGM	PJ6-EXD-MRI-BQDA-0058	-	Ex"d" / NIS				0	100	psi G		-	TBD		2			
		CHEM INJ PACKAGE PMP P-8051TF DIAPHRAGM FAUILURE	-	MRI	LOOP POWERED							-	-						
392	PT -8200 TF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex"d" / NIS				0	120	psi G		-			2			
		V-851A-TF PRESSURE	-	MRI	-							-	-						
393	PT -8201 TF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex"d" / NIS				0	120	psi G		-			2			
		V-851A-TF (SAFETY)	-	MRI	-							-	-						
394	PT -8202 TF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex"d" / NIS				0	120	psi G		-			2			
		V-851B-TF PRESSURE	-	MRI	-							-	-						
395	PT -8203 TF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex"d" / NIS				0	120	psi G		-			2			
		V-851B-TF (SAFETY)	-	MRI	-							-	-						
396	PT -8204 TF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex"d" / NIS				0	120	psi G		-			2			
		V-851C-TF PRESSURE	-	MRI	-							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 37 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
397	PT -8205 TF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex"d" / NIS				0	120	psi G		-			2			
		V-851C-TF (SAFETY)	-	MRI	-							-	-						
398	PT -8206 TF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex"d" / NIS				0	120	psi G		-			2			
		V-852-TF (SAFETY)	-	MRI	-							-	-						
399	PT -8207 TF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex"d" / NIS				0	120	psi G		-			2			
		V-852-TF PRESSURE	-	MRI	-							-	-						
400	PT -8208 TF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	120	psi G		-			2			
		V-852-TF (Safety)	-	MRI	-							-	-						
401	PT -8210ATF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS				0	50	psi G	PJ6-EXD-GEN-YZ0H-0005-103	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		MRD PROD WATER DISPOSAL PMP (P-851A-TF) SUCTION LINE	12"-PW-DL0N-8714	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
402	PT -8210BTF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS				0	1600	psi G	PJ6-EXD-GEN-YZ0H-0005-104	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		MRD PROD WATER DISPOSAL PMP (P-851A-TF) DISCHRG LINE	10"-PW-DL0N-8703	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
403	PT -8211ATF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS				0	50	psi G	PJ6-EXD-GEN-YZ0H-0005-105	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		MRD PROD WATER DISPOSAL PMP (P-851B-TF) SUCTION LINE	12"-PW-DL0N-8715	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
404	PT -8211BTF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS				0	1600	psi G	PJ6-EXD-GEN-YZ0H-0005-106	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		MRD PROD WATER DISPOSAL PMP (P-851B-TF) DISCHRG LINE	10"-PW-DL0N-8704	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
405	PT -8212ATF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS				0	50	psi G	PJ6-EXD-GEN-YZ0H-0005-107	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		MRD PROD WATER DISPOSAL PMP (P-851C-TF) SUCTION LINE	12"-PW-DL0N-8716	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
406	PT -8212BTF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	-	Ex"d" / NIS				0	1600	psi G	PJ6-EXD-GEN-YZ0H-0005-108	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2			
		MRD PROD WATER DISPOSAL PMP (P-851C-TF) DISCHRG LINE	10"-PW-DL0N-8705	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
407	PT -8220 TF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	WD-10	Ex'd' / NIS				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0005-109	-	TBD		2			
		WATER DISPOSAL WELL WD-10 PRESSURE	-	MRI	-							-	-	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 38 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
408	PT -8221 TF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	WD-10	Ex'd' / NIS				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0005-110	-	TBD		2			
		WATER DISPOSAL WELL WD-10 PRESSURE	-	MRI	-							-	TBD						
409	PT -8230 TF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	WD-11	Ex'd' / NIS				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0005-111	-	TBD		2			
		WATER DISPOSAL WELL WD-11 PRESSURE	-	MRI	-							-	TBD						
410	PT -8231 TF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	WD-11	Ex'd' / NIS				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0005-112	-	TBD		2			
		WATER DISPOSAL WELL WD-11 PRESSURE	-	MRI	-							-	TBD						
411	PT -8240 TF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	WD-12	Ex'd' / NIS				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0005-113	-	TBD		2			
		WATER DISPOSAL WELL WD-12 PRESSURE	-	MRI	-							-	TBD						
412	PT -8241 TF	PRESSURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0042	WD-12	Ex'd' / NIS				0	1500	psi G	PJ6-EXD-GEN-YZ0H-0005-114	-	TBD		2			
		WATER DISPOSAL WELL WD-12 PRESSURE	-	MRI	-							-	TBD						
413	PT -8250ATF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	g/cm²		-			2			
		P-851A-TF API PLAN 53B PRESSURE TRANSMITTER- DE 1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
414	PT -8250BTF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	g/cm²		-			2			
		P-851B-TF API PLAN 53B PRESSURE TRANSMITTER- DE 1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
415	PT -8250CTF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	g/cm²		-			2			
		P-851C-TF API PLAN 53B PRESSURE TRANSMITTER- DE 1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
416	PT -8251ATF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	g/cm²		-			2			
		P-851A-TF API PLAN 53B PRESSURE TRANSMITTER- DE 2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
417	PT -8251BTF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	g/cm²		-			2			
		P-851B-TF API PLAN 53B PRESSURE TRANSMITTER- DE 2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
418	PT -8251CTF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	g/cm²		-			2			
		P-851C-TF API PLAN 53B PRESSURE TRANSMITTER- DE 2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						

FD شركة نفط أبوظبي المحدودة (اليابان) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 39 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
419	PT -8252ATF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	g/cm²		-			2			
		P-851A-TF API PLAN 53B PRESSURE TRANSMITTER- NDE 1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
420	PT -8252BTF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	g/cm²		-			2			
		P-851B-TF API PLAN 53B PRESSURE TRANSMITTER- NDE 1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
421	PT -8252CTF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	g/cm²		-			2			
		P-851C-TF API PLAN 53B PRESSURE TRANSMITTER- NDE 1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
422	PT -8253ATF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	g/cm²		-			2			
		P-851A-TF API PLAN 53B PRESSURE TRANSMITTER- NDE 2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
423	PT -8253BTF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	g/cm²		-			2			
		P-851B-TF API PLAN 53B PRESSURE TRANSMITTER- NDE 2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
424	PT -8253CTF	PRESSURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	g/cm²		-			2			
		P-851C-TF API PLAN 53B PRESSURE TRANSMITTER- NDE 2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
425	PY -8004ATF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0023	PCV-8004ATF	Ex"d" / NIS								-	TBD	TYPE-5	2			
		PCV-8004ATF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
426	PY -8004BTF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0023	PCV-8004BTF	Ex"d" / NIS								-	TBD	TYPE-5	2			
		PCV-8004BTF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
427	PY -8006ATF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0024	PCV-8006ATF	Ex"d" / NIS								-	TBD	TYPE-5	2			
		PCV-8006ATF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
428	PY -8006BTF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0024	PCV-8006BTF	Ex"d" / NIS								-	TBD	TYPE-5	2			
		PCV-8006BTF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
429	PY -8009 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0026	PCV-8009TF	Ex'd' / NIS								-	TBD	TYPE-5 (BY PACKAGE VENDOR) (Note-5)	2			
		PCV-8009TF POSITIONER	-	MRI	LOOP POWERED							-	-	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 40 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
430	PY -8010 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0026	PCV-8010TF	Ex'd' / NIS								-	TBD	TYPE-5 (BY PACKAGE VENDOR) (Note-5)	2			
		PCV-8010TF POSITIONER	-	MRI	LOOP POWERED							-	-	TBD					
431	PY -8017 TF	CONTROL VALVE POSITIONER	PJ6-EXD-MRI-BQDA-0021	PCV-8017TF	Ex"d" / NIS								-	TBD	TYPE-5	2			
		PCV-8017TF POSITIONER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
432	PY -8200 TF	CONTROL VALVE POSITIONER	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		CONTROL SIGNAL PCV-8200, V-852-TF	-	MRI	2 WIRE							-	-						
433	PZT -8004ATF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0023	PCV-8004ATF	Ex"d" / NIS								-	TBD	TYPE-5	2			
		PCV-8004ATF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
434	PZT -8004BTF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0023	PCV-8004BTF	Ex"d" / NIS								-	TBD	TYPE-5	2			
		PCV-8004BTF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
435	PZT -8006ATF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0024	PCV-8006ATF	Ex"d" / NIS								-	TBD	TYPE-5	2			
		PCV-8006ATF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
436	PZT -8006BTF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0024	PCV-8006BTF	Ex"d" / NIS								-	TBD	TYPE-5	2			
		PCV-8006BTF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
437	PZT -8017 TF	POSITION TRANSMITTER	PJ6-EXD-MRI-BQDA-0021	PCV-8017TF	Ex"d" / NIS								-	TBD	TYPE-5	2			
		PCV-8017TF POSITION TRANSMITTER	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
438	PZT -8200 TF	FEEDBACK	P250001-PLK00C01001	-	NIS								-			2			
		POSITION FEEDBACK PCV-8200, V-852-TF	-	MRI	2 WIRE							-	-						
439	RO -018 CTF	RESTRICTION ORIFICE	PJ6-EXD-MRI-BQDA-0025	-	-				0	2100	lb/h	PJ6-EXD-GEN-YZ0H-0009-058	-	TBD	*	2			
		RECOVERY GAS CMPSR DISCHARGE SCRB RO	6"-SG-AS0-8709	MRI	-							-	-	TBD					
440	RO -8001 TF	RESTRICTION ORIFICE	PJ6-EXD-MRI-BQDA-0022	-	-				0	17500	lb/h	PJ6-EXD-GEN-YZ0H-0009-059	-	TBD	*	2			
		PIG RCVR TO FLARE RO	2"-PL-DC3N-8105	MRI	-							-	-	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 41 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
441	RO -8002 TF	RESTRICTION ORIFICE	PJ6-EXD-MRI-BQDA-0022	-	-				0	17500	lb/h	PJ6-EXD-GEN-YZ0H-0009-060	-	TBD	*	2			
		MRI PIG RCVR TO CLOSE DRAIN RO	4"-CD-AC3N-8184	MRI	-							-	-	TBD					
442	RO -8003 TF	RESTRICTION ORIFICE	PJ6-EXD-MRI-BQDA-0022	-	-				0	17500	lb/h	PJ6-EXD-GEN-YZ0H-0009-061	-	TBD	*	2			
		MRI PIG RCVR TO 3 PHASE SEPT	6"-CD-AC3N-8183	MRI	-							-	-	TBD					
443	RO -8004 TF	RESTRICTION ORIFICE	PJ6-EXD-MRI-BQDA-0023	-	-				0	72000	lb/h	PJ6-EXD-GEN-YZ0H-0009-062	-	TBD	*	2			
		OIL SLUG CATC TO FLARE RO	4"-SG-AC3N-8109	MRI	-							-	-	TBD					
444	RO -8005 TF	RESTRICTION ORIFICE	PJ6-EXD-MRI-BQDA-0024	-	-				0	4000	lb/h	PJ6-EXD-GEN-YZ0H-0009-063	-	TBD	*	2			
		3 PHASE SEPT TO FLARE RO	2"-SG-AC3N-8114	MRI	-							-	-	TBD					
445	RO -8006 TF	RESTRICTION ORIFICE	PJ6-EXD-MRI-BQDA-0021	-	-				0	1000	lb/h	PJ6-EXD-GEN-YZ0H-0009-064	-	TBD	*	2			
		3 PHASE SEPT TO FLARE RO	2"-SG-AC3N-8126	MRI	-							-	-	TBD					
446	RO -8007 TF	RESTRICTION ORIFICE	PJ6-EXD-MRI-BQDA-0023	-	-				0	72000	lb/h	PJ6-EXD-GEN-YZ0H-0009-065	-	TBD	*	2			
		OIL SLUG CATC TO FLARE RO	2"-SG-AC3N-8110	MRI	-							-	-	TBD					
447	SD -9001 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG HVAC SYSTEM SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
448	SD -9002 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG HVAC SYSTEM SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
449	SD -9003 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG HVAC SYSTEM SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
450	SD -9004 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG HVAC SYSTEM SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
451	SD -9005 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 42 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
452	SD -9006 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
453	SD -9007 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG ALR SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
454	SD -9008 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG ALR SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
455	SD -9009 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG ALR SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
456	SD -9010 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG BATTERY ROOM SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
457	SD -9011 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
458	SD -9012 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
459	SD -9013 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
460	SD -9014 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
461	SD -9015 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
462	SD -9016 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 43 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
463	SD -9017 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
464	SD -9018 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
465	SD -9019 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 ALR SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
466	SD -9020 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 ALR SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
467	SD -9021 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 ALR SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
468	SD -9022 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 ENGG ROOM SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
469	SD -9023 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 ENGG ROOM SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
470	SD -9024 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 EQUIP ROOM SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
471	SD -9025 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 EQUIP ROOM SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
472	SD -9026 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 EQUIP ROOM SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
473	SD -9027 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 EQUIP ROOM SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (اليابان) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 44 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
474	SD -9028 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 EQUIP ROOM SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
475	SD -9029 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CABINET ROOM-3 HVAC SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
476	SD -9030 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CABINET ROOM-3 HVAC SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
477	SD -9031 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CABINET ROOM-3 HVAC SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
478	SD -9032 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CABINET ROOM-3 HVAC SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
479	SD -9033 -M	SMOKE DETECTOR - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD		2			
		ICSS ROOM-3 SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	-	TBD					
480	SDF -9001 -M	SMOKE DETECTOR RAISED FLOOR- ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 EQUIP ROOM CEILING SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
481	SDF -9002 -M	SMOKE DETECTOR RAISED FLOOR- ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 ENG ROOM CEILING SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
482	SDF -9003 -M	SMOKE DETECTOR RAISED FLOOR- ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 ENG ROOM CEILING SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
483	SDF -9004 -M	SMOKE DETECTOR RAISED FLOOR- ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 EQUIP ROOM CEILING SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
484	SDF -9005 -M	SMOKE DETECTOR RAISED FLOOR- ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 EQUIP ROOM CEILING SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 45 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
485	SDF -9006 -M	IOKE DETECTOR RAISED FLOOR- ADDRESSAB	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD		2			
		ICSS CONTROL-3 EQUIP ROOM CEILING SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
486	SDF -9007 -M	IOKE DETECTOR RAISED FLOOR- ADDRESSAB	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 EQUIP ROOM CEILING SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
487	SDF -9008 -M	IOKE DETECTOR RAISED FLOOR- ADDRESSAB	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 EQUIP ROOM CEILING SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
488	SDHS -017 CTF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-BQDA-0025	SDV-017CTF	Ex"d" / NIS								-	TBD	TYPE-3 (BY PACKAGE VENDOR) (Note-5)	2			
		SDV-017CTF RESET PB	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
489	SDHS -8001 TF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-BQDA-0022	SDV-8001TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8001TF RESET PB	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
490	SDHS -8002 TF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-BQDA-0022	SDV-8002TF	Ex"d" / NIS								-	TBD	TYPE-3B	2			
		SDV-8002TF RESET PB	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
491	SDHS -8003 TF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-BQDA-0023	SDV-8003TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8003 RESET PB	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
492	SDHS -8004 TF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-BQDA-0023	SDV-8004TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8004TF RESET PB	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
493	SDHS -8005 TF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-BQDA-0023	SDV-8005TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8005TF RESET PB	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
494	SDHS -8006 TF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-BQDA-0024	SDV-8006TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8006TF RESET PB	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
495	SDHS -8007 TF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-BQDA-0024	SDV-8007TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8007TF RESET PB	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 46 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
496	SDHS -8009 TF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-BQDA-0024	SDV-8009TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8009TF RESET PB	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
497	SDHS -8014 TF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-BQDA-0025	SDV-8014TF	Ex"d" / NIS								-	TBD	TYPE-3 (BY PACKAGE VENDOR) (Note-5)	2			
		SDV-8014TF RESET PB	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
498	SDHS -8016 TF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-BQDA-0021	SDV-8016TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8016TF RESET PB	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
499	SDHS -8017 TF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-BQDA-0021	SDV-8017TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8017TF RESET PB	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
500	SDHS -8018 TF	LOCAL HAND PUSH BUTTON	PJ6-EXD-MRI-BQDA-0023	SDV-8018TF	Ex"d" / NIS								-	TBD		2			
		SDV-8018TF RESET PB	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
501	SDHS -8200 TF	FIELD RESET SWITCH	P250001-PLK00C01001	-	NIS								-	TBD		2			
		SDV-8200TF LOCAL RESET ESD	-	MRI	-							-	-	TBD					
502	SDR -9001 -M	SMOKE DETECTOR CEILING - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG BATTERY ROOM SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
503	SDR -9002 -M	SMOKE DETECTOR CEILING - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG CEILING SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
504	SDR -9003 -M	SMOKE DETECTOR CEILING - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBST BLDG CEILING SMOKE DETECTOR	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
505	SDR -9004 -M	SMOKE DETECTOR CEILING - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 EQUIP ROOM CEILING SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
506	SDR -9005 -M	SMOKE DETECTOR CEILING - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 ENGG ROOM CEILING SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					

 شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)																	
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 47 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
507	SDR -9006 -M	SMOKE DETECTOR CEILING - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 ENGG ROOM CEILING SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
508	SDR -9007 -M	SMOKE DETECTOR CEILING - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 EQUIP ROOM CEILING SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
509	SDR -9008 -M	SMOKE DETECTOR CEILING - ADDRESSABLE	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS CONTROL-3 EQUIP ROOM CEILING SMOKE DETECTOR	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
510	SDV -017 CTF	SHUT DOWN VALVE	PJ6-EXD-MRI-BQDA-0025	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0001-047	-	TBD	TYPE-3 (BY PACKAGE VENDOR) (Note-5)	2			
		RGC DISCHARGE SCRB INLET SDV	6"-SG-AC3N-8103	MRI	-							-	-	TBD					
511	SDV -8001 TF	SHUT DOWN VALVE	PJ6-EXD-MRI-BQDA-0022	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0001-029	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-3	2			
		FRM PIG LNCR CFP-MRI LINE SDV	30" MULTIPHASE PIPELINE APL 5L GR X65	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
512	SDV -8002 TF	SHUT DOWN VALVE	PJ6-EXD-MRI-BQDA-0022	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0001-031	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-3B	2			
		FRM PIG LNCR CFP-MRI LINE BYPASS SDV	2"-PL-DC3N-8101	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
513	SDV -8003 TF	SHUT DOWN VALVE	PJ6-EXD-MRI-BQDA-0023	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0001-033	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-3	2			
		PIG REVR CFP-MRI TO NEW OIL SLUG CATC LINE SDV	20"-PL-DC3N-8106	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
514	SDV -8004 TF	SHUT DOWN VALVE	PJ6-EXD-MRI-BQDA-0023	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0001-035	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-3	2			
		OIL SLUG CATC TO MEA INLET SCRB SDV	6"-SG-AC3N-8112	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
515	SDV -8005 TF	SHUT DOWN VALVE	PJ6-EXD-MRI-BQDA-0023	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0001-037	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-3	2			
		OIL SLUG CATC V803TF OUTLET TO 3 PHASE SEPT SDV	12"-PL-AC3N-8113	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
516	SDV -8006 TF	SHUT DOWN VALVE	PJ6-EXD-MRI-BQDA-0024	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0001-039	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-3	2			
		3 PHASE SEPT GAS TO NEW MEA SCRB SDV	3"-SG-AC3N-8116	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
517	SDV -8007 TF	SHUT DOWN VALVE	PJ6-EXD-MRI-BQDA-0024	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0001-041	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-3	2			
		3 PHASE SEPT TO PRODUCED WATER SDV	12"-PW-AL0N-8104	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 48 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
518	SDV -8009 TF	SHUT DOWN VALVE	PJ6-EXD-MRI-BQDA-0024	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0001-043	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-3	2			
		3 PHASE SEPT OIL TO NEW HEATER OUTLET SDV	10"-PL-AC3N-8116	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
519	SDV -8010 TF	SHUT DOWN VALVE	PJ6-EXD-MRI-BQDA-0026	-	Ex'd' / NIS								-	TBD	TYPE-3 (BY PACKAGE VENDOR) (Note-5)	2			
		SWEET GAS CMPSR INLET SCR B V-101E-TF INLET SDV	12"	MRI	-							-	-	TBD					
520	SDV -8011 TF	SHUT DOWN VALVE	PJ6-EXD-MRI-BQDA-0026	-	Ex'd' / NIS								-	TBD	TYPE-3 (BY PACKAGE VENDOR) (Note-5)	2			
		SWEET GAS CMPSR INLET SCR B V-101E-TF OUTLET SDV	2"	MRI	-							-	-	TBD					
521	SDV -8012 TF	SHUT DOWN VALVE	PJ6-EXD-MRI-BQDA-0026	-	Ex'd' / NIS								-	TBD	TYPE-3 (BY PACKAGE VENDOR) (Note-5)	2			
		SWEET GAS CMPSR INLET SCR B V-103E-TF OUTLET SDV	2"	MRI	-							-	-	TBD					
522	SDV -8013 TF	SHUT DOWN VALVE	PJ6-EXD-MRI-BQDA-0026	-	Ex'd' / NIS								-	TBD	TYPE-3 (BY PACKAGE VENDOR) (Note-5)	2			
		SWEET GAS CMPSR OUTLET SCR B V-105E-TF OUTLET SDV	2"	MRI	-							-	-	TBD					
523	SDV -8014 TF	SHUT DOWN VALVE	PJ6-EXD-MRI-BQDA-0025	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0001-045	-	TBD	TYPE-3 (BY PACKAGE VENDOR) (Note-5)	2			
		SOUR GAS CMPSR INLET SCR B V-010C-TF OUTLET SDV	12"-SG-AC3N-8101	MRI	-							-	-	TBD					
524	SDV -8016 TF	SHUT DOWN VALVE	PJ6-EXD-MRI-BQDA-0021	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0001-025	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-3	2			
		GAS TO MEA SCR B V-806-TF SDV	10"-SG-AC3N-8133	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
525	SDV -8017 TF	SHUT DOWN VALVE	PJ6-EXD-MRI-BQDA-0021	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0001-027	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-3	2			
		MEA INLET SCR B OUTLET TO V-160/V-180-TF SDV	2"-CD-AC3N-8101	MRI	-							-	PJ6-EXD-MRI-YCPA-0002	TBD					
526	SDV -8018 TF	SHUT DOWN VALVE	PJ6-EXD-MRI-BQDA-0023	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0001-049	PJ6-EXD-MRF-YZ0A-0002	TBD	TYPE-3	2			
		OIL SLUG CATC V803TF OUTLET TO 3 PHASE SEPT SDV	12"-PL-AC3N-8114	MRI	-							-	-	TBD					
527	SDY -017 CTF	SOLENOID VALVE	PJ6-EXD-MRI-BQDA-0025	SDV-017CTF	Ex"d" / NIS								-	TBD	TYPE-3 (BY PACKAGE VENDOR) (Note-5)	2			
		SDV-017CTF SOV	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
528	SDY -8001 TF	SOLENOID VALVE	PJ6-EXD-MRI-BQDA-0022	SDV-8001TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8001TF SOV	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 49 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
529	SDY -8002 TF	SOLENOID VALVE	PJ6-EXD-MRI-BQDA-0022	SDV-8002TF	Ex"d" / NIS								-	TBD	TYPE-3B	2			
		SDV-8002TF SOV	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
530	SDY -8003 TF	SOLENOID VALVE	PJ6-EXD-MRI-BQDA-0023	SDV-8003TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8003 SOV	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
531	SDY -8004 TF	SOLENOID VALVE	PJ6-EXD-MRI-BQDA-0023	SDV-8004TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8004TF SOV	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
532	SDY -8005 TF	SOLENOID VALVE	PJ6-EXD-MRI-BQDA-0023	SDV-8005TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8005TF SOV	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
533	SDY -8006 TF	SOLENOID VALVE	PJ6-EXD-MRI-BQDA-0024	SDV-8006TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8006TF SOV	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
534	SDY -8007 TF	SOLENOID VALVE	PJ6-EXD-MRI-BQDA-0024	SDV-8007TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8007TF SOV	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
535	SDY -8009 TF	SOLENOID VALVE	PJ6-EXD-MRI-BQDA-0024	SDV-8009TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8009TF SOV	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
536	SDY -8014 TF	SOLENOID VALVE	PJ6-EXD-MRI-BQDA-0025	SDV-8014TF	Ex"d" / NIS								-	TBD	TYPE-3 (BY PACKAGE VENDOR) (Note-5)	2			
		SDV-8014TF SOV	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
537	SDY -8016 TF	SOLENOID VALVE	PJ6-EXD-MRI-BQDA-0021	SDV-8016TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8016TF SOV	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
538	SDY -8017 TF	SOLENOID VALVE	PJ6-EXD-MRI-BQDA-0021	SDV-8017TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8017TF SOV	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
539	SDY -8018 TF	SOLENOID VALVE	PJ6-EXD-MRI-BQDA-0023	SDV-8014TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8018TF SOV	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS		
		Instrument and F&G Index - Mubarraz Island														
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001		
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model		
540	SDY -8200 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2
		SDV-8200TF OPEN/CLOSE	-	MRI	-							-				
541	SHY -017 CTF	PARTIAL STROKE POSITIONER	PJ6-EXD-MRI-BQDA-0025	SDV-017CTF	Ex"d" / NIS								-	TBD	TYPE-3 (BY PACKAGE VENDOR) (Note-5)	2
		SDV-017CTF PST	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-	TBD		
542	SHY -8001 TF	PARTIAL STROKE POSITIONER	PJ6-EXD-MRI-BQDA-0022	SDV-8001TF	Ex"d" / NIS								-	TBD	TYPE-3	2
		SDV-8001TF PST	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
543	SHY -8003 TF	PARTIAL STROKE POSITIONER	PJ6-EXD-MRI-BQDA-0023	SDV-8003TF	Ex"d" / NIS								-	TBD	TYPE-3	2
		SDV-8003 PST	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
544	SHY -8004 TF	PARTIAL STROKE POSITIONER	PJ6-EXD-MRI-BQDA-0023	SDV-8004TF	Ex"d" / NIS								-	TBD	TYPE-3	2
		SDV-8004TF PST	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
545	SHY -8005 TF	PARTIAL STROKE POSITIONER	PJ6-EXD-MRI-BQDA-0023	SDV-8005TF	Ex"d" / NIS								-	TBD	TYPE-3	2
		SDV-8005TF PST	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
546	SHY -8006 TF	PARTIAL STROKE POSITIONER	PJ6-EXD-MRI-BQDA-0024	SDV-8006TF	Ex"d" / NIS								-	TBD	TYPE-3	2
		SDV-8006TF PST	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
547	SHY -8007 TF	PARTIAL STROKE POSITIONER	PJ6-EXD-MRI-BQDA-0024	SDV-8007TF	Ex"d" / NIS								-	TBD	TYPE-3	2
		SDV-8007TF PST	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
548	SHY -8009 TF	PARTIAL STROKE POSITIONER	PJ6-EXD-MRI-BQDA-0024	SDV-8009TF	Ex"d" / NIS								-	TBD	TYPE-3	2
		SDV-8009TF PST	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
549	SHY -8014 TF	PARTIAL STROKE POSITIONER	PJ6-EXD-MRI-BQDA-0025	SDV-8014TF	Ex"d" / NIS								-	TBD	TYPE-3 (BY PACKAGE VENDOR) (Note-5)	2
		SDV-8014TF PST	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-	TBD		
550	SHY -8016 TF	PARTIAL STROKE POSITIONER	PJ6-EXD-MRI-BQDA-0021	SDV-8016TF	Ex"d" / NIS								-	TBD	TYPE-3	2
		SDV-8016TF PST	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS		
		Instrument and F&G Index - Mubarraz Island														
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001		
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model		
551	SHY -8017 TF	PARTIAL STROKE POSITIONER	PJ6-EXD-MRI-BQDA-0021	SDV-8017TF	Ex"d" / NIS								-	TBD	TYPE-3	2
		SDV-8017TF PST	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
552	SHY -8018 TF	PARTIAL STROKE POSITIONER	PJ6-EXD-MRI-BQDA-0023	SDV-8014TF	Ex"d" / NIS								-	TBD	TYPE-3	2
		SDV-8018TF PST	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-	TBD		
553	SHY -8200 TF	POSITIONER (PARTIAL STROKE)	P250001-PLK00C01001	-	Ex"d" / NIS								-			2
		SDV-8200TF PARTIAL STROKE TEST	-	MRI	-							-	-			
554	SI -6004A-M	SOUNDER	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS								-			2
		SLUG CATCHER AREA FIRE & GAS ALARM SOUNDER	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-			
555	SI -6004B-M	SOUNDER	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS								-			2
		SLUG CATCHER AREA FIRE & GAS ALARM SOUNDER	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-			
556	SI -6006A-M	SOUNDER	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS								-			2
		CMPSR AREA FIRE & GAS ALARM SOUNDER	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-			
557	SI -6006B-M	SOUNDER	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS								-			2
		CMPSR AREA FIRE & GAS ALARM SOUNDER	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-			
558	SI -9001A-M	ALARM BELL	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS								-	TBD		2
		SUBSTATION FIRE ALARM BELL	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD		
559	SI -9001B-M	ALARM BELL	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS								-	TBD		2
		SUBSTATION FIRE ALARM BELL	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD		
560	SI -9002A-M	SOUNDER	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS								-	TBD		2
		SUBSTATION FIRE ALARM SOUNDER TONE	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD		
561	SI -9002B-M	SOUNDER	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS								-	TBD		2
		SUBSTATION FIRE ALARM SOUNDER TONE	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD		

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 52 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
562	SI -9004A-M	SOUNDER	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS								-	TBD		2			
		SUBSTATION FIRE ALARM SOUNDER TONE	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
563	SI -9004B-M	SOUNDER	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS								-	TBD		2			
		SUBSTATION FIRE ALARM SOUNDER TONE	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
564	SI -9006A-M	ALARM BELL	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS								-	TBD	*	2			
		SUBSTATION FIRE ALARM BELL	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
565	SI -9006B-M	ALARM BELL	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS								-	TBD	*	2			
		SUBSTATION GAS ALARM BELL	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
566	SI -9008A-M	SOUNDER	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS								-	TBD	*	2			
		ICSS ROOM-3 FIRE & GAS ALARM SOUNDER	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
567	SI -9008B-M	SOUNDER	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS								-	TBD	*	2			
		ICSS ROOM-3 FIRE & GAS ALARM SOUNDER	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
568	SI -9501A-M	SOUNDER	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS							SI -9501A-M-SP	-	TBD	*	2			
		SOUR GAS CMPSR AREA FIRE & GAS ALARM SOUNDER	-	MRI	2 WIRE							-	-	TBD					
569	SI -9501B-M	SOUNDER	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS							SI -9501B-M-SP	-	TBD	*	2			
		SOUR GAS CMPSR AREA FIRE & GAS ALARM SOUNDER	-	MRI	2 WIRE							-	-	TBD					
570	SOV -8210-TF	SOLENOID VALVE	PJ6-EXD-MRI-BQDA-0028	-	NIS								-			2			
		FIRE MONITOR AT HEATER AREA	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-						
571	SOV -8211-TF	SOLENOID VALVE	PJ6-EXD-MRI-BQDA-0028	-	NIS								-			2			
		FIRE MONITOR AT HEATER AREA	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-						
572	SPG -8001 TF	PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0022	SDV-8001TF	-						D	SPG -8001 TF-SP	-	TBD	TYPE-4 (BY PACKAGE VENDOR) (Note-5)	2			
		SDV-8001TF VOLUME TANK PRESSURE	-	MRI	-							-	-	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS		
		Instrument and F&G Index - Mubarraz Island														
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001		
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model		
573	SPG -8003 TF	PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0023	SDV-8003TF	-						D	SPG -8003 TF-SP	-	TBD	TYPE-4 (BY PACKAGE VENDOR) (Note-5)	2
		SDV-8003TF VOLUME TANK PRESSURE	-	MRI	-							-	-	TBD		
574	SPG -8005 TF	PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0023	SDV-8005TF	-						D		-	TBD	TYPE-4 (BY PACKAGE VENDOR) (Note-5)	2
		SDV-8005TF VOLUME TANK PRESSURE	-	MRI	-							-	-	TBD		
575	SPG -8018 TF	PRESSURE GAUGE	PJ6-EXD-MRI-BQDA-0023	SDV-8018TF	-						D		-	TBD	TYPE-4 (BY PACKAGE VENDOR) (Note-5)	2
		SDV-8018TF VOLUME TANK PRESSURE	-	MRI	-							-	-	TBD		
576	SPSV -8001 TF	PRESSURE SAFETY VALVE	PJ6-EXD-MRI-BQDA-0023	SDV-8001TF	-						D		-	TBD	TYPE-4 (BY PACKAGE VENDOR) (Note-5)	2
		SDV-8001TF VOLUME TANK PSV	-	MRI	-							-	-	TBD		
577	SPSV -8003 TF	PRESSURE SAFETY VALVE	PJ6-EXD-MRI-BQDA-0023	SDV-8003TF	-						D		-	TBD	TYPE-4 (BY PACKAGE VENDOR) (Note-5)	2
		SDV-8003TF VOLUME TANK PSV	-	MRI	-							-	-	TBD		
578	SPSV -8005 TF	PRESSURE SAFETY VALVE	PJ6-EXD-MRI-BQDA-0023	SDV-8005TF	-						D		-	TBD	TYPE-4 (BY PACKAGE VENDOR) (Note-5)	2
		SDV-8005TF VOLUME TANK PSV	-	MRI	-							-	-	TBD		
579	SPSV -8018 TF	PRESSURE SAFETY VALVE	PJ6-EXD-MRI-BQDA-0023	SDV-8018TF	-						D		-	TBD	TYPE-4 (BY PACKAGE VENDOR) (Note-5)	2
		SDV-8018TF VOLUME TANK PSV	-	MRI	-							-	-	TBD		
580	SXA -017 CTF	DISCREPANCY ALARM	PJ6-EXD-MRI-BQDA-0025	-	-								-			2
		SDV-017CTF DISCREPANCY ALARM	-	MRI	-							-	-			
581	SXA -8001 TF	DISCREPANCY ALARM	PJ6-EXD-MRI-BQDA-0022	-	-								-			2
		SDV-8001TF DISCREPANCY ALARM	-	MRI	-							-	-			
582	SXA -8002 TF	DISCREPANCY ALARM	PJ6-EXD-MRI-BQDA-0022	-	-								-			2
		SDV-8002TF DISCREPANCY ALARM	-	MRI	-							-	-			
583	SXA -8003 TF	DISCREPANCY ALARM	PJ6-EXD-MRI-BQDA-0023	-	-								-			2
		SDV-8003 DISCREPANCY ALARM	-	MRI	-							-	-			

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 54 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
584	SXA -8004 TF	DISCREPANCY ALARM	PJ6-EXD-MRI-BQDA-0023	-	-								-			2			
		SDV-8004TF DISCREPANCY ALARM	-	MRI	-							-	-						
585	SXA -8005 TF	DISCREPANCY ALARM	PJ6-EXD-MRI-BQDA-0023	-	-								-			2			
		SDV-8005TF DISCREPANCY ALARM	-	MRI	-							-	-						
586	SXA -8006 TF	DISCREPANCY ALARM	PJ6-EXD-MRI-BQDA-0024	-	-								-			2			
		SDV-8006TF DISCREPANCY ALARM	-	MRI	-							-	-						
587	SXA -8007 TF	DISCREPANCY ALARM	PJ6-EXD-MRI-BQDA-0024	-	-								-			2			
		SDV-8007TF DISCREPANCY ALARM	-	MRI	-							-	-						
588	SXA -8009 TF	DISCREPANCY ALARM	PJ6-EXD-MRI-BQDA-0024	-	-								-			2			
		SDV-8009TF DISCREPANCY ALARM	-	MRI	-							-	-						
589	SXA -8014 TF	DISCREPANCY ALARM	PJ6-EXD-MRI-BQDA-0025	-	-								-			2			
		SDV-8014TF DISCREPANCY	-	MRI	-							-	-						
590	SXA -8016 TF	DISCREPANCY ALARM	PJ6-EXD-MRI-BQDA-0021	-	-								-			2			
		SDV-8016TF DISCREPANCY	-	MRI	-							-	-						
591	SXA -8017 TF	DISCREPANCY ALARM	PJ6-EXD-MRI-BQDA-0021	-	-								-			2			
		SDV-8017TF DISCREPANCY ALARM	-	MRI	-							-	-						
592	SXA -8018 TF	DISCREPANCY ALARM	PJ6-EXD-MRI-BQDA-0023	-	-								-			2			
		SDV-8018TF DISCREPANCY ALARM	-	MRI	-							-	-						
593	SZCA -017 CTF	POSITION CLOSE ALARM	PJ6-EXD-MRI-BQDA-0025	-	-								-			2			
		SDV-017CTF POSITION CLOSE ALARM	-	MRI	-							-	-						
594	SZCA -8001 TF	POSITION CLOSE ALARM	PJ6-EXD-MRI-BQDA-0022	-	-								-			2			
		SDV-8001TF POSITION CLOSE ALARM	-	MRI	-							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 55 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
595	SZCA -8002 TF	POSITION CLOSE ALARM	PJ6-EXD-MRI-BQDA-0022	-	-								-			2			
		SDV-8002TF POSITION CLOSE ALARM	-	MRI	-							-	-						
596	SZCA -8003 TF	POSITION CLOSE ALARM	PJ6-EXD-MRI-BQDA-0023	-	-								-			2			
		SDV-8003 DISCREPANCY ALARM	-	MRI	-							-	-						
597	SZCA -8004 TF	POSITION CLOSE ALARM	PJ6-EXD-MRI-BQDA-0023	-	-								-			2			
		SDV-8004TF POSITION CLOSE ALARM	-	MRI	-							-	-						
598	SZCA -8005 TF	POSITION CLOSE ALARM	PJ6-EXD-MRI-BQDA-0023	-	-								-			2			
		SDV-8005TF POSITION CLOSE ALARM	-	MRI	-							-	-						
599	SZCA -8006 TF	POSITION CLOSE ALARM	PJ6-EXD-MRI-BQDA-0024	-	-								-			2			
		SDV-8006TF POSITION CLOSE ALARM	-	MRI	-							-	-						
600	SZCA -8007 TF	POSITION CLOSE ALARM	PJ6-EXD-MRI-BQDA-0024	-	-								-			2			
		SDV-8007TF POSITION CLOSE ALARM	-	MRI	-							-	-						
601	SZCA -8009 TF	POSITION CLOSE ALARM	PJ6-EXD-MRI-BQDA-0024	-	-								-			2			
		SDV-8009TF POSITION CLOSE ALARM	-	MRI	-							-	-						
602	SZCA -8014 TF	POSITION CLOSE ALARM	PJ6-EXD-MRI-BQDA-0025	-	-								-			2			
		SDV-8014TF POSITION CLOSE ALARM	-	MRI	-							-	-						
603	SZCA -8016 TF	POSITION CLOSE ALARM	PJ6-EXD-MRI-BQDA-0021	-	-								-			2			
		SDV-8016TF POSITION CLOSE ALARM	-	MRI	-							-	-						
604	SZCA -8017 TF	POSITION CLOSE ALARM	PJ6-EXD-MRI-BQDA-0021	-	-								-			2			
		SDV-8017TF POSITION CLOSE ALARM	-	MRI	-							-	-						
605	SZCA -8018 TF	POSITION CLOSE ALARM	PJ6-EXD-MRI-BQDA-0023	-	-								-			2			
		SDV-8018TF POSITION CLOSE ALARM	-	MRI	-							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 56 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
606	SZSC -017 CTF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0025	SDV-017CTF	Ex"d" / NIS								-	TBD	TYPE-3 (BY PACKAGE VENDOR) (Note-5)	2			
		SDV-017CTF CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
607	SZSC -8001 TF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0022	SDV-8001TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8001TF CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
608	SZSC -8002 TF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0022	SDV-8002TF	Ex"d" / NIS								-	TBD	TYPE-3B	2			
		SDV-8002TF CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
609	SZSC -8003 TF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0023	SDV-8003TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8003 CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
610	SZSC -8004 TF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0023	SDV-8004TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8004TF CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
611	SZSC -8005 TF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0023	SDV-8005TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8005TF CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
612	SZSC -8006 TF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0024	SDV-8006TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8006TF CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
613	SZSC -8007 TF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0024	SDV-8007TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8007TF CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
614	SZSC -8009 TF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0024	SDV-8009TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8009TF CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
615	SZSC -8014 TF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0025	SDV-8014TF	Ex"d" / NIS								-	TBD	TYPE-3 (BY PACKAGE VENDOR) (Note-5)	2			
		SDV-8014TF CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
616	SZSC -8016 TF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0021	SDV-8016TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8016TF CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 57 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
617	SZSC -8017 TF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0021	SDV-8017TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8017TF CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
618	SZSC -8018 TF	POSITION SWITCH CLOSE	PJ6-EXD-MRI-BQDA-0023	SDV-8014TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8018TF CLOSED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
619	SZSC -8200 TF	LIMIT SWITCH	P250001-PLK00C01001	-	NIS								-			2			
		SDV-8200TF CLOSED STATUS	-	MRI	-							-	-						
620	SZSO -017 CTF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0025	SDV-017CTF	Ex"d" / NIS								-	TBD	TYPE-3 (BY PACKAGE VENDOR) (Note-5)	2			
		SDV-017CTF OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
621	SZSO -8001 TF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0022	SDV-8001TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8001TF OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
622	SZSO -8002 TF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0022	SDV-8002TF	Ex"d" / NIS								-	TBD	TYPE-3B	2			
		SDV-8002TF OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
623	SZSO -8003 TF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0023	SDV-8003TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8003 OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
624	SZSO -8004 TF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0023	SDV-8004TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8004TF OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
625	SZSO -8005 TF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0023	SDV-8005TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8005TF OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
626	SZSO -8006 TF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0024	SDV-8006TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8006TF OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
627	SZSO -8007 TF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0024	SDV-8007TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8007TF OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 58 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
628	SZSO -8009 TF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0024	SDV-8009TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8009TF OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
629	SZSO -8014 TF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0025	SDV-8014TF	Ex"d" / NIS								-	TBD	TYPE-3 (BY PACKAGE VENDOR) (Note-5)	2			
		SDV-8014TF OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
630	SZSO -8016 TF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0021	SDV-8016TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8016TF OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
631	SZSO -8017 TF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0021	SDV-8017TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8017TF OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
632	SZSO -8018 TF	POSITION SWITCH OPEN	PJ6-EXD-MRI-BQDA-0023	SDV-8018TF	Ex"d" / NIS								-	TBD	TYPE-3	2			
		SDV-8018TF OPEN	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
633	SZSO -8200 TF	LIMIT SWITCH	P250001-PLK00C01001	-	NIS								-			2			
		SDV-8200TF OPEN STATUS	-	MRI	-							-	-						
634	TE -8002 TF	RTD ELEMENT	PJ6-EXD-MRI-BQDA-0022	-	-								PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		FRM PIG LNCR TO SLUG CATC TO SLUG CATC TEMP	20"-PL-DC3N-8106	MRI	-							-	-	TBD					
635	TE -8005 TF	RTD ELEMENT	PJ6-EXD-MRI-BQDA-0024	V-804-TF	-								PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		3 PHASE SEPT TEMP	-	MRI	-							-	-	TBD					
636	TG -128C TF	TEMPERATURE GAUGE - BIMETALLIC	4RC31303 / 1RC20648	-	-							PJ6-EXD-GEN-YZ0H-0007-024	-	TBD	*	2			
		1ST CYL. JW INLET TEMP.	-	MRI	-							-	-	TBD					
637	TG -128E TF	TEMPERATURE GAUGE - BIMETALLIC	4RC31303 / 1RC20648	-	-							PJ6-EXD-GEN-YZ0H-0007-025	-	TBD	*	2			
		2ND CYL. JW INLET TEMP.	-	MRI	-							-	-	TBD					
638	TG -128G TF	TEMPERATURE GAUGE - BIMETALLIC	4RC31303 / 1RC20648	-	-							PJ6-EXD-GEN-YZ0H-0007-026	-	TBD	*	2			
		LO COOLER JW OUTLET TEMP.	-	MRI	-							-	-	TBD					

FD شركة نفط أبوظبي المحدودة (اليابان) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 59 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
639	TG -8001 TF	TEMPERATURE GAUGE - BIMETALLIC	PJ6-EXD-MRI-BQDA-0022	-	-							PJ6-EXD-GEN-YZ0H-0007-018	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		FRM PIG LNCR TO SLUG CATC TO SLUG CATC TEMP	20"-PL-DC3N-8106	MRI	-							-	-	TBD					
640	TG -8003 TF	TEMPERATURE GAUGE - BIMETALLIC	PJ6-EXD-MRI-BQDA-0023	V-803-TF	-							PJ6-EXD-GEN-YZ0H-0007-019	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		OIL SLUG CATC V803TF TEMP	-	MRI	-							-	-	TBD					
641	TG -8004 TF	TEMPERATURE GAUGE - BIMETALLIC	PJ6-EXD-MRI-BQDA-0024	V-804-TF	-							PJ6-EXD-GEN-YZ0H-0007-020	PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		3 PHASE SEPT TEMP	-	MRI	-							-	-	TBD					
642	TG -8210 TF	TEMPERATURE GAUGE - BIMETALLIC	PJ6-EXD-MRI-BQDA-0042	-	-							PJ6-EXD-GEN-YZ0H-0007-021	-	TBD	*	2			
		MRD PROD WATER DISPOSAL PMP (P-851A-TF) DISCHRG LINE	10"-PW-DL0N-8703	MRI	-							-	-	TBD					
643	TG -8211 TF	TEMPERATURE GAUGE - BIMETALLIC	PJ6-EXD-MRI-BQDA-0042	-	-							PJ6-EXD-GEN-YZ0H-0007-022	-	TBD	*	2			
		MRD PROD WATER DISPOSAL PMP (P-851B-TF) DISCHRG LINE	10"-PW-DL0N-8704	MRI	-							-	-	TBD					
644	TG -8212 TF	TEMPERATURE GAUGE - BIMETALLIC	PJ6-EXD-MRI-BQDA-0042	-	-							PJ6-EXD-GEN-YZ0H-0007-023	-	TBD	*	2			
		MRD PROD WATER DISPOSAL PMP (P-851C-TF) DISCHRG LINE	10"-PW-DL0N-8705	MRI	-							-	-	TBD					
645	TGD -3024 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		MEA INLET SCR8 V-806-TF AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
646	TGD -3025 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		NEW MEA INLET SCRUBBER AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
647	TGD -6029 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SLUG CATCHER AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
648	TGD -6030 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SLUG CATCHER AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
649	TGD -6031 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SLUG CATCHER AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (اليابان) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 60 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
650	TGD -6032 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		3 PHASE SPTR AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
651	TGD -6033 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		3 PHASE SPTR AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
652	TGD -6034 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		3 PHASE SPTR AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
653	TGD -6035 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		PIG RCVR AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
654	TGD -6036 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		PIG RCVR AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
655	TGD -6037 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		PIG RCVR AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
656	TGD -6038 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SOUR GAS CMPSR AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
657	TGD -6039 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SOUR GAS CMPSR AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
658	TGD -6040 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SOUR GAS CMPSR AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
659	TGD -7006 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		NEW OIL HEATER H-801-TF AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
660	TGD -7007 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		NEW OIL HEATER H-801-TF AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS		
		Instrument and F&G Index - Mubarraz Island														
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001		
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model		
661	TGD -7008 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2
		NEW OIL HEATER AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
662	TGD -7009 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD		2
		SWEET GAS CMPSR K-101E-TF AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
663	TGD -7010 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD		2
		SWEET GAS CMPSR K-101E-TF AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
664	TGD -9001 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0002	-	Ex'd' / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2
		SUBST BLDG HVAC AREA TOXIC GAS DETECTOR	-	SUB	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
665	TGD -9002 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0002	-	Ex'd' / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2
		SUBST BLDG HVAC AREA TOXIC GAS DETECTOR	-	SUB	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
666	TGD -9004 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2
		SUBSTATION AIR LOCK ROOM TOXIC GAS DETECTOR	-	SUB	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
667	TGD -9005 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2
		SUBSTATION AIR LOCK ROOM TOXIC GAS DETECTOR	-	SUB	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
668	TGD -9007 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD		2
		ICSS ROOM-3 AIR LOCK ROOM TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
669	TGD -9008 -M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD		2
		ICSS ROOM-3 AIR LOCK ROOM TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
670	TGD -9501-M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD		2
		PWT AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD		
671	TGD -9502-M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD		2
		PWT AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD		

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS		
		Instrument and F&G Index - Mubarraz Island														
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001		
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model		
672	TGD -9503-M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD		2
		PWT AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD		
673	TGD -9504-M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD		2
		PWT AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD		
674	TGD -9505-M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD		2
		PWT AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD		
675	TGD -9506-M	HYDROGEN SULPHIDE GAS DETECTOR	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS				0	100	PPMW	PJ6-EXD-GEN-YZ0H-0004	-	TBD		2
		PWT AREA TOXIC GAS DETECTOR	-	MRI	3 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD		
676	TT -8002 TF	TEMPERATURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0022	-	Ex"d" / NIS				0	260	°F	PJ6-EXD-GEN-YZ0H-0008-018	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2
		FRM PIG LAUNCHER TO SLUG CATCHER TEMP	20"-PL-DC3N-8106	MRI	-							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
677	TT -8005 TF	TEMPERATURE TRANSMITTER	PJ6-EXD-MRI-BQDA-0024	V-804-TF	Ex"d" / NIS				0	200	°F	PJ6-EXD-GEN-YZ0H-0008-019	PJ6-EXD-MRF-YZ0A-0002	TBD	-	2
		3 PHASE SEPT TEMP	-	MRI	-							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD		
678	TT -8250ATF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	248	°F		-			2
		P-851A-TF API PLAN 53B TEMPERATURE TRANSMITTER - DE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-			
679	TT -8250BTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	248	°F		-			2
		P-851B-TF API PLAN 53B TEMPERATURE TRANSMITTER - DE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-			
680	TT -8250CTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	248	°F		-			2
		P-851C-TF API PLAN 53B TEMPERATURE TRANSMITTER - DE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-			
681	TT -8251ATF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	248	°F		-			2
		P-851A-TF API PLAN 53B TEMPERATURE TRANSMITTER - NDE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-			
682	TT -8251BTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	248	°F		-			2
		P-851B-TF API PLAN 53B TEMPERATURE TRANSMITTER - NDE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-			

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 63 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
683	TT -8251CTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	248	°F		-			2			
		P-851C-TF API PLAN 53B TEMPERATURE TRANSMITTER - NDE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
684	TT -8252ATF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851A-TF MOTOR BEARING TEMPERATURE TRANSMITTER DE 1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
685	TT -8252BTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851B-TF MOTOR BEARING TEMPERATURE TRANSMITTER DE 1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
686	TT -8252CTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851C-TF MOTOR BEARING TEMPERATURE TRANSMITTER DE 1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
687	TT -8253ATF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851A-TF MOTOR BEARING TEMPERATURE TRANSMITTER DE 2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
688	TT -8253BTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851B-TF MOTOR BEARING TEMPERATURE TRANSMITTER DE 2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
689	TT -8253CTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851C-TF MOTOR BEARING TEMPERATURE TRANSMITTER DE 2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
690	TT -8254ATF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851A-TF MOTOR BEARING TEMPERATURE TRANSMITTER NDE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
691	TT -8254BTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851B-TF MOTOR BEARING TEMPERATURE TRANSMITTER NDE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
692	TT -8254CTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851C-TF MOTOR BEARING TEMPERATURE TRANSMITTER NDE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
693	TT -8255ATF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851A-TF MOTOR BEARING TEMPERATURE TRANSMITTER NDE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 64 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
694	TT -8255BTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851B-TF MOTOR BEARING TEMPERATURE TRANSMITTER NDE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
695	TT -8255CTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851C-TF MOTOR BEARING TEMPERATURE TRANSMITTER NDE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
696	TT -8256ATF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851A-TF PUMP BEARING TEMPERATURE TRANSMITTER DE 1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
697	TT -8256BTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851B-TF PUMP BEARING TEMPERATURE TRANSMITTER DE 1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
698	TT -8256CTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851C-TF PUMP BEARING TEMPERATURE TRANSMITTER DE 1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
699	TT -8257ATF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851A-TF PUMP BEARING TEMPERATURE TRANSMITTER DE 2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
700	TT -8257BTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851B-TF PUMP BEARING TEMPERATURE TRANSMITTER DE 2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
701	TT -8257CTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851C-TF PUMP BEARING TEMPERATURE TRANSMITTER DE 2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
702	TT -8258ATF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851A-TF PUMP BEARING TEMPERATURE TRANSMITTER NDE 1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
703	TT -8258BTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851B-TF PUMP BEARING TEMPERATURE TRANSMITTER NDE 1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
704	TT -8258CTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851C-TF PUMP BEARING TEMPERATURE TRANSMITTER NDE 1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 65 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
705	TT -8259ATF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851A-TF PUMP BEARING TEMPERATURE TRANSMITTER NDE 2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
706	TT -8259BTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851B-TF PUMP BEARING TEMPERATURE TRANSMITTER NDE 2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
707	TT -8259CTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	230	°F		-			2			
		P-851C-TF PUMP BEARING TEMPERATURE TRANSMITTER NDE 2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
708	TT -8260ATF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851A-TF MOTOR WINDING TEMPERATURE U1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
709	TT -8260BTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851B-TF MOTOR WINDING TEMPERATURE U1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
710	TT -8260CTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851C-TF MOTOR WINDING TEMPERATURE U1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
711	TT -8261ATF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851A-TF MOTOR WINDING TEMPERATURE U2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
712	TT -8261BTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851B-TF MOTOR WINDING TEMPERATURE U2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
713	TT -8261CTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851C-TF MOTOR WINDING TEMPERATURE U2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
714	TT -8262ATF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851A-TF MOTOR WINDING TEMPERATURE V1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
715	TT -8262BTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851B-TF MOTOR WINDING TEMPERATURE V1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 66 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
716	TT -8262CTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851C-TF MOTOR WINDING TEMPERATURE V1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
717	TT -8263ATF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851A-TF MOTOR WINDING TEMPERATURE V2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
718	TT -8263BTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851B-TF MOTOR WINDING TEMPERATURE V2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
719	TT -8263CTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851C-TF MOTOR WINDING TEMPERATURE V2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
720	TT -8264ATF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851A-TF MOTOR WINDING TEMPERATURE W1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
721	TT -8264BTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851B-TF MOTOR WINDING TEMPERATURE W1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
722	TT -8264CTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851C-TF MOTOR WINDING TEMPERATURE W1	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
723	TT -8265ATF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851A-TF MOTOR WINDING TEMPERATURE W2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
724	TT -8265BTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851B-TF MOTOR WINDING TEMPERATURE W2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
725	TT -8265CTF	TEMPERATURE TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	392	°F		-			2			
		P-851C-TF MOTOR WINDING TEMPERATURE W2	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
726	TW -8001 TF	THERMOWELL	PJ6-EXD-MRI-BQDA-0022	-	-								PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		FRM PIG LNCR TO SLUG CATC TO SLUG CATC TEMP	20"-PL-DC3N-8106	MRI	-							-	-	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 67 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
727	TW -8002 TF	THERMOWELL	PJ6-EXD-MRI-BQDA-0022	-	-								PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		FRM PIG LNCR TO SLUG CATC TO SLUG CATC TEMP	20"-PL-DC3N-8106	MRI	-								-	TBD					
728	TW -8003 TF	THERMOWELL	PJ6-EXD-MRI-BQDA-0023	V-803-TF	-								PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		OIL SLUG CATC V803TF TEMP	-	MRI	-								-	TBD					
729	TW -8004 TF	THERMOWELL	PJ6-EXD-MRI-BQDA-0024	V-804-TF	-								PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		3 PHASE SEPT TEMP	-	MRI	-								-	TBD					
730	TW -8005 TF	THERMOWELL	PJ6-EXD-MRI-BQDA-0024	V-804-TF	-								PJ6-EXD-MRF-YZ0A-0002	TBD	*	2			
		3 PHASE SEPT TEMP	-	MRI	-								-	TBD					
731	TW -8210 TF	THERMOWELL	PJ6-EXD-MRI-BQDA-0042	-	-								-	TBD	*	2			
		PROD WATER DISPOSAL PMP P-851A-TF DISCHRG LINE TEMP	10"-PW-DL0N-8730	MRI	-								-	TBD					
732	TW -8211 TF	THERMOWELL	PJ6-EXD-MRI-BQDA-0042	-	-								-	TBD	*	2			
		PROD WATER DISPOSAL PMP P-851B-TF DISCHRG LINE TEMP	10"-PW-DL0N-8731	MRI	-								-	TBD					
733	TW -8212 TF	THERMOWELL	PJ6-EXD-MRI-BQDA-0042	-	-								-	TBD	*	2			
		PROD WATER DISPOSAL PMP P-851B-TF DISCHRG LINE TEMP	10"-PW-DL0N-8732	MRI	-								-	TBD					
734	VT -8250ATF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	25.4	mm/s		-			2			
		P-851A-TF PUMP BEARING HOUSING VIBRATION DE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
735	VT -8250BTF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	25.4	mm/s		-			2			
		P-851B-TF PUMP BEARING HOUSING VIBRATION DE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
736	VT -8250CTF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	25.4	mm/s		-			2			
		P-851C-TF PUMP BEARING HOUSING VIBRATION DE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
737	VT -8251ATF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	25.4	mm/s		-			2			
		P-851A-TF PUMP BEARING HOUSING VIBRATION NDE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 68 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
738	VT -8251BTF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	25.4	mm/s		-			2			
		P-851B-TF PUMP BEARING HOUSING VIBRATION NDE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
739	VT -8251CTF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	25.4	mm/s		-			2			
		P-851C-TF PUMP BEARING HOUSING VIBRATION NDE	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
740	VT -8252ATF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	MILS		-			2			
		P-851A-TF MOTOR VIBRATION PROXIMITOR DE X-AXIS	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
741	VT -8252BTF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	MILS		-			2			
		P-851B-TF MOTOR VIBRATION PROXIMITOR DE X-AXIS	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
742	VT -8252CTF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	MILS		-			2			
		P-851C-TF MOTOR VIBRATION PROXIMITOR DE X-AXIS	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
743	VT -8253ATF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	MILS		-			2			
		P-851A-TF MOTOR VIBRATION PROXIMITOR DE Y-AXIS	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
744	VT -8253BTF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	MILS		-			2			
		P-851B-TF MOTOR VIBRATION PROXIMITOR DE Y-AXIS	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
745	VT -8253CTF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	MILS		-			2			
		P-851C-TF MOTOR VIBRATION PROXIMITOR DE Y-AXIS	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
746	VT -8254ATF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	MILS		-			2			
		P-851A-TF MOTOR VIBRATION PROXIMITOR NDE X-AXIS	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
747	VT -8254BTF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	MILS		-			2			
		P-851B-TF MOTOR VIBRATION PROXIMITOR NDE X-AXIS	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
748	VT -8254CTF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	MILS		-			2			
		P-851C-TF MOTOR VIBRATION PROXIMITOR NDE X-AXIS	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 69 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
749	VT -8255ATF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	MILS		-			2			
		P-851A-TF MOTOR VIBRATION PROXIMITOR NDE Y-AXIS	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
750	VT -8255BTF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	MILS		-			2			
		P-851B-TF MOTOR VIBRATION PROXIMITOR NDE Y-AXIS	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
751	VT -8255CTF	VIBRATION TRANSMITTER	P250001-PLK00C01001	-	Ex'd' / NIS				0	10	MILS		-			2			
		P-851C-TF MOTOR VIBRATION PROXIMITOR NDE Y-AXIS	-	MRI	LOOP POWERED							PJ6-EXD-MRI-YZ0A-0001	-						
752	XA -010 CTF	SHUTDOWN ALARM	PJ6-EXD-MRI-BQDA-0025	-	NIS								-			2			
		CMPRSR C-010C ESD ALARM	-	MRI	-							-	-						
753	XA -101 ETF	SHUTDOWN ALARM	PJ6-EXD-MRI-BQDA-0026	-	NIS						0		-			2			
		CMPRSR K-101E ESD ALARM	-	MRI	-							-	-						
754	XA -102 ETF	PSD SHUTDOWN ALARM	PJ6-EXD-MRI-BQDA-0026	-	NIS						0		-			2			
		CMPRSR K-101E PLC ALARM	-	MRI	-							-	-						
755	XA -120 TF	COMMON ALARM	PJ6-EXD-MRI-BQDA-0027	-	NIS						0		-			2			
		HEATER H120TF ESD TRIP ALARM	-	MRI	-							-	-						
756	XA -6010 -M	BEACON	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SLUG CATCHER AREA FLAM. GAS ALARM BEACON - AMBER	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
757	XA -6011 -M	BEACON	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SLUG CATCHER AREA TOXIC GAS ALARM BEACON - BLUE	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
758	XA -6012 -M	BEACON	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SLUG CATCHER AREA FIRE ALARM BEACON - RED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
759	XA -6016 -M	BEACON	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		CMPRSR AREA FLAMMABLE GAS ALARM BEACON - AMBER	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 70 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
760	XA -6017 -M	BEACON	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		CMPRSR AREA TOXIC GAS ALARM BEACON - BLUE	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
761	XA -6018 -M	BEACON	PJ6-EXD-MRI-FZ0A-0003	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		CMPRSR AREA FIRE ALARM BEACON - RED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
762	XA -801 TF	COMMON ALARM	PJ6-EXD-MRI-BQDA-0027	-	NIS						0		-			2			
		HEATER H801TF ESD TRIP ALARM	-	MRI	-							-	-						
763	XA -9002 -M	BEACON	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION FIRE ALARM BEACON - AMBER	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
764	XA -9004 -M	BEACON	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION FIRE ALARM BEACON - AMBER	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
765	XA -9007 -M	BEACON	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION FIRE ALRM BEACON - RED	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
766	XA -9009 -M	BEACON	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION FIRE ALRM BEACON - RED	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
767	XA -9012 -M	BEACON	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION TOXIC GAS ALARM BEACON - BLUE	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
768	XA -9014 -M	BEACON	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION TOXIC GAS ALARM BEACON - BLUE	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
769	XA -9016 -M	BEACON	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION FIRE ALARM BEACON - AMBER	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
770	XA -9017 -M	BEACON	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION FIRE ALRM BEACON - RED	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 71 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
771	XA -9018 -M	BEACON	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION TOXIC GAS ALARM BEACON - BLUE	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
772	XA -9019 -M	BEACON	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION FIRE ALARM BEACON - AMBER	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
773	XA -9020 -M	BEACON	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION TOXIC GAS ALARM BEACON - RED	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
774	XA -9021 -M	BEACON	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		SUBSTATION TOXIC GAS ALARM BEACON - BLUE	-	SUB	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
775	XA -9025 -M	BEACON	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS						0	PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS ROOM-3 FLAMMABLE GAS ALARM BEACON - AMBER	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
776	XA -9026 -M	BEACON	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS ROOM-3 FIRE ALARM BEACON - RED	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
777	XA -9027 -M	BEACON	PJ6-EXD-MRI-FZ0A-0002	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		ICSS ROOM-3 TOXIC GAS ALARM BEACON - BLUE	-	ICSS CAB ROOM-3	2 WIRE							-	PJ6-EXD-MRI-YCPA-0002	TBD					
778	XA -9501-M	BEACON	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		PWT AREA FLAMMABLE GAS ALRM BEACON-AMBER	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
779	XA -9502-M	BEACON	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		PWT AREA TOXIC GAS ALRM BEACON-BLUE	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
780	XA -9503-M	BEACON	PJ6-EXD-MRI-FZ0A-0003	-	Ex'd' / NIS							PJ6-EXD-GEN-YZ0H-0004	-	TBD	*	2			
		PWT AREA TOXIC GAS ALRM BEACON-RED	-	MRI	2 WIRE							PJ6-EXD-MRI-YZ0A-0001	-	TBD					
781	XI -120 TF	START PERMISSIVE	PJ6-EXD-MRI-BQDA-0027	-	NIS								-			2			
		HEATER H120TF START PERMISSIVE	-	MRI	-							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 72 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
782	XI -801 TF	START PERMISSIVE	PJ6-EXD-MRI-BQDA-0027	-	NIS								-			2			
		HEATER H801TF START PERMISSIVE	-	MRI	-								-						
783	XL -8050 TF	LEVEL 1 INDICATION	-	-	NIS								-			2			
		LEVEL 1 TOTAL PROD SHDWN - MRI LAMP INDICATION	-	MRI	2 WIRE								-						
784	XS -010 CTF	PERMISSIVE TO START	PJ6-EXD-MRI-BQDA-0025	-	NIS								-			2			
		CMPRSR C-010C START PERMISSIVE	-	MRI	-								-						
785	XS -012 CTF	REMOTE STOP COMMAND	PJ6-EXD-MRI-BQDA-0025	-	NIS								-			2			
		CMPRSR C-010C STOP COMMAND	-	MRI	-								-						
786	XS -013 CTF	TRIP COMMAND	PJ6-EXD-MRI-BQDA-0025	-	NIS								-			2			
		CMPRSR C-010C TRIP COMMAND	-	MRI	-								-						
787	XS -101 ETF	PERMISSIVE TO START	PJ6-EXD-MRI-BQDA-0026	-	NIS								-			2			
		CMPRSR K-101E START PERMISSIVE	-	MRI	-								-						
788	XS -103 ETF	REMOTE STOP COMMAND	PJ6-EXD-MRI-BQDA-0026	-	NIS								-			2			
		CMPRSR K-101E STOP COMMAND	-	MRI	-								-						
789	XS -104 ETF	TRIP COMMAND	PJ6-EXD-MRI-BQDA-0026	-	NIS								-			2			
		CMPRSR K-101E TRIP COMMAND	-	MRI	-								-						
790	XS -121 TF	REMOTE STOP COMMAND	PJ6-EXD-MRI-BQDA-0027	-	NIS								-			2			
		HEATER H120TF STOP COMMAND	-	MRI	-								-						
791	XS -122 TF	TRIP COMMAND	PJ6-EXD-MRI-BQDA-0027	-	NIS								-			2			
		HEATER H120TF TRIP COMMAND	-	MRI	-								-						
792	XS -8001 TF	PIG SIGNALLER	PJ6-EXD-MRI-BQDA-0022	-	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0010-010	-	TBD	*	2			
		FRM PIG LNCR CFP-MRI LINE PIG SIGNALLER	30" MULTIPHASE PIPELINE APL 5L GR X65	MRI	2 Wire							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					

FD شركة نفط أبوظبي المحدودة (اليابان) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 73 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
793	XS -8002 TF	PIG SIGNALLER	PJ6-EXD-MRI-BQDA-0022	V-805-TF	Ex"d" / NIS							PJ6-EXD-GEN-YZ0H-0010-011	-	TBD	*	2			
		PIG RCVR PIG SIGNALLER	-	MRI	2 Wire							PJ6-EXD-MRI-YZ0A-0001	PJ6-EXD-MRI-YCPA-0002	TBD					
794	XS -8011 TF	RUNNING STATUS	PJ6-EXD-MRI-QH0A-0008	-	NIS								-			2			
		NEW SUB STATION HVAC SYSTEM RUNNING STATUS	-	MRI	-							-	-						
795	XS -8012 TF	FAILURE STATUS	PJ6-EXD-MRI-QH0A-0008	-	NIS								-			2			
		NEW SUB STATION HVAC SYSTEM POWER FAILURE STATUS	-	MRI	-							-	-						
796	XS -8013 TF	COMMON ALARM	PJ6-EXD-MRI-QH0A-0008	-	-								-			2			
		NEW SUB STATION HVAC SYSTEM COMMON ALARM	-	MRI	-							-	-						
797	XS -8014 TF	COMMON ALARM	PJ6-EXD-MRI-QH0A-0008	-	-								-			2			
		NEW SUB STATION HVAC SYSTEM TEMPERATURE STATUS	-	MRI	-							-	-						
798	XS -8015 TF	COMMON ALARM	PJ6-EXD-MRI-QH0A-0008	-	-								-			2			
		NEW SUB STATION HVAC SYSTEM OFF STATUS	-	MRI	-							-	-						
799	XS -8016 TF	COMMON ALARM	PJ6-EXD-MRI-QH0A-0008	-	-								-			2			
		NEW SUB STATION HVAC SYSTEM TRIP STATUS	-	MRI	-							-	-						
800	XS -8017 TF	COMMON ALARM	PJ6-EXD-MRI-QH0A-0008	-	-								-			2			
		NEW SUB STATION HVAC SYSTEM HIGH HUMIDITY ALARM	-	MRI	-							-	-						
801	XS -8019 TF	COMMON ALARM	PJ6-EXD-MRI-QH0A-0008	-	-								-			2			
		STANDBY BATTERY ROOM EXHOUST FAN START COMMAND	-	MRI	-							-	-						
802	XS -802 TF	REMOTE STOP COMMAND	PJ6-EXD-MRI-BQDA-0027	-	NIS								-			2			
		HEATER H801TF STOP COMMAND	-	MRI	-							-	-						
803	XS -8020 TF	COMMON ALARM	PJ6-EXD-MRI-QH0A-0008	-	-								-			2			
		HVAC SYSTEM RE-CIRCULATION MODE SIGNAL	-	MRI	-							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 74 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
804	XS -8021 TF	SYSTEM STATUS	-	-	NIS								-			2			
		FIRE IN NEW SUBSTATION/ICSS-3	-	MRI	-							-	-						
805	XS -8022 TF	SYSTEM STATUS	-	-	NIS								-			2			
		NEW SUBSTATION/ICSS-3 INERGEN DISCHARGED	-	MRI	-							-	-						
806	XS -8023 TF	COMMON FAULT	-	-	NIS								-			2			
		NEW SUBSTATION/ICSS-3 FAECP FAULT	-	MRI	2 WIRE							-	-						
807	XS -8024 TF	SYSTEM STATUS	-	-	NIS								-			2			
		NEW SUBSTATION/ICSS-3 FAECP ACK FRM FGS	-	MRI	-							-	-						
808	XS -8025 TF	SYSTEM STATUS	-	-	NIS								-			2			
		NEW SUBSTATION/ICSS-3 FAECP SILENCE FRM FGS	-	MRI	-							-	-						
809	XS -8026 TF	STATUS SIGNAL	PJ6-EXD-GEN-EZ0L-0001	-	NIS								-			2			
		460V MCS-8002-TF INCOMER CB ON STATUS	-	MRI	2 WIRE							-	-						
810	XS -8027 TF	STATUS SIGNAL	PJ6-EXD-GEN-EZ0L-0001	-	NIS								-			2			
		460V MCS-8002-TF INCOMER CB OFF STATUS	-	MRI	2 WIRE							-	-						
811	XS -8028 TF	STATUS SIGNAL	PJ6-EXD-GEN-EZ0L-0001	-	NIS								-			2			
		460V MCS-8002-TF INCOMER TRIP STATUS	-	MRI	2 WIRE							-	-						
812	XS -8029 TF	GENERAL ALARM	PJ6-EXD-GEN-EZ0L-0001	-	NIS								-			2			
		460V MCS-8002-TF INCOMER OCR ALARM	-	MRI	2 WIRE							-	-						
813	XS -803 TF	TRIP COMMAND	PJ6-EXD-MRI-BQDA-0027	-	NIS								-			2			
		HEATER H801TF TRIP COMMAND	-	MRI	-							-	-						
814	XS -8030 TF	GENERAL ALARM	PJ6-EXD-GEN-EZ0L-0001	-	NIS								-			2			
		AC/DC UPS BYPASS-1 DC-8001-TF COMMON FAULT	-	MRI	2 WIRE							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 75 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
815	XS -8031 TF	GENERAL ALARM	PJ6-EXD-GEN-EZ0L-0001	-	NIS								-			2			
		NON UPS LOADS DP-8001-TF COMMON FAULT	-	MRI	2 WIRE							-	-						
816	XS -8032 TF	GENERAL ALARM	PJ6-EXD-GEN-EZ0L-0001	-	NIS								-			2			
		460 V HVAC PANEL FEEDER COMMON FAULT	-	MRI	2 WIRE							-	-						
817	XS -8033 TF	GENERAL ALARM	PJ6-EXD-GEN-EZ0L-0001	-	NIS								-			2			
		MOV DB DP-8004-TF COMMON FAULT	-	MRI	2 WIRE							-	-						
818	XS -8034 TF	GENERAL ALARM	PJ6-EXD-GEN-EZ0L-0001	-	NIS								-			2			
		AC/DCUPS DC-8001-TF COMMON FAULT	-	MRI	2 WIRE							-	-						
819	XS -8035 TF	GENERAL ALARM	PJ6-EXD-GEN-EZ0L-0001	-	NIS								-			2			
		AC/DC UPS DC-8001-TF COMMON FAULT-1	-	MRI	2 WIRE							-	-						
820	XS -8036 TF	COMMAND SIGNAL	PJ6-EXD-GEN-EZ0L-0001	-	NIS								-			2			
		AC/DC UPS DC-8001-TF BATTERY IN OPERATION	-	MRI	2 WIRE							-	-						
821	XS -8037 TF	GENERAL ALARM	PJ6-EXD-GEN-EZ0L-0001	-	NIS								-			2			
		AC/DC UPS DC-8001-TF DISTRIBUTION FDR TRIPPED FDBK	-	MRI	2 WIRE							-	-						
822	XS -8038 TF	COMMAND SIGNAL	PJ6-EXD-GEN-EZ0L-0001	-	NIS								-			2			
		AC/DC UPS DC-8001-TF BATTERY DISCONNECT	-	MRI	2 WIRE							-	-						
823	XS -8039 TF	GENERAL ALARM	PJ6-EXD-GEN-EZ0L-0001	-	NIS								-			2			
		AC/DC UPS DC-8001-TF BATTERY DISCONNECTION CMD	-	MRI	2 WIRE							-	-						
824	XS -8511 TF	STATUS SIGNAL	-	-	NIS								-			2			
		PCS-SYS-105 PCS SYSTEM CABINET TEMPERATURE ALARM	-	MRI	2 WIRE							-	-						
825	XS -8512 TF	STATUS SIGNAL	-	-	NIS								-			2			
		PCS-SYS-105 PCS SYSTEM CABINET FAN FAIL ALARM	-	MRI	2 WIRE							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 76 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
826	XS -8513 TF	STATUS SIGNAL	-	-	NIS								-			2			
		PCS-IFP-612 PCS ANALOG CABINET TEMPERATURE ALARM	-	MRI	2 WIRE							-	-						
827	XS -8514 TF	STATUS SIGNAL	-	-	NIS								-			2			
		PCS-IFP-612 PCS ANALOG CABINET FAN FAIL ALARM	-	MRI	2 WIRE							-	-						
828	XS -8515 TF	STATUS SIGNAL	-	-	NIS								-			2			
		PCS-IFP-613 PCS DIGITAL CABINET TEMPERATURE ALARM	-	MRI	2 WIRE							-	-						
829	XS -8516 TF	STATUS SIGNAL	-	-	NIS								-			2			
		PCS-IFP-613 PCS DIGITAL CABINET FAN FAIL ALARM	-	MRI	2 WIRE							-	-						
830	XS -8517 TF	STATUS SIGNAL	-	-	NIS								-			2			
		PCS-IFP-613 PCS DIGITAL CABINET POWER FAIL ALARM	-	MRI	2 WIRE							-	-						
831	XS -8518 TF	STATUS SIGNAL	-	-	NIS								-			2			
		PCS-IFP-612 PCS MAR CABIN EARTH LKGE MONTR ALARM	-	MRI	2 WIRE							-	-						
832	XS -8519 TF	STATUS SIGNAL	-	-	NIS								-			2			
		NW-SYS-116 NETWORK CABINET TEMPERATURE ALARM	-	MRI	2 WIRE							-	-						
833	XS -8520 TF	STATUS SIGNAL	-	-	NIS								-			2			
		NW-SYS-116 NETWORK CABINET FAN FAIL ALARM	-	MRI	2 WIRE							-	-						
834	XS -8521 TF	STATUS SIGNAL	-	-	NIS								-			2			
		NW-SYS-117 NETWORK CABINET TEMPERATURE ALARM	-	MRI	2 WIRE							-	-						
835	XS -8522 TF	STATUS SIGNAL	-	-	NIS								-			2			
		NW-SYS-117 NETWORK CABINET FAN FAIL ALARM	-	MRI	2 WIRE							-	-						
836	XS -8523 TF	STATUS SIGNAL	-	-	NIS								-			2			
		NW-SYS-117 NETWORK CABINET POWER FAIL ALARM	-	MRI	2 WIRE							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 77 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
837	XS -8524 TF	STATUS SIGNAL	-	-	NIS								-			2			
		PCS-IFP-613 PCS MAR TER BOARD PWR SUPPLY ALARM	-	MRI	2 WIRE							-	-						
838	XS -8525 TF	STATUS SIGNAL	-	-	NIS								-			2			
		PCS-IFP-613 PCS MAR TER BOARD PWR SUPPLY ALARM	-	MRI	2 WIRE							-	-						
839	XS -8526 TF	STATUS SIGNAL	-	-	NIS								-			2			
		PROGRAM ENABLE KEY SCS1107	-	MRI	2 WIRE							-	-						
840	XS -8527 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET DOOR OPEN ALARM ESD-SYS-106	-	MRI	2 WIRE							-	-						
841	XS -8528 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET TEMPERATURE ALARM ESD-SYS-106	-	MRI	2 WIRE							-	-						
842	XS -8529 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET FAN FAILURE ALARM ESD-SYS-106	-	MRI	2 WIRE							-	-						
843	XS -8530 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET DOOR OPEN ALARM ESD-IFP-614	-	MRI	2 WIRE							-	-						
844	XS -8531 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET TEMPERATURE ALARM ESD-IFP-614	-	MRI	2 WIRE							-	-						
845	XS -8532 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET FAN FAILURE ALARM ESD-IFP-614	-	MRI	2 WIRE							-	-						
846	XS -8533 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET DOOR OPEN ALARM ESD-IFP-615	-	MRI	2 WIRE							-	-						
847	XS -8534 TF	STATUS SIGNAL	-	-	NIS								-			2			
		TERMINAL BOARD PSU FAILURE ALARM ESD-IFP-615	-	MRI	2 WIRE							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 78 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
848	XS -8535 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET TEMPERATURE ALARM ESD-IFP-615	-	MRI	2 WIRE							-	-						
849	XS -8536 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET FAN FAILURE ALARM ESD-IFP-615	-	MRI	2 WIRE							-	-						
850	XS -8537 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET PSU FAILURE ALARM ESD-IFP-615	-	MRI	2 WIRE							-	-						
851	XS -8538 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET ELM ALARM ESD-IFP-615	-	MRI	2 WIRE							-	-						
852	XS -8539 TF	STATUS SIGNAL	-	-	NIS								-			2			
		PROGRAM ENABLE KEY SCS1108	-	MRI	2 WIRE							-	-						
853	XS -8540 TF	STATUS SIGNAL	-	-	NIS								-			2			
		ESD-IFP-615 ESD MAR TER BOARD POWER SUPPLY ALARM	-	MRI	2 WIRE							-	-						
854	XS -8541 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET TEMPERATURE ALARM FGS-SYS-107	-	MRI	2 WIRE							-	-						
855	XS -8542 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET FAN FAILURE ALARM FGS-SYS-107	-	MRI	2 WIRE							-	-						
856	XS -8543 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET DOOR OPEN ALARM FGS-IFP-616	-	MRI	2 WIRE							-	-						
857	XS -8544 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET TEMPERATURE ALARM FGS-IFP-616	-	MRI	2 WIRE							-	-						
858	XS -8545 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET FAN FAILURE ALARM FGS-IFP-616	-	MRI	2 WIRE							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 79 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
859	XS -8546 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET PSU FAILURE ALARM FGS-IFP-616	-	MRI	2 WIRE							-	-						
860	XS -8547 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET ELM ALARM FGS-IFP-616	-	MRI	2 WIRE							-	-						
861	XS -8548 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET DOOR OPEN ALARM FGS-IFP-617	-	MRI	2 WIRE							-	-						
862	XS -8549 TF	STATUS SIGNAL	-	-	NIS								-			2			
		TERMINAL BOARD PSU FAILURE ALARM FGS-IFP-617	-	MRI	2 WIRE							-	-						
863	XS -8550 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET TEMPERATURE ALARM FGS-IFP-617	-	MRI	2 WIRE							-	-						
864	XS -8551 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET FAN FAILURE ALARM FGS-IFP-617	-	MRI	2 WIRE							-	-						
865	XS -8552 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET PSU FAILURE ALARM FGS-IFP-617	-	MRI	2 WIRE							-	-						
866	XS -8553 TF	STATUS SIGNAL	-	-	NIS								-			2			
		CABINET ELM ALARM FGS-IFP-617	-	MRI	2 WIRE							-	-						
867	XY -8018 TF	TRIP COMMAND	PJ6-EXD-MRI-QH0A-0008	-	NIS								-			2			
		NEW SUB STATION HVAC CONFIRMED FIRE &GAS TRIP	-	MRI	-							-	-						
868	XY -8200 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8200 OPEN/CLOSE	-	MRI	-							-	-						
869	XY -8201 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8201 OPEN/CLOSE	-	MRI	-							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 80 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
870	XY -8202 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8202 OPEN/CLOSE	-	MRI	-							-	-						
871	XY -8203 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8203 OPEN/CLOSE	-	MRI	-							-	-						
872	XY -8204 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8204 OPEN/CLOSE	-	MRI	-							-	-						
873	XY -8205 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8205 OPEN/CLOSE	-	MRI	-							-	-						
874	XY -8206 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8206 OPEN/CLOSE	-	MRI	-							-	-						
875	XY -8207 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8207 OPEN/CLOSE	-	MRI	-							-	-						
876	XY -8208 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8208 OPEN/CLOSE	-	MRI	-							-	-						
877	XY -8209 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8209 OPEN/CLOSE	-	MRI	-							-	-						
878	XY -8210 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8210 OPEN/CLOSE	-	MRI	-							-	-						
879	XY -8211 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8211 OPEN/CLOSE	-	MRI	-							-	-						
880	XY -8212 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8212 OPEN/CLOSE	-	MRI	-							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YCOS-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 81 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
881	XY -8213 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8213 OPEN/CLOSE	-	MRI	-							-	-						
882	XY -8214 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8214 OPEN/CLOSE	-	MRI	-							-	-						
883	XY -8215 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8215 OPEN/CLOSE	-	MRI	-							-	-						
884	XY -8216 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8216 OPEN/CLOSE	-	MRI	-							-	-						
885	XY -8217 TF	SOLENOID VALVE	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8217 OPEN/CLOSE	-	MRI	-							-	-						
886	XZSC -8200 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8200 CLOSED STATUS	-	MRI	-							-	-						
887	XZSC -8201 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8201 CLOSED STATUS	-	MRI	-							-	-						
888	XZSC -8202 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8202 CLOSED STATUS	-	MRI	-							-	-						
889	XZSC -8203 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8203 CLOSED STATUS	-	MRI	-							-	-						
890	XZSC -8204 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8204 CLOSED STATUS	-	MRI	-							-	-						
891	XZSC -8205 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8205 CLOSED STATUS	-	MRI	-							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 82 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
892	XZSC -8206 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8206 CLOSED STATUS	-	MRI	-							-	-						
893	XZSC -8207 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8207 CLOSED STATUS	-	MRI	-							-	-						
894	XZSC -8208 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8208 CLOSED STATUS	-	MRI	-							-	-						
895	XZSC -8209 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8209 CLOSED STATUS	-	MRI	-							-	-						
896	XZSC -8210 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8210 CLOSED STATUS	-	MRI	-							-	-						
897	XZSC -8211 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8211 CLOSED STATUS	-	MRI	-							-	-						
898	XZSC -8212 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8212 CLOSED STATUS	-	MRI	-							-	-						
899	XZSC -8213 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8213 CLOSED STATUS	-	MRI	-							-	-						
900	XZSC -8214 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8214 CLOSED STATUS	-	MRI	-							-	-						
901	XZSC -8215 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8215 CLOSED STATUS	-	MRI	-							-	-						
902	XZSC -8216 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8216 CLOSED STATUS	-	MRI	-							-	-						

FD شركة نفط أبوظبي المحدودة (البحرين) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												REJLERS					
		Instrument and F&G Index - Mubarraz Island																	
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC CONSULTANT No. P5901055												Document No.: PJ6-EXD-MRI-YC0S-0001					
		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2			Sheet 83 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.			
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model					
903	XZSC -8217 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8217 CLOSED STATUS	-	MRI	-							-	-						
904	XZSO -8200 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8200 OPEN STATUS	-	MRI	-							-	-						
905	XZSO -8201 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8201 OPEN STATUS	-	MRI	-							-	-						
906	XZSO -8202 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8202 OPEN STATUS	-	MRI	-							-	-						
907	XZSO -8203 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8203 OPEN STATUS	-	MRI	-							-	-						
908	XZSO -8204 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8204 OPEN STATUS	-	MRI	-							-	-						
909	XZSO -8205 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8205 OPEN STATUS	-	MRI	-							-	-						
910	XZSO -8206 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8206 OPEN STATUS	-	MRI	-							-	-						
911	XZSO -8207 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8207 OPEN STATUS	-	MRI	-							-	-						
912	XZSO -8208 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8208 OPEN STATUS	-	MRI	-							-	-						
913	XZSO -8209 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2			
		XV-8209 OPEN STATUS	-	MRI	-							-	-						

FD شركة نفط أبوظبي المحدودة (الإمارات) Abu Dhabi Oil Co., Ltd (Japan)		PROJECT: Detailed Engineering for Mubarraz Redevelopment Project(EPC Phase)												AREJLERS				
		Instrument and F&G Index - Mubarraz Island																
		ADOC CONSULTANT No. P5901055										Document No.: PJ6-EXD-MRI-YC0S-0001						
PMC: DORSCH Holding GmbH-Abu Dhabi		ADOC PROJECT NO.PJ-2025-CR-002												REV: 2		Sheet 84 of 84		
SL.No	Tag Number	Instrument Type	PID Number	EQPT Number	Ex Class(IS/NIS)	Instrument Range			Calibration Range			Datasheet No.	Hook up Dwg No	Manufacturer	Remarks	Rev.		
		Service Description	Line No.	Location	Power Supply	Min	Max	Unit	Min	Max	Unit	Loop Dwg No.	Location Layout No	Model				
914	XZSO -8210 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2		
		XV-8210 OPEN STATUS	-	MRI	-							-	-					
915	XZSO -8211 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2		
		XV-8211 OPEN STATUS	-	MRI	-							-	-					
916	XZSO -8212 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2		
		XV-8212 OPEN STATUS	-	MRI	-							-	-					
917	XZSO -8213 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2		
		XV-8213 OPEN STATUS	-	MRI	-							-	-					
918	XZSO -8214 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2		
		XV-8214 OPEN STATUS	-	MRI	-							-	-					
919	XZSO -8215 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2		
		XV-8215 OPEN STATUS	-	MRI	-							-	-					
920	XZSO -8216 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2		
		XV-8216 OPEN STATUS	-	MRI	-							-	-					
921	XZSO -8217 TF	LIMIT SWITCH	P250001-PLK00C01001	-	Ex"d" / NIS								-			2		
		XV-8217 OPEN STATUS	-	MRI	-							-	-					