

## CHAPTER 2

### DEFINITIONS

#### 201.0 General

For the purpose of this Code, the following terms have the meanings indicated in this chapter.

No attempt is made to define ordinary words which are used in accordance with their established dictionary meanings, except where a word has been used loosely and it is necessary to define its meaning as used in this Code to avoid misunderstanding.

The definitions of terms are arranged alphabetically according to the first word of the term.

#### 202.0 Definition of Terms

##### 203.0

##### – A –

**ABS** – Acrylonitrile-Butadiene-Styrene.

**Accessible** – When applied to a fixture, connection, appliance, or equipment, “accessible” means having access thereto, but which first may require the removal of an access panel, door, or similar obstruction. “Readily accessible” means direct access without the necessity of removing any panel, door, or similar obstruction.

**Administrative Authority** – The individual official, board, department, or agency established and authorized by a state, county, city, or other political subdivision created by law to administer and enforce the provisions of the plumbing code as adopted or amended. This definition shall include the Administrative Authority’s duly authorized representative.

**Airbreak** – A physical separation which may be a low inlet into the indirect waste receptor from the fixture, appliance, or device indirectly connected.

**Air Chamber** – A pressure surge-absorbing device operating through the compressibility of air.

**Airgap, Drainage** – The unobstructed vertical distance through the free atmosphere between the lowest opening from any pipe, plumbing fixture, appliance or appurtenance conveying waste to the flood level rim of the receptor.

**Airgap, Water Distribution** – The unobstructed vertical distance through the free atmosphere between the lowest opening from any pipe or faucet conveying potable water to the flood level rim of any tank, vat or fixture.

**Anchors** – See Supports.

**Approved** – Accepted or acceptable under an applicable specification or standard stated or cited in this Code, or accepted as suitable for the proposed use under procedures and authority of the Administrative Authority.

**Approved Testing Agency** – An organization primarily established for purposes of testing to approved standards and approved by the Administrative Authority.

**Area Drain** – A receptor designed to collect surface or storm water from an open area.

**Aspirator** – A fitting or device supplied with water or other fluid under positive pressure which passes through an integral orifice or constriction, causing a vacuum.

##### 204.0

##### – B –

**Backflow** – The flow of water or other liquids, mixtures, or substances into the distributing pipes of a potable supply of water from any sources other than its intended source. See Back-Siphonage, Back-Pressure Backflow.

**Backflow Connection** – Any arrangement whereby backflow can occur.

**Back-Pressure Backflow** – Backflow due to an increased pressure above the supply pressure, which may be due to pumps, boilers, gravity or other sources of pressure.

**Backflow Preventer** – A device or means to prevent backflow into the potable water system.

**Back-Siphonage** – The flowing back of used, contaminated, or polluted water from a plumbing fixture or vessel into a water supply pipe due to a pressure less than atmospheric in such pipe. See Backflow.

**Backwater Valve** – A device installed in a drainage system to prevent reverse flow.

**Bathroom** – A room equipped with a shower or bathtub.

**Battery of Fixtures** – Any group of two (2) or more similar, adjacent fixtures which discharge into a common horizontal waste or soil branch.

**Boiler Blowoff** – An outlet on a boiler to permit emptying or discharge of sediment.

**Branch** – Any part of the piping system other than a main, riser, or stack.

**Branch, Fixture** – See Fixture Branch.

**Branch, Horizontal** – See Horizontal Branch.

**Branch Vent** – A vent connecting one or more individual vents with a vent stack or stack vent.

**Building** – A structure built, erected, and framed of component structural parts designed for the housing, shelter, enclosure, or support of persons, animals, or property of any kind.

**Building Drain** – That part of the lowest piping of a drainage system which receives the discharge from soil, waste, and other drainage pipes inside the walls of the building and conveys it to the building sewer beginning two (2) feet (610 mm) outside the building wall.

**Building Drain (Sanitary)** – A building drain which conveys sewage only.

**Building Drain (Storm)** – A building drain which conveys storm water or other drainage, but no sewage.

**Building Sewer** – That part of the horizontal piping of a drainage system which extends from the end of the building drain and which receives the discharge of the building drain and conveys it to a public sewer, private sewer, private sewage disposal system, or other point of disposal.

**Building Sewer (Combined)** – A building sewer which conveys both sewage and storm water or other drainage.

**Building Sewer (Sanitary)** – A building sewer which conveys sewage only.

**Building Sewer (Storm)** – A building sewer which conveys storm water or other drainage, but no sewage.

**Building Subdrain** – That portion of a drainage system which does not drain by gravity into the building sewer.

**Building Supply** – The pipe carrying potable water from the water meter or other source of water supply to a building or other point of use or distribution on the lot. Building supply shall also mean water service.

## 205.0

## – C –

**Certified Backflow Assembly Tester** – A person who has shown competence to test and maintain backflow assemblies to the satisfaction of the Administrative Authority having jurisdiction.

**Cesspool** – A lined excavation in the ground which receives the discharge of a drainage system or part thereof, so designed as to retain the organic matter and solids discharging therein, but permitting the liquids to seep through the bottom and sides.

**Chemical Waste** – See Special Wastes.

**Clarifier** – See Interceptor.

**Clear Water Waste** – Cooling water and condensate drainage from refrigeration and air-conditioning equipment; cooled condensate from steam heating systems; cooled boiler blowdown water.

**Clinic Sink** – A sink designed primarily to receive wastes from bedpans and having a flush rim, an integral trap with a visible trap seal, and the same flushing and cleansing characteristics as a water closet.

**Code** – This publication: *Uniform Plumbing Code*.

**Combination Thermostatic/Pressure Balancing Valve** – A mixing valve which senses outlet temperature and incoming hot and cold water pressure and compensates for fluctuations in incoming hot and cold water temperatures and/or pressures to stabilize outlet temperatures.

**Combination Waste and Vent System** – A specially designed system of waste piping embodying the horizontal wet venting of one or more sinks or floor drains by means of a common waste and vent pipe, adequately sized to provide free movement of air above the flow line of the drain.

**Combined Building Sewer** – See Building Sewer, (Combined).

**Common** – That part of a plumbing system which is so designed and installed as to serve more than one (1) appliance, fixture, building, or system.

**Conductor** – A pipe inside the building which conveys storm water from the roof to a storm drain, combined building sewer, or other approved point of disposal.

**Confined Space** – A room or space having a volume less than fifty (50) cubic feet per 1000 Btu/h (1.4 m<sup>3</sup>/293W) of the aggregate input rating of all fuel burning appliances installed in that space.

**Contamination** – An impairment of the quality of the potable water which creates an actual hazard to the public health through poisoning or through the spread of disease by sewage, industrial fluids or waste. Also defined as High Hazard.

**Continuous Vent** – A vertical vent that is a continuation of the drain to which it connects.

**Continuous Waste** – A drain connecting the compartments of a set of fixtures to a trap or connecting other permitted fixtures to a common trap.

**CPVC** – Chlorinated Poly (Vinyl Chloride).

**Critical Level** – The critical level (C-L or C/L) marking on a backflow prevention device or vacuum breaker is a point conforming to approved standards and established by the testing laboratory (usually

stamped on the device by the manufacturer) which determines the minimum elevation above the flood level rim of the fixture or receptor served at which the device may be installed. When a backflow prevention device does not bear a critical level marking, the bottom of the vacuum breaker, combination valve, or the bottom of any such approved device shall constitute the critical level.

**Cross-Connection** – Any connection or arrangement, physical or otherwise, between a potable water supply system and any plumbing fixture or any tank, receptor, equipment or device, through which it may be possible for non-potable, used, unclean, polluted and contaminated water, or other substances, to enter into any part of such potable water system under any condition.

## 206.0 – D –

**Department Having Jurisdiction** – The Administrative Authority, including any other law enforcement agency affected by any provision of this Code, whether such agency is specifically named or not.

**Developed Length** – The length along the center line of a pipe and fittings.

**Diameter** – Unless specifically stated, “diameter” is the nominal diameter as designated commercially.

**Domestic Sewage** – The liquid and water-borne wastes derived from the ordinary living processes, free from industrial wastes, and of such character as to permit satisfactory disposal, without special treatment, into the public sewer or by means of a private sewage disposal system.

**Downspout** – The rainleader from the roof to the building storm drain, combined building sewer, or other means of disposal located outside of the building. See Conductor and Leader.

**Drain** – Any pipe which carries waste or water-borne wastes in a building drainage system.

**Drainage System** – Includes all the piping within public or private premises, which conveys sewage or other liquid wastes to a legal point of disposal, but does not include the mains of a public sewer system or a public sewage treatment or disposal plant.

**Durham System** – A soil or waste system in which all piping is threaded pipe, tubing, or other such rigid construction, using recessed drainage fittings to correspond to the types of piping.

## 207.0 – E –

**Effective Opening** – The minimum cross-sectional area at the point of water supply discharge measured

or expressed in terms of: (1) diameter of a circle, or (2) if the opening is not circular, or the diameter of a circle of equivalent cross-sectional area. (This is applicable also to airgap.)

**Existing Work** – A plumbing system or any part thereof which has been installed prior to the effective date of this Code.

## 208.0 – F –

**Fixture Branch** – A water supply pipe between the fixture supply pipe and the water distributing pipe.

**Fixture Drain** – The drain from the trap of a fixture to the junction of that drain with any other drain pipe.

**Fixture Supply** – A water supply pipe connecting the fixture with the fixture branch.

**Fixture Unit** – A quantity in terms of which the load-producing effects on the plumbing system of different kinds of plumbing fixtures are expressed on some arbitrarily chosen scale.

**Flammable Vapor or Fumes** is the concentration of flammable constituents in air that exceeds 25 percent of its lower flammability limit (LFL).

**Flood Level** – See Flooded.

**Flood Level Rim** – The top edge of a receptor from which water overflows.

**Flooded** – A fixture is flooded when the liquid therein rises to the flood level rim.

**Flush Tank** – A tank located above or integral with water closets, urinals, or similar fixtures for the purpose of flushing the usable portion of the fixture.

**Flush Valve** – A valve located at the bottom of a tank for the purpose of flushing water closets and similar fixtures.

**Flushometer Tank** – A tank integrated within an air accumulator vessel which is designed to discharge a predetermined quantity of water to fixtures for flushing purposes.

**Flushometer Valve** – A valve which discharges a predetermined quantity of water to fixtures for flushing purposes and is actuated by direct water pressure.

## 209.0 – G –

**Gang or Group Shower** – Two or more showers in a common area.

**Grade** – The slope or fall of a line of pipe in reference to a horizontal plane. In drainage, it is usually expressed as the fall in a fraction of an inch (mm) or percentage slope per foot (meter) length of pipe.

**Grease Interceptor** – An interceptor of at least 750 gallon (2839 L) capacity to serve one (1) or more fixtures and which shall be remotely located.

**Grease Trap** – A device designed to retain grease from one (1) to a maximum of four (4) fixtures.

## 210.0 – H –

**Hangers** – See Supports.

**High Hazard** – See Contamination.

**Horizontal Branch** – A drain pipe extending laterally from a soil or waste stack or building drain with or without vertical sections or branches, which receives the discharge from one or more fixture drains and conducts it to the soil or waste stack or to the building drain.

**Horizontal Pipe** – Any pipe or fitting which is installed in a horizontal position or which makes an angle of less than forty-five (45) degrees with the horizontal.

**House Drain** – See Building Drain.

**House Sewer** – See Building Sewer.

## 211.0 – I –

**Indirect Waste Pipe** – A pipe that does not connect directly with the drainage system but conveys liquid wastes by discharging into a plumbing fixture, interceptor, or receptacle which is directly connected to the drainage system.

**Individual Vent** – A pipe installed to vent a fixture trap and which connects with the vent system above the fixture served or terminates in the open air.

**Industrial Waste** – Any and all liquid or water-borne waste from industrial or commercial processes, except domestic sewage.

**Insanitary** – A condition which is contrary to sanitary principles or is injurious to health.

Conditions to which “insanitary” shall apply include the following:

- (1) Any trap which does not maintain a proper trap seal.
- (2) Any opening in a drainage system, except where lawful, which is not provided with an approved water-sealed trap.
- (3) Any plumbing fixture or other waste discharging receptor or device, which is not supplied with water sufficient to flush and maintain the fixture or receptor in a clean condition.
- (4) Any defective fixture, trap, pipe, or fitting.
- (5) Any trap, except where in this Code exempted, directly connected to a drainage

system, the seal of which is not protected against siphonage and back-pressure by a vent pipe.

(6) Any connection, cross-connection, construction or condition, temporary or permanent, which would permit or make possible by any means whatsoever, for any unapproved foreign matter to enter a water distribution system used for domestic purposes.

(7) The foregoing enumeration of conditions to which the term “insanitary” shall apply, shall not preclude the application of that term to conditions that are, in fact, insanitary.

**Interceptor (Clarifier)** – A device designed and installed so as to separate and retain deleterious, hazardous, or undesirable matter from normal wastes and permit normal sewage or liquid wastes to discharge into the disposal terminal by gravity.

**Invert** – The lowest portion of the inside of a horizontal pipe.

## 212.0 – J –

**Joint, Brazed** – Any joint obtained by joining of metal parts with alloys which melt at temperatures higher than 840°F (449°C), but lower than the melting temperature of the parts to be joined.

**Joint, Soldered** – A joint obtained by the joining of metal parts with metallic mixtures or alloys which melt at a temperature up to and including 840°F (449°C).

## 213.0 – K –

No definitions

## 214.0 – L –

**Labeled** – Equipment or materials bearing a label of a listing agency. See Listed.

**Lavatories in Sets** – Two (2) or three (3) lavatories that are served by one (1) trap.

**Leader** – An exterior vertical drainage pipe for conveying storm water from roof or gutter drains. See Downspout.

**Liquid Waste** – The discharge from any fixture, appliance, or appurtenance in connection with a plumbing system which does not receive fecal matter.

**Listed** – Equipment or materials included in a list published by a listing agency that maintains periodic inspection on current production of listed equipment or materials and whose listing states either that the equipment or material complies with approved standards or has been tested and found suitable for use in a specified manner.

**Listing Agency** – An agency accepted by the Administrative Authority which is in the business of listing or labeling and which maintains a periodic inspection program on current production of listed products, and which makes available a published report of such listing in which specific information is included that the product has been tested to approved standards and found safe for use in a specific manner.

**Lot** – A single or individual parcel or area of land legally recorded or validated by other means acceptable to the Administrative Authority on which is situated a building or which is the site of any work regulated by this Code, together with the yards, courts, and unoccupied spaces legally required for the building or works, and which is owned by or is in the lawful possession of the owner of the building or works.

**Low Hazard** – See Pollution.

## 215.0 – M –

**Macerating Toilet System** – A system comprised of a sump with macerating pump and with connections for a water closet and other plumbing fixtures, which is designed to accept, grind and pump wastes to an approved point of discharge.

**Main** – The principal artery of any system of continuous piping to which branches may be connected.

**Main Sewer** – See Public Sewer.

**Main Vent** – The principal artery of the venting system to which vent branches may be connected.

**May** – A permissive term.

**Mobile Home Park Sewer** – That part of the horizontal piping of a drainage system which begins two (2) feet (610 mm) downstream from the last mobile home site and conveys it to a public sewer, private sewer, private sewage disposal system, or other point of disposal

## 216.0 – N –

**Nuisance** – Includes, but is not limited to:

- (1) Any public nuisance known at common law or in equity jurisprudence.
- (2) Whenever any work regulated by this Code is dangerous to human life or is detrimental to health and property.
- (3) Inadequate or unsafe water supply or sewage disposal system.

## 217.0 – O –

**Offset** – A combination of elbows or bends in a line of piping which brings one section of the pipe out of line but into a line parallel with the other section.

**Oil Interceptor** – See Interceptor.

## 218.0 – P –

**PB** – Polybutylene.

**PE** – Polyethylene.

**PEX** – Cross-linked Polyethylene.

**Person** – A natural person, his heirs, executor, administrators, or assigns and shall also include a firm, corporation, municipal or quasi-municipal corporation, or governmental agency. Singular includes plural, male includes female.

**Pipe** – A cylindrical conduit or conductor, conforming to the particular dimensions commonly known as “pipe size”.

**Plumbing** – The business, trade, or work having to do with the installation, removal, alteration, or repair of plumbing systems or parts thereof.

**Plumbing Appliance** – Any one of a special class of device or equipment which is intended to perform a special plumbing function. Its operation and/or control may be dependent upon one or more energized components, such as motors, controls, heating elements, or pressure or temperature-sensing elements. Such device or equipment may operate automatically through one or more of the following actions: a time cycle, a temperature range, a pressure range, a measured volume or weight; or the device or equipment may be manually adjusted or controlled by the user or operator.

**Plumbing Appurtenance** – A manufactured device, or a prefabricated assembly, or an on-the-job assembly of component parts, and which is an adjunct to the basic piping system and plumbing fixtures. An appurtenance demands no additional water supply, nor does it add any discharge load to a fixture or the drainage system. It performs some useful function in the operation, maintenance, servicing, economy, or safety of the plumbing system.

**Plumbing Fixture** – An approved type installed receptacle, device, or appliance which is supplied with water or which receives liquid or liquid-borne wastes and discharges such wastes into the drainage system to which it may be directly or indirectly connected. Industrial or commercial tanks, vats, and similar processing equipment are not plumbing fixtures, but may be connected to or discharged into approved traps or plumbing fixtures when and as otherwise provided for elsewhere in this Code.

**Plumbing Official** – See Administrative Authority.

**Plumbing System** – Includes all potable water building supply and distribution pipes, all plumbing fixtures and traps, all drainage and vent pipe(s), and all building drains and building sewers, including their respective joints and connection, devices, receptors, and appurtenances within the property lines of the premises and shall include potable water piping, potable water treating or using equipment, medical gas and medical vacuum systems, fuel gas piping, water heaters and vents for same.

**Pollution** – An impairment of the quality of the potable water to a degree which does not create a hazard to the public health but which does adversely and unreasonably affect the aesthetic qualities of such potable waters for domestic use. Also defined as Low Hazard.

**Potable Water** – Water which is satisfactory for drinking, culinary, and domestic purposes and meets the requirements of the health authority having jurisdiction.

**PP** – Polypropylene.

**Pressure** – The normal force exerted by a homogeneous liquid or gas, per unit of area, on the wall of the container.

(1) **Static Pressure** – The pressure existing without any flow.

(2) **Residual Pressure** – The pressure available at the fixture or water outlet after allowance is made for pressure drop due to friction loss, head, meter, and other losses in the system during maximum demand periods.

**Pressure Balancing Valve** – A mixing valve which senses incoming hot and cold water pressures and compensates for fluctuations in either, to stabilize outlet temperature.

**Private or Private Use** – Applies to plumbing fixtures in residences and apartments, to private bathrooms in hotels and hospitals, and to restrooms in commercial establishments where the fixtures are intended for the use of a family or an individual.

**Private Sewage Disposal System** – A septic tank with the effluent discharging into a subsurface disposal field, into one or more seepage pits or into a combination of subsurface disposal field and seepage pit or of such other facilities as may be permitted under the procedures set forth elsewhere in this Code.

**Private Sewer** – A building sewer which receives the discharge from more than one (1) building drain and conveys it to a public sewer, private sewage disposal system, or other point of disposal.

**Public or Public Use** – All buildings or structures that are not defined as private or private use.

**Public Sewer** – A common sewer directly controlled by public authority.

**PVC** – Polyvinyl Chloride.

## 219.0 – Q –

No definitions.

## 220.0 – R –

**Receptor** – An approved plumbing fixture or device of such material, shape, and capacity as to adequately receive the discharge from indirect waste pipes, so constructed and located as to be readily cleaned.

**Regulating Equipment** – Includes all valves and controls used in a plumbing system which are required to be accessible or readily accessible.

**Relief Vent** – A vent, the primary function of which is to provide circulation of air between drainage and vent systems or to act as an auxiliary vent on a specially designed system.

**Remote Outlet** – When used for sizing water piping, it is the furthest outlet dimension, measuring from the meter, either the developed length of the cold water piping or through the water heater to the furthest outlet on the hot water piping.

**Rim** – See Flood Level Rim.

**Riser** – A water supply pipe which extends vertically one (1) full story or more to convey water to branches or fixtures.

**Roof Drain** – A drain installed to receive water collecting on the surface of a roof and to discharge it into a leader, downspout, or conductor.

**Roughing-In** – The installation of all parts of the plumbing system which can be completed prior to the installation of fixtures. This includes drainage, water supply, gas piping, and vent piping and the necessary fixture supports.

## 221.0 – S –

**Sand Interceptor** – See Interceptor.

**SDR** – An abbreviation for “standard dimensional ratio,” which is the specific ratio of the average specified outside diameter to the minimum wall thickness for outside controlled diameter plastic pipe.

**Seepage Pit** – A lined excavation in the ground which receives the discharge of a septic tank so designed as to permit the effluent from the septic tank to seep through its bottom and sides.

**Septic Tank** – A watertight receptacle which receives the discharge of a drainage system or part

thereof, designed and constructed so as to retain solids, digest organic matter through a period of detention and allow the liquids to discharge into the soil outside of the tank through a system of open joint piping or a seepage pit meeting the requirements of this Code.

**Sewage** – Any liquid waste containing animal or vegetable matter in suspension or solution and may include liquids containing chemicals in solution.

**Sewage Ejector** – A device for lifting sewage by entraining it in a high-velocity jet of steam, air or water.

**Sewage Pump** – A permanently installed mechanical device, other than an ejector, for removing sewage or liquid waste from a sump.

**Shall** – A mandatory term.

**Shielded Coupling** – An approved elastomeric sealing gasket with an approved outer shield and a tightening mechanism.

**Shock Arrestor** – See Water Hammer Arrestor.

**Single Family Dwelling** – A building designed to be used as a home by the owner of such building, which shall be the only dwelling located on a parcel of ground with the usual accessory buildings.

**Size and Type of Tubing** – See Diameter.

**Slip Joint** – An adjustable tubing connection, consisting of a compression nut, a friction ring, and a compression washer, designed to fit a threaded adapter fitting, or a standard taper pipe thread.

**Slope** – See Grade.

**Soil Pipe** – Any pipe which conveys the discharge of water closets, urinals, clinic sinks or fixtures having similar functions of collection and removal of domestic sewage, with or without the discharge from other fixtures to the building drain or building sewer.

**Special Wastes** – Wastes which require some special method of handling such as the use of indirect waste piping and receptors, corrosion resistant piping, sand, oil or grease interceptors, condensers, or other pretreatment facilities.

**Stack** – The vertical main of a system of soil, waste or vent piping extending through one or more stories.

**Stack Vent** – The extension of a soil or waste stack above the highest horizontal drain connected to the stack.

**Storm Drain** – See Building Drain (Storm).

**Storm Sewer** – A sewer used for conveying rainwater, surface water, condensate, cooling water, or similar liquid wastes.

**Subsoil Drain** – A drain which collects subsurface or seepage water and conveys it to a place of disposal.

**Sump** – An approved tank or pit which receives sewage or liquid waste and which is located below the normal grade of the gravity system and which must be emptied by mechanical means.

**Supports** – Supports, hangers, and anchors are devices for properly supporting and securing pipe, fixtures, and equipment.

## 222.0

## – T –

**Tailpiece** – The pipe or tubing that connects the outlet of a plumbing fixture to a trap.

**Thermostatic (Temperature Control) Valve** – A mixing valve which senses outlet temperature and compensates for fluctuations in incoming hot or cold water temperatures.

**Trap** – A fitting or device so designed and constructed as to provide, when properly vented, a liquid seal which will prevent the back passage of air without materially affecting the flow of sewage or waste water through it.

**Trap Arm** – That portion of a fixture drain between a trap and the vent.

**Trap Primer** – A device and system of piping that maintains a water seal in a remote trap.

**Trap Seal** – The vertical distance between the crown weir and the top dip of the trap.

**Crown Weir (Trap Weir)** – the lowest point in the cross section of the horizontal waterway at the exit of the trap.

**Top Dip (of Trap)** – the highest point in the internal cross section of the trap at the lowest part of the bend (inverted siphon). By contrast, the bottom dip is the lowest point in the internal cross section.

## 223.0

## – U –

**Unconfined Space** – A room or space having a volume equal to at least 50 cubic feet per 1000 Btu/h (1.4 m<sup>3</sup>/293W) of the aggregate input rating of all fuel-burning appliances installed in that space. Rooms communicating directly with the space in which the appliances are installed, through openings not furnished with doors, are considered a part of the unconfined space.

**Unsanitary (Insanitary)** – See Insanitary.

## 224.0

## – V –

**Vacuum** – Any pressure less than that exerted by the atmosphere.

**Vacuum Breaker** – See Backflow Preventer.

**Vacuum Relief Valve** – A device that prevents excessive vacuum in a pressure vessel.

**Vent** – Any pipe provided to ventilate a plumbing system, to prevent trap siphonage and back pressure, or to equalize the air pressure within the drainage system.

#### **Vented Appliance Categories**

**Category I** is an appliance which operates with a non-positive vent static pressure and with a vent gas temperature that avoids excessive condensate production in the vent.

**Category II** is an appliance which operates with a non-positive vent static pressure and with a vent gas temperature that may cause excessive condensate production in the vent.

**Category III** is an appliance which operates with a positive vent static pressure and with a vent gas temperature that avoids excessive condensate production in the vent.

**Category IV** is an appliance which operates with a positive vent static pressure and with a vent gas temperature that may cause excessive condensate production in the vent.

**Vent Pipe** – See Vent.

**Vent Stack** – The vertical vent pipe installed primarily for the purpose of providing circulation of air to and from any part of the drainage system.

**Vent System** – A pipe or pipes installed to provide a flow of air to or from a drainage system or to provide a circulation of air within such system to protect trap seals from siphonage and back-pressure.

**Vertical Pipe** – Any pipe or fitting which is installed in a vertical position or which makes an angle of not more than forty-five (45) degrees with the vertical.

#### **225.0 – W –**

**Wall-Hung Water Closet** – A water closet installed in such a way that no part of the water closet touches the floor.

**Waste** – See Liquid Waste and Industrial Waste.

**Waste Pipe** – A pipe which conveys only liquid waste, free of fecal matter.

**Water Conditioning or Treating Device** – A device which conditions or treats a water supply so as to change its chemical content or remove suspended solids by filtration.

**Water-Distributing Pipe** – In a building or premises, a pipe which conveys potable water from the building supply pipe to the plumbing fixtures and other water outlets.

**Water Hammer Arrestor** – A device to absorb hydraulic shock, either of the air chamber or mechanical device design.

**Water Main (Street Main)** – A water-supply pipe for public or community use.

**Water Supply System** – The building supply pipe, the water distributing pipes and the necessary connecting pipes, fittings, control valves, backflow prevention devices and all appurtenances carrying or supplying potable water in or adjacent to the building or premises.

**Welded Joint or Seam** – Any joint or seam obtained by the joining of metal parts in the plastic molten state.

**Welder, Pipe** – A person who specializes in welding of pipes and holds a valid certificate of competency from a recognized testing laboratory, based on the requirements of the A.S.M.E. Boiler and Pressure Vessels Code, Section IX.

**Wet Vent** – A vent which also serves as a drain.

**Whirlpool Bathtub** – A bathtub fixture equipped and fitted with a circulating piping system designed to accept, circulate and discharge bathtub water upon each use.

#### **226.0 – X –**

No definitions.

#### **227.0 – Y –**

**Yoke Vent** – A pipe connecting upward from a soil or waste stack to a vent stack for the purpose of preventing pressure changes in the stacks.

#### **228.0 – Z –**

No definitions.