

Table 13 Oxygen: design and diversified flows

Department	Design flow for each terminal unit (L/min)	Diversified flow Q (L/min)
In-patient accommodation (ward units): Single 4-bed rooms and treatment room Ward block/department	10 10	$Q_w = 10 + [(n-1)6/4]$ $Q_d = Q_w[1 + (nW-1)/2]$
Accident & emergency: Resuscitation room, per trolley space Major treatment/plaster room, per trolley space Post-anaesthesia recovery, per trolley space Treatment room/cubicle	100 10 10 10	$Q = 100 + [(n-1)6/4]$ $Q = 10 + [(n-1)6/4]$ $Q = 10 + [(n-1)6/8]$ $Q = 10 + [(n-1)6/10]$
Operating: Anaesthetic rooms Operating rooms Post-anaesthesia recovery	100 100	$Q = \text{no addition made}$ $Q = 100 + (nT-1)10$ $Q = 10 + (n-1)6$
Maternity: LDRP rooms: Mother Baby Operating suites: Anaesthetist Paediatrician Post-anaesthesia recovery In-patient accommodation: Single/multi-bed wards Nursery, per cot space Special care baby unit	10 10 100 10 10 10 10 10 10 10	$Q = 10 + [(n-1)6/4]$ $Q = 10 + [(n-1)3/2]$ $Q = 100 + (nS-1)6$ $Q = 10 + (n-1)3$ $Q = 10 + [(n-1)3/4]$ $Q = 10 + [(n-1)6/6]$ $Q = 10 + [(n-1)3/2]$ $Q = 10 + (n-1)6$
Radiological: All anaesthetic and procedures rooms	100	$Q = 10 + [(n-1)6/3]$
Critical care areas	10	$Q = 10 + [(n-1)6]3/4$
Coronary care unit (CCU)	10	$Q = 10 + [(n-1)6]3/4$
High-dependency unit (HDU)	10	$Q = 10 + [(n-1)6]3/4$
Renal	10	$Q = 10 + [(n-1)6/4]$
CPAP ventilation	75	$Q = 75n \times 75\%$
Adult mental illness accommodation: Electro-convulsive therapy (ECT) room Post-anaesthesia, per bed space	10 10	$Q = 10 + [(n-1)6/4]$ $Q = 10 + [(n-1)6/4]$
Adult acute day care accommodation: Treatment rooms Post-anaesthesia recovery per bed space	10 10	$Q = 10 + [(n-1)6/4]$ $Q = 10 + [(n-1)6/4]$
Day patient accommodation (as “In-patient accommodation”)		As “In-patient accommodation”
Oral surgery/orthodontic: Consulting rooms, type 1 Consulting rooms, types 2 & 3 Recovery room, per bed space	10 10 10	$Q = 10 + [(n-1)6/2]$ $Q = 10 + [(n-1)6/3]$ $Q = 10 + [(n-1)6/6]$
Out-patient: Treatment rooms	10	$Q = 10 + [(n-1)6/4]$
Equipment service rooms, sterile services etc	100	Residual capacity will be adequate without an additional allowance